



Your local supply, on tap



Water Resources Management Plan

2020-2080

April 2020

Page intentionally left blank

Contents

Executive Summary.....	1
Our Plan for the Central region.....	7
Our Plan for the East region.....	8
Our Plan for the Southeast region	9
1 Setting the scene.....	10
1.1 Introduction	10
1.2 Our supply regions	10
1.3 Challenges and issues	11
1.4 Developing our fWRMP19	12
1.5 The process we followed	14
2 Consulting with customers and stakeholders.....	16
2.1 Introduction	16
2.2 Consultation on our dWRMP19	16
2.3 Pre-consultation for the rdWRMP19	17
2.4 Further consultation on our rdWRMP19	18
2.5 How customers have shaped our Plan.....	18
3 The scale of the challenge – baseline supply-demand balance.....	21
3.1 Introduction	21
3.2 Water Resource Zones.....	21
3.3 Baseline demand forecast.....	24
3.4 Baseline supply forecast	37
3.5 Risk and uncertainty – target headroom	51
3.6 Baseline supply demand balance.....	54
4 Appraisal of future options	62
4.1 Introduction	62
4.2 Unconstrained options – Stage 1.....	63
4.3 Options screening – Stage 2.....	65
4.4 Developing our feasible options – Stage 3.....	67
4.5 Strategic supply options.....	69
4.6 Impacts of growth and new abstraction on regional water availability.	72
4.7 Assessing the environmental impact of options.....	73
5 Formulating our Plan	75
5.1 Introduction	75

5.2	Allowing for the Regional Context	76
5.3	Selection of the modelling process – Problem Characterisation	76
5.4	Our decision-making process for our Central region	78
5.5	Our decision-making process for our East and Southeast regions	80
5.6	Results and key decisions – Central region.....	81
	Our four futures	82
	Options selected under all our futures	84
	Tipping points for our four futures	85
5.7	Results and key decisions – East and Southeast regions.	91
5.8	Testing the Plan.....	92
	Scenario 1: Environmental impacts	93
	Scenario 2: Increased drought resilience	93
	Scenario 3: High growth.....	94
	Scenario 4: Further Reductions in Abstraction from the Chalk	94
5.9	Incorporating environmental considerations into our decision-making process.....	95
5.10	Checking compliance with technical guidance	96
6	Our best value Plan	97
6.1	Introduction	97
6.2	Our demand management strategy.....	98
6.3	Our water supply strategy for the Central region.....	108
6.4	Our adaptive strategy for the Central region	117
	Further Consultation and Engagement with Customers and Stakeholders	125
	Alignment with Thames Water in the Period 2020 to 2023	126
	Alignment with Thames Water	127
	Alignment with Thames Water	128
6.5	Our water supply strategy for the Southeast region (WRZ7)	129
6.6	Our water supply strategy for the East region (WRZ8).....	129
6.7	Environmental assessment of our Plan	130
6.8	Cost of our Plan.....	132
6.9	Final supply / demand water balances and WRMP Tables.....	134
6.10	Drought levels of service.....	138
6.11	Alignment of our Plan with other companies’ WRMPs	141
7	Regional collaboration and links to other plans	143
7.1	Introduction	143
7.2	Regional co-ordination.....	143
7.3	The National Water UK study	147

7.4	Future development of water trading	148
7.5	Links to other types of plans	149
8	Board assurance and governance	152
8.1	Introduction	152
8.2	Governance	152
8.3	Assurance	152
8.4	Summary	153
	Appendix: List of Technical Reports	154
	Abbreviation list and Glossary	155

Executive Summary

This document presents our final Water Resources Management Plan 2019 (fWRMP19). It should be read in conjunction with our Statement of Response (SoR) which summarises feedback on our revised draft WRMP 2019 (rdWRMP19) and states how we intended to revise our Plan in light of the feedback received. A separate summary document is available providing a non-technical overview of our Plan at the following location:


www.affinitywater.co.uk/waterresourcesplan

Our fWRMP19 sets out how we plan to provide a reliable, resilient, efficient and affordable water supply to customers from 2020 to 2080, whilst protecting the environment. At the core of this is the need to balance the amount of water available for supply with the demand for water.

Our plans for balancing water supply with demand include a commitment to increase our resilience to droughts which we will deliver by supporting customers to reduce demand, reducing leakage and investing in supply side capacity improvements. This fWRMP19 also includes the measures identified by the Environment Agency's (EA) Water Industry National Environment Programme, and our habitat and river restoration programmes, that contribute to improvements in Chalk stream habitats.


We operate in three geographically separate regions, Central, Southeast and East. In our Central region, as a result of planning to reduce abstraction from Chalk catchments and to improve our resilience to drought events, we face a shortfall in supply under drought conditions of 43 MI/d by 2025, rising to 256 MI/d in 2080. Available water supplies continue to fall throughout this time due to the impacts of climate change and demand increases due to population growth. We expect approximately 1.6 million more people in our Central region by 2080. The scale of the challenge that we face in our Central region is illustrated in the following graphic.

Central Region Outlook



In our Southeast region a small surplus of water exists in 2020 of 1.3 MI/d. This moves into a small deficit of 0.1 MI/d by 2045, increasing to 4.3 MI/d by 2080 due to an increasing population.


Southeast Region Outlook



MI/d = Million Litres per day

Under our current planning estimates, even after we have accounted for improvements in drought resilience, our East region is in surplus under both average and peak conditions for the duration of the planning period. The balance comes close to zero by 2080 due to an increasing population in the order of 41% by 2080, equivalent to more than 60,000 more people in our East region. Although the region is in surplus, we do face some uncertainties over the availability of water supplies as a result of ongoing environmental investigations, which could significantly affect the supply-demand balance even in the short-term.

East Region Outlook



MI/d = Million Litres per day

Without investment, we face the risk of a significant shortfall of water during future drought events within our largest Central supply region, and longer-term risks within our Southeast supply region. The scale of the challenge in our Central region and the fact that it is driven by a combination of uncertain future risks (growth in demand, reductions in abstraction and climate change) means that there is a great deal of uncertainty about the exact timing and scale of the risk. If our abstractions in the East

region are reduced beyond our current expectations then this would also trigger potentially significant investment.

In response to the challenge that we face we have developed a planning process and investment programme that is both flexible to future uncertainties and ensures that we will maintain the balance between supply and demand through investments that represent the best value to customers. For the Central region that means we have adopted an ‘adaptive planning’ approach. As with conventional Water Resource Management Plans (WRMPs), such an approach contains a currently preferred set of investments that will allow us to meet the challenge. However, our Plan also shows how and when we might need to adapt in response to the uncertainties that we face.

We fully recognise that in the medium to long term we will need to rely on large scale strategic resources, which involve significant infrastructure and the associated import of water into our Central Region. With a unique position, without direct strategic supply ourselves, we are committed to acting as the promoter of a collaborative approach open to all options available for securing sustainable supply of water to customers. This includes working with and encouraging others to explore new solutions now and in the future. We were at the inception of a collaborative approach in creating WRSE and will continue to support and contribute to regional resilience planning. Our Plan is based on the thorough examination of solutions available now, and the planned investigations necessary to adapt, explore and deliver resilient water resources. We have therefore proposed an approach that keeps all appropriate options open for investigation in the shorter term, and provides us with timely alternatives if certain developments prove not to be viable. For the Southeast and East regions, we have sufficient time and control over the risks involved to allow us to maintain a more ‘conventional’ approach to investment planning.

The planning process that we have used to develop our investment programme is transparent, structured and clearly accounts for customer and stakeholder feedback, with a specific customer and stakeholder analysis stage built into the process. For our rdWRMP19 consultation we received over 800 responses from customers and stakeholders. At the same time we carried out a quantitative, representative survey of 1,000 customers to gain feedback on our revised plans. This identified some areas where clarification and increased adaptability is required in our WRMP, but confirmed that the findings and the way that we structured our decision-making process in response to customer and stakeholder feedback for the rdWRMP19 were appropriate and representative. Our customer and stakeholder analysis of all of the consultation responses that we received concluded that there is a:

- Preference for reducing abstractions from Chalk catchments to the full level proposed in the EA’s National Environment Programme, and a desire to move to a higher (1 in 200 year return period) level of drought resilience in our supply system.
- Preference for investments that will improve information for customers, helping them to reduce their demand whilst at the same time allowing us to identify and reduce leakage within customers’ properties.
- Preference for us to include ‘stretching’ ambitions for demand management and leakage reduction as part of our Plan, whilst at the same time ensuring that we can maintain future drought resilience if it is not possible to affordably achieve these ambitions. On the demand side, we need to combine the insights on customer demand, plumbing losses and customer side leakage

that we will gain from our metering programme, with a focus on helping customers to install water saving devices and support them in reducing customer side wastage.

- Lack of support for variable tariff options.
- Preference for strategic supply-side schemes that use existing infrastructure, and support for strategic reservoir development.
- Expectation that further reductions in abstraction on Chalk rivers should be considered.

Environmental considerations were also integral to the investment planning process. Within this Plan we have clearly set out how the findings from our Strategic Environmental Assessment (SEA), Habitats Risk Assessment (HRA) and Water Framework Directive (WFD) assessments shaped the nature of the options that we considered and our planning approach.

Our resulting investment programme proposes a ‘twin track’ strategic approach, whereby demand management and leakage reduction measures are introduced first, supported by improvements in our ability to import water from other water companies and schemes that strengthen our network to make best use of our existing supplies. In the longer term for the Central region we then propose to develop large strategic supply schemes, which we will develop in collaboration with other water companies and the Canal & River Trust.

For the Central region, our Plan also includes a detailed ‘adaptive strategy’, which identifies how we will monitor and respond to the uncertainties that we face, along with up-front investigative activities and investments that we will undertake to ensure we can deliver any adaptations in a timely manner. We have economically tested the costs associated with those up-front investments to make sure that our adaptive approach represents the best long-term strategy for customers. The main focus of the adaptive strategy is on the timing and nature of the strategic options that we will need in the medium and long term. We anticipate we will require the first strategic development by 2038, but our adaptive strategy will allow us to either accelerate investment if higher growth or additional environmental reductions in Chalk abstraction are required, or defer that investment and hence save customers’ money, if our monitoring of likely future risks concludes that it is prudent to do so.

Our identification of supply side options has been carried out in collaboration with regional water industry groups such as Water Resources in the South East and Water Resources in the East, and in liaison with third party partners such as the Canal & River Trust. As part of our adaptive strategy we will continue to work with those partners to ensure that our plans are complementary to the wider strategic needs within the South East of England.

We have reviewed the coverage and timing of the AMP7 (2020 – 2025) enabling actions on strategic resources contained within our adaptive strategy, to ensure that these fully align with the proposals contained within the evidence documents that water companies have submitted to the economic regulator (Ofwat) for their 2020 to 2025 five-year Business Plans.

Summary of our Demand Management Strategy

- Leakage** - We share the water industry wide ambition to reduce leakage by 50% before 2050. Our Plan provides for 18.5% leakage reduction within the 2020 to 2025 period (this is the absolute in year target, which equates to more than 20% on a rolling 3-year basis, as required in our PR19 Final Business Plan) through increasing intensity of leakage activities, innovation, efficiency and reducing customer side leakage. This represents an overall reduction of 30% leakage compared to our 2015 position. In the longer-term we will aim to achieve an overall level of 50% leakage reduction between 2015 and 2045, through further innovation and efficiencies in distribution network leakage control and customer supply pipe leakage reduction. This timescale of leakage reduction is currently five years earlier than the rest of the industry. We have also included further ambition to reduce leakage by a further 7% (to 57% from our 2015 position) so that we achieve 50% reduction from our 2020 target, by 2050.
- Per Capita Consumption (PCC)** - Our Plan sets a PCC target for consumption in a ‘normal year’ of 129 l/h/d by 2025 compared to our 2016/17 average consumption of 152 l/h/d, taking us towards industry leading levels. We then propose to continue to further reduce PCC through concerted action on water efficiency and smart metering. This ‘concerted action’ is aimed at developing wider collaboration. It includes aspirations to reduce this further (potentially as low as 110l/h/d), depending on industry wide and policy support for demand management, involving measures such as mandatory water efficient labelling and retailing of white goods and fittings.

Summary of our Supply Strategy

Central region

- Smaller Resource Options:** We have included Lower Greensand abstractions, which we are investigating with the potential of developing to a total of 6MI/d in the medium term (between 2025 and 2035). We have also identified that the existing Canal & River Trust reservoir in Brent can be utilised to deliver up to 7.5MI/d into the west of the region.
- Import from Anglian Water:** Currently we are only able to make use of around 50MI/d of our shared resource with Anglian Water. We will install a conditioning plant and network storage to allow us to increase that to its full capacity of 91MI/d by 2025 (pre impact of climate change).
- Internal transfers:** As well as facilitating the Anglian Water import, our “Supply 2040” programme allows us to build better inter-connectivity throughout our Central region to remove constraints within our distribution network that will allow us to ‘unlock’ and transfer 17MI/d of existing capacity from the south west of our Central region by 2025. Further developments in the AMP8 (2025 to 2030) period will allow us to transfer an additional 15MI/d from the south west of our Central region, and beyond that we have included schemes that will allow our strategic resource developments to be used across the region as the additional supplies become available. As a result of this strategy we have made sure that we are able to fully share water between the individual zones that make up our Central region as the balances of supply and demand in those zones change in the future.

- **Strategic supply options:** The nature and timing of strategic options is a key part of our adaptive planning process. Our main focus is on ensuring that we progress with investigations and investment in a timely manner. Our current modelling indicates that our 'best value plan' should include joint development of the South East Strategic Reservoir option with Thames Water in 2038. We intend to utilise 100ML/d of the yield capacity of the reservoir, which we will abstract and treat for supply into the south and west of the region through staged network and treatment developments. Our Plan also includes the Grand Union Canal import option, which will transfer 50ML/d of treated waste water from the Birmingham area for treatment and supply into the west of our region. Under our current 'best value' plan we anticipate needing this resource by 2065. However, within our adaptive strategy we have incorporated appropriate investigations into these and other alternative options, and 'check points' that will allow us to make sure that the nature and timing of the strategic solutions that we implement are the most appropriate for customers and the South East of England as a whole.

Southeast region

- The majority of the deficit for the Southeast region can be managed through the demand management measures. On the supply-side we will only need to agree continuation of our bulk supply arrangements with our neighbouring water companies and make relatively low cost network improvements to make best use of two of our existing sources.

East region

- Under our current plan we do not require any supply side investments in this region.

We recognise that our adaptive planning proposals represent an innovative approach to water resources planning, and we have planned out the timescales required to develop our preferred strategic option whilst allowing for all reasonable planning needs, including potential Public Inquiry if we need to progress with this option for WRMP24. A detailed timetable for this process is provided within Chapter 6 of this WRMP. This timeline is fully aligned with the proposals contained in Thames Water's WRMP.


Our Board has been actively engaged with the development of this WRMP throughout the process, from the first dWRMP through to this final proposed plan. It has commissioned and been provided with assurance that our fWRMP19 represents the most cost effective and sustainable long-term solution for managing and developing water resources.

Our Plan for the Central region

Our Plan sets out how we will provide a reliable, resilient, efficient and affordable water supply to customers from 2020 to 2080, whilst helping to protect the environment.

1. Key challenges met

Central region outlook



Our Plan addresses the need to balance the availability of water supply with the demand for water from customers. Without action, we face the risk of a significant shortfall of water in the future in this region due to population growth and climate change. We also want to help protect the environment and improve the resilience of our water supplies to droughts and other challenges.

2. Our Plan:

- Is adaptive, flexible and supported by customers and stakeholders
- Improves drought resilience of water supplies for customers
- Contributes to the protection of rare Chalk stream habitats by reducing abstraction from Chalk sources
- Prioritises reducing demand and is innovative
- Ensures timely delivery of the appropriate strategic supply infrastructure
- Remains affordable to ensure the best value for customers now and in the long term for future generations.

MI/d = million litres of water per day

Use of existing shared Anglian reservoir supply at full capacity by 2024/25

Grand Union Canal option expected 2050 onwards

'Supply 2040' transfer schemes to move water north

South East Strategic Reservoir option

- 50 MI/d (expected late 2030s)
- Further 50 MI/d in 2050+



3. Protecting the environment

We will reduce the amount of water we take from existing Chalk sources and not develop any new Chalk groundwater sources in our Central region.

4. Our proposals to reduce the demand for water



Leakage

We are committed to reducing leakage. In 2015, leakage was around 21% (189 MI/d) of the water we put into supply. By 2025 we plan to have reduced this to 15%. Our leakage ambition is set to achieve a 50% reduction in leakage between 2015 and 2045, resulting in 11% of water into supply being lost to leakage by 2045.




Water use per person (Per Capita Consumption – PCC)

We will put in place actions to help customers reduce their water use from an average of 152 litres of water per person per day to 129 litres by 2025. We aim to reduce water use to between 110 and 120 litres per person per day by 2045, if this is affordable for customers and delivered in a way that is acceptable to them.

Our actions will include:

- Installing more water meters in homes and businesses
- Providing customers with more regular information on how much water they are using
- Providing customers and communities with water audits to encourage them to become more water efficient
- Supporting a national water efficiency campaign and work with Government to introduce new policies to reduce consumption
- Working with retailers to improve water efficiency of businesses.



5. Our proposals to increase supply for water

Developing strategic supply options and resilience

- 'Supply 2040' – a programme that delivers network infrastructure improvements that will help us to move water to where and when it is needed
- Maximise use of our existing sources of water, including full use of imports of water
- Building a new reservoir in Oxfordshire, which we refer to as the South East Strategic Reservoir, to provide an extra 100 MI/d by the late 2030s. We will also continue to liaise with neighbouring water companies to examine the potential to use water trading, possibly via the proposed Severn Thames Transfer scheme, to act as an alternative source of water on the River Thames
- A transfer of water via the Grand Union Canal which could provide an additional 50 MI/d in the longer term or as an alternative to the reservoir development
- An alternative strategic transfer solution from South Lincolnshire that could provide up to 100 MI/d if required in the longer term.

Collaboration with neighbouring water companies

We will continue to collaborate with neighbouring water companies and other parties to secure the additional resources needed. We have ensured with our partners, that these strategic options form part of a coherent long term regional strategy for the South East of England.


Improving resilience to droughts

We estimate that without taking action, there is around a 60% chance over the next 60 years we would have to resort to exceptional drought management measures, such as standpipes. We propose investing to reduce this to around a 25% chance (1 in 200 year drought event).

Our Plan for the East region (Brett Community)

Our Plan sets out how we will provide a reliable, resilient, efficient and affordable water supply to customers from 2020 to 2080, whilst helping to protect the environment.

1. Key challenges met




Our Plan addresses the need to balance the availability of water supply with the demand for water from customers. Our East region has sufficient water for the duration of the planning period by only focusing on reducing the demand for water. There is no need to take action to increase the supply of water for this area. However, we do want to help protect the environment and improve the resilience of our water supplies to droughts and other challenges.

2. Our Plan:

- Is adaptive, flexible and supported by customers and stakeholders
- Improves drought resilience of water supplies for customers
- Contributes to the protection of rare Chalk stream habitats by reducing abstraction from Chalk sources
- Prioritises reducing demand and is innovative
- Ensures timely delivery of the appropriate strategic supply infrastructure
- Remains affordable to ensure the best value for customers now and in the long term for future generations.

MI/d = million litres of water per day

Use of existing shared Anglian reservoir supply at full capacity by 2024/25



3. Protecting the environment

Our Plan includes an allowance for reduction of the amount of water we take from Chalk catchments in our East region.



4. Our proposals to reduce the demand for water



Leakage

We are committed to reducing leakage. In 2015, leakage was around 21% (189 MI/d) of the water we put into supply. By 2025 we plan to have reduced this to 15%. Our leakage ambition is set to achieve a 50% reduction in leakage between 2015 and 2045, resulting in 11% of water into supply being lost to leakage by 2045.



Water use per person (Per Capita Consumption – PCC)

We will put in place actions to help customers reduce their water use from an average of 152 litres of water per person per day to 129 litres by 2025. We aim to reduce water use to between 110 and 120 litres per person per day by 2045, if this is affordable for customers and delivered in a way that is acceptable to them.

Our actions will include:

- Installing more water meters in homes and businesses
- Providing customers with more regular information on how much water they are using
- Providing customers and communities with water audits to encourage them to become more water efficient
- Supporting a national water efficiency campaign and work with Government to introduce new policies to reduce consumption
- Working with retailers to improve water efficiency of businesses.

5. Our proposals to increase supply for water

Developing strategic supply options and resilience

We will manage the water resources available to us more efficiently, reducing any potential impacts on the environment and enhance our ability to cope with different types of weather and climatic events, such as severe drought. Under our Plan for our East region we are able to do this primarily based on our demand management activities alone.

There is a risk that we will face substantial (up to 15-20 MI/d) reductions in abstraction for our sources within the River Brett catchment in the near term. If that does occur then we would need to construct a desalination plant on the East coast, or if the timing and the volumetric reduction changes, a shared alternative option. We will work closely with the Environment Agency to protect supplies and the environment.

Collaboration with neighbouring water companies

We will continue to collaborate with neighbouring water companies or other parties to ensure that these strategic options form part of a coherent long term regional strategy for the East of England.

Improving resilience to droughts


We estimate that without taking action, there is around a 60% chance over the next 60 years we would have to resort to exceptional drought management measures, such as standpipes. We propose investing to reduce this to around a 25% chance (1 in 200 year drought event).

Our Plan for the Southeast region (Dour Community)

Our Plan sets out how we will provide a reliable, resilient, efficient and affordable water supply to customers from 2020 to 2080, whilst helping to protect the environment.

1. Key challenges met

Southeast region outlook




Our Plan addresses the need to balance the availability of water supply with the demand for water from customers. Without action, we face the risk of a shortfall of water in the future in our Southeast region due to population growth and climate change. We also want to help protect the environment and improve the resilience of our water supplies to droughts and other challenges.

2. Our Plan:


- Is adaptive, flexible and supported by customers and stakeholders
- Improves drought resilience of water supplies for customers
- Contributes to the protection of rare Chalk stream habitats by reducing abstraction from Chalk sources
- Prioritises reducing demand and is innovative
- Ensures timely delivery of the appropriate strategic supply infrastructure
- Remains affordable to ensure the best value for customers now and in the long term for future generations.

MI/d = million litres of water per day



3. Protecting the environment

We are stopping the reliance on drought permits for additional abstraction to meet our 1 in 200 year drought resilience commitment from March 2024.



4. Our proposals to reduce the demand for water



Leakage

We are committed to reducing leakage. In 2015, leakage was around 21% (189 MI/d) of the water we put into supply. By 2025 we plan to have reduced this to 15%. Our leakage ambition is set to achieve a 50% reduction in leakage between 2015 and 2045, resulting in 11% of water into supply being lost to leakage by 2045.



Water use per person (Per Capita Consumption – PCC)

We will put in place actions to help customers reduce their water use from an average of 152 litres of water per person per day to 129 litres by 2025. We aim to reduce water use to between 110 and 120 litres per person per day by 2045, if this is affordable for customers and delivered in a way that is acceptable to them.

Our actions will include:

- Installing more water meters in homes and businesses
- Providing customers with more regular information on how much water they are using
- Providing customers and communities with water audits to encourage them to become more water efficient
- Supporting a national water efficiency campaign and work with Government to introduce new policies to reduce consumption
- Working with retailers to improve water efficiency of businesses.

5. Our proposals to increase supply for water

Developing strategic supply options and resilience

We will manage the water resources available to us more efficiently, reducing any potential impacts on the environment and enhance our ability to cope with different types of weather and climatic events, such as severe drought. Under our Plan for our Southeast region we are able to do this mainly based on our demand management activities, plus extension of our supply arrangements with our neighbouring water companies. Some licence changes and infrastructure schemes are required to improve smaller supply options and enable us to address needs during periods of peak demand.

Collaboration with neighbouring water companies

We will continue to collaborate with neighbouring water companies or other parties to ensure that these options form part of a coherent long term regional strategy for the South East of England.

Improving resilience to droughts

We estimate that without taking action, there is around a 60% chance over the next 60 years we would have to resort to exceptional drought management measures, such as standpipes. We propose investing to reduce this to around a 25% chance (1 in 200 year drought event).

1 Setting the scene

1.1 Introduction

1.1.1 This document presents our final Water Resources Management Plan 2019 (fWRMP19). It should be read in conjunction with our Statement of Response (SoR) dated 7th June 2019 published with this plan, which summarise feedback on our revised draft Water Resources Management Plan 2019 (rdWRMP19) and our response to that feedback. A separate summary document is available providing a non-technical overview of our Plan.

www.affinitywater.co.uk/waterresourcesplan

1.1.2 Our fWRMP19 sets out how we plan to deliver a reliable, resilient, efficient and affordable water supply to customers from 2020 to 2080, whilst protecting the environment. At the core of this task is the need to balance the availability of water supply with the demand¹ for water from customers. Delivering resilient water supplies is a priority for us and for government.

1.1.3 This Chapter sets the scene. In this Chapter, we describe our supply area (section 1.2) and the challenges we face (section 1.3). We then provide an overview of the stages of work involved in developing our rdWRMP19 (section 1.4). Finally, we explain the process we are following and where in the process we are (section 1.5).

1.1.4 Chapters 2-5 provide the detail of the work involved in developing our fWRMP19. The fWRMP19 is presented in Chapter 6. Chapter 6 also sets out our future supply and demand and our levels of service in a drought if we implement our fWRMP19. We explain how we have collaborated with other water companies at a regional level in developing our fWRMP19 and links to other plans, including the WRMPs of other water companies and our Business Plan in Chapter 7. In Chapter 8, we describe how our Board has overseen the preparation of our fWRMP19.

1.2 Our supply regions

1.2.1 We have three geographically separate supply regions: Central, Southeast and East. Our Central region is split into six areas known as ‘communities’. Each has a name: Wey, Pinn, Colne, Misbourne, Lee and Stort. Our East region is named the Brett community and our Southeast region named the Dour community. Each community is also a Water Resource Zone (WRZ) for water resources planning purposes and is allocated a number, WRZ1 to WRZ8, as illustrated in Figure 1.

¹ The volume of water both household and non-household customers draw from the supply system and therefore demand from a water company, is known as the demand for water.




Figure 1: The Affinity Water Supply Area

- 1.2.2 We abstract approximately 65% of water from groundwater sources and the remainder is from surface water, principally from the River Thames. We also receive water from and provide water to neighbouring water companies (known as “bulk supplies”). In our East region we obtain water from a reservoir that that we jointly own with Anglian Water.

1.3 Challenges and issues

- 1.3.1 We have a number of key challenges and issues that we need to address through our fdWRMP19. The first of these is that substantial, continued housing growth is planned for our supply area, particularly in our Central region. The population is predicted to increase by 12% over the next 25 years and by over 50% by 2080 (the equivalent of an additional 1.8 million people living in our supply area).
- 1.3.2 Until recently we had one of the highest per capita consumption (“PCC”) levels in the UK. PCC measures the amount of water each person uses each day. This has reduced but we still have an average PCC of 152 litres per head per day (l/h/d).
- 1.3.3 Our supply area is located in one of the driest parts of the UK. The Thames Valley and London normally receive less than 650 mm of rain per year², which is less than Rome, Sydney or New York, and among the lowest in the UK for total annual average rainfall per person. Climate change is predicted to bring warmer wetter winters and hotter drier summers, reducing the overall available supply of water and increasing the demand for water.
- 1.3.4 Our supply area has 8 to 9% of globally rare Chalk streams. We recognise the environmental pressures that Chalk catchments are facing and we continue to work with partnership organisations to protect water ecosystems, improve river habitats for wildlife and enhance biodiversity at our sites.

² Source: <https://www.metoffice.gov.uk/climate/uk/regional-climates/so#rainfall>

- 1.3.5 There are several major infrastructure projects planned in our supply area, all of which could encourage population growth or an increased number of tourists, business travellers or commuters. These include a third runway at Heathrow Airport, the expansion of Luton Airport, the Oxford to Cambridge corridor development, High Speed Rail (HS2), Crossrail and a new rail link from Slough to Heathrow.
- 1.3.6 We have several significant water quality pressures in our catchment as a result of historic and current polluting activities, which we need to manage to safeguard the quality of the water that we abstract.

1.4 Developing our fWRMP19

- 1.4.1 The purpose of our water resources planning is to ensure that we are able to balance the supply of water with the demand for water notwithstanding these challenges. We assess this within our three geographically separate regions - Central, Southeast and East - and then more widely in the context of the South East of England. Our approach is based upon standard best practice, following the Environment Agency’s Water Resources Planning Guidelines (WRPG)³.
- 1.4.2 Figure 2 illustrates at a high level, the process we took to develop our strategy and highlights the components which make up the supply and demand forecasts.




Figure 2: High level WRMP process

- 1.4.3 We first calculated a ‘baseline’ supply-demand balance, which tells us how much water we have available (supply) and how much water we need (demand), now and into the future (see Chapter 3 for further information).
- 1.4.4 We then carried out an options appraisal to work out what options we have available to us to balance our supply and demand into the future (see Chapter 4 for further information). We also engaged with customers and stakeholders to understand the features they would like to see in our Plan (see Chapter 2 for further information).
- 1.4.5 We developed a decision-making process to choose between the different options taking into account our options appraisal and customer and stakeholder feedback (Chapter 5). This allowed us to decide on our fWRMP19 for each of our three supply regions. In each case, our primary objective was to ensure we had sufficient water to meet the needs of customers. We also needed to achieve resilience to a 1 in 200-year drought without the use of drought options after 2024, achieve leakage reduction of 18.5% during AMP7 and aim for further

³ Water Resources Planning Guideline: Interim update, Environment Agency, July 2018

future reductions. In the case of our Central and East regions we planned to deliver sustainability reductions to decrease the amount of water we abstract from the environment.

- 1.4.6 Our fWRMP19 for our East and Southeast regions includes demand management options and some supply-side options (Chapter 6). The scale of the challenge in our Central region is much greater and requires us to take large-scale action. Our fWRMP19 adopts a “twin track” approach of extensive demand management to reduce demand, supported by large-scale schemes to increase supply. We cannot be certain how these challenges and risks will emerge in the future. For this reason, our fWRMP19 is an “adaptive plan” that is able to respond in a structured way to future changes in supply and demand.
- 1.4.7 The way that we developed our “adaptive plan” is shown conceptually in Figure 3. We analysed key future uncertainties to develop four future scenarios. We then worked out the best way to invest to meet those futures. In some cases, we need to deliver schemes with long lead-in times. We therefore established when we needed to start construction of these schemes and what enabling actions we need to take before then to ensure we can deliver them when they are needed. Finally, our adaptive plan includes a monitoring plan so that we can make key decisions on the basis of objective evidence. We explain this in detail in Chapters 5 and 6.




Figure 3: Concept behind our Adaptive Plan (*In this case “best” represents the combination of investments that are both cost-effective and reflect customer and stakeholder expectations).

1.4.8 We have formally assessed the environmental impacts of our fWRMP19. We have done this through carrying out:

- A Strategic Environmental Assessment (“SEA”) – this was carried out under the Environmental Assessment of Plans and Programmes Regulations 2004, which requires the environmental impacts of certain plans and programmes likely to have significant effects on the environment to be assessed.
- A Habitats Regulations Assessment (“HRA”) – this was carried out in accordance with the Conservation of Habitats and Species Regulations 2017. It assessed the impact of our proposals on European Sites, being Special Areas of Conservation (“SACs”), Special Protection Areas (“SPAs”) and Ramsar sites. We considered whether a plan or project is likely to have a significant effect on one of these sites and if so requires an appropriate assessment to be carried out to ensure that it will not have an adverse effect on the integrity of the European Site.
- A Water Framework Directive (“WFD”) Assessment – the WFD sets environmental objectives for water bodies, which for most water bodies includes achieving “good status”. Our WFD Assessment considered whether our proposals would impact on achievement of these environmental objectives, by causing a risk of deterioration in its statement or of failure to achieve “good status”.

1.4.9 We used the information we obtained from these assessments in our options appraisal (see Section 4.6) and our decision-making (see Section 5.8). We also assessed our fWRMP19 as a whole (see Section 6.7).

1.5 The process we followed

1.5.1 We started our WRMP19 process by understanding the scale of the challenge we face in the future through our assessment of need and problem characterisation in 2016. Whilst developing the technical components of our dWRMP19 we undertook a pre-consultation with our stakeholders and customers.

1.5.2 Our dWRMP19 was submitted to the Secretary of State on 1 December 2017 and published on 19 March 2018. We then ran a public and stakeholder consultation on our dWRMP19 between 19 March and 23 May 2018.

1.5.3 All the feedback received on our dWRMP19 was considered and we published our Statement of Response (SoR) on 31 October 2018. This set out the main topics upon which customers and stakeholders provided feedback, along with an outline of the changes we proposed to make in our rdWRMP19 as a result. We provide an individual response to every representation made in Appendix 1 of our SoR which is available on our website at: <https://stakeholder.affinitywater.co.uk/water-resources.aspx>.

1.5.4 During the development of our rdWRMP19 we ran a pre-consultation with stakeholders, regulators and customers, through focus groups, to inform and shape decisions taken in our rdWRMP19. This feedback shaped our Plan, which is demonstrated in Chapter 5.

We then undertook further consultation with customers and stakeholders on our rdWRMP19 between 1 March and 26 April 2019. We have used this feedback to modify the clarity and adaptability of our fWRMP19, as shown in Chapters 5 and 6 of this document.

1.5.5 Details of our WRMP19 timeline are shown in Figure 4.




Figure 4: Our WRMP19 Programme Timeline


1.5.6 The suite of documents making up our fWRMP19 comprises:

- A non-technical summary of our fWRMP19 main Plan document (published).
- **This document** - our fWRMP19 main Plan document (published).
- Our Statement of Response on our rdWRMP19.
- Our Water Resource Planning data tables (published).
- A series of supporting Technical Reports. These include full results and conclusions from the detailed studies undertaken to produce this Plan as listed in the Appendix (available on request).
- Our Strategic Environmental Assessment Report and Habitats Regulations Assessment (published).

2 Consulting with customers and stakeholders

2.1 Introduction

2.1.1 Throughout the preparation of our WRMP19 and our PR19 Business Plan we have been committed to listening and acting on the feedback received from both customers and stakeholders regarding the direction of our plans. We needed to understand their priorities to decide on what our WRMP19 should look like.



2.1.2 Our programme of engagement has enabled us to set out and shape our overall approach and provide customers, regulators and stakeholders with an opportunity to tell us what they expect from our WRMP19 and our Business Plan for 2020-25. We used an enabling phase to map out a profile for our consultation activities that ensured both dWRMP19 and Business Plan consultation periods tracked one another cohesively and effectively.

2.1.3 To support and deliver our customer engagement programme, we appointed the UK's second largest market research agency, Ipsos MORI. Our programme included bespoke market research, recommendations for customer segmentation, analysis of operational customer contact data and triangulation⁴.

2.2 Consultation on our dWRMP19

2.2.1 Prior to submitting our dWRMP19 to the Department for the Environment, Food and Rural Affairs (Defra) in early 2018, we undertook a pre-consultation with our stakeholders and customers. We wrote to over 2,000 stakeholders asking for their views on our dWRMP19 proposals and direction of travel. Customer views were captured via a variety of market research findings through our PR19 Customer Engagement programme, the engagement programme for development of our Business Plan 2020-25. These views were subsequently used to develop follow up areas of focus for the quantitative and qualitative market research during the dWRMP19 public consultation.

2.2.2 From 19 March 2018 to 23 May 2018 we undertook a public consultation on our dWRMP19. We used a variety of methods within our dWRMP19 and PR19 Business Plan customer engagement programme such as face to face interviews, online surveys, customer focus groups, stakeholder forums and other methods to ensure all customers and stakeholders

⁴ Triangulation is a technique that facilitates validation of data through cross verification from two or more sources. It refers to the application and combination of several research methods in the study of the same phenomenon.

were given the opportunity to respond. We utilised customer profiling and segmentation to target customers appropriately to ensure results were robust and in line with the feedback received from our Customer Challenge Group (“CCG”).

- 2.2.3 The public consultation on our ddWRMP19 was circulated to statutory consultees as well as any other persons and organisations with an interest in our plans. In addition, the dWRMP19 was published on our website and made publicly available to any person wishing to review it. We published and promoted a non-technical consultation document alongside the dWRMP19 to encourage and provide customers and stakeholders a platform to respond.
- 2.2.4 We received a total of 82 responses to our dWRMP19 consultation including responses from customers, the EA, Ofwat, Natural England, the Canal & River Trust, the Consumer Council for Water, local authorities and environmental groups. In addition, 65 stakeholders attended eight stakeholder forums held across our three regions.
- 2.2.5 During Phase 2 of our customer engagement programme on our Business Plan we sought both quantitative data and qualitative opinion on our dWRMP19. Existing and new channels of engagement were utilised to facilitate customer and stakeholder representation and feedback through a broad range of activities including ethnographic and in-depth customer interviews, establishment of an on-line customer community, a non-technical consultation document, on-line and face to face customer surveys, customer focus groups, delivery of bill acceptability studies and stakeholder forums.
- 2.2.6 Each piece of research was carefully scoped to ensure we defined the objectives and considered the materiality and significance of the issues to be addressed. This informed the approach we took to ensure the sample and methodology chosen were both appropriate and proportionate to the importance of the issue. Findings were consolidated into key themes and against performance commitments. These were validated through external triangulation and assurance to ensure robustness of both the interpretation and the process we followed.
- 2.2.7 Overall, 15,300 individual pieces of feedback were received from customers as part of the PR19 Customer Engagement process which informed and aligned our dWRMP19 and Business Plan consultations. We evaluated the responses we received and have taken account of customer and stakeholder views in preparing our rdWRMP19.

2.3 Pre-consultation for the rdWRMP19

- 2.3.1 To support our decision making and development of the rdWRMP19, we enhanced our customer consultation through a series of rdWRMP19 pre-consultation focus groups independently held in November 2018 and January 2019. These were aimed at refining our understanding of customer preferences in a number of areas, including demand management options and options for longer term strategic supply side schemes. During this phase of pre-consultation we also held a number of meetings with external stakeholders, to help us shape our decision making for the rdWRMP19.
- 2.3.2 We ran eight pre-consultation focus groups exploring with customers a number of demand management options, per capita consumption, drought resilience and long term strategic supply options to inform our rdWRMP19. This research focused on areas we had not fully explored with customers to date, and provided valuable insight into customer preferences.

- 2.3.3 Our pre-consultation with stakeholders targeted several key organisations. This included the EA, Defra, Ofwat, Drinking Water Inspectorate (DWI), Natural England, Group Against Reservoir Development (GARD), Local Authorities, river and environmental groups, Canal & River Trust, neighbouring water companies, Water Resources South East (WRSE) and water retailers.
- 2.3.4 We have also taken on board the results of Thames Water’s customer research for the South East Strategic Reservoir (SESR), a potential scheme which we would need to develop jointly with Thames Water. The findings are from Thames Water’s further engagement on their revised WRMP19 from October to November 2018 and are relevant to our rdWRMP19 and have therefore been included in our pre-consultation.

2.4 Further consultation on our rdWRMP19

- 2.4.1 We conducted a demographically representative online survey with 1,000 Affinity Water customers. The survey built on our pre-consultation focus group sessions with customers undertaken for the rdWRMP19 pre-consultation. The survey presented participants with several key propositions including the customer bill impact resulting from the rdWRMP19.
- 2.4.2 In addition to our demographically representative survey, customers and stakeholders were encouraged to take part in an online survey which consisted of five key questions which presented a number of key propositions including customer bill impact. This was an open access survey and, although it was self-selecting, the findings provided valuable insight into the views of customers and stakeholders.
- 2.4.3 A Stakeholder Assembly was held in Central London. The purpose of the Assembly was to enable stakeholders to contribute to shaping our future strategies. It allowed national and local government, environmental bodies, industry experts, developers, third sector organisations and other key stakeholders to analyse and discuss fundamental areas of work for Affinity Water. We firmly believe that stronger partnerships across sectors will be fundamental to meet future challenges.
- 2.4.4 We held meetings with regulators and other water companies both individually and through WRSE and Water Resources East (WRE) groups and met with several key stakeholders including local authorities, GARD and environmental groups to present and discuss the rdWRMP19.
- 2.4.5 A comprehensive communications campaign was delivered through a wide variety of channels to ensure customers and stakeholders across our supply area and beyond were made aware of the further consultation and able to make representations. This included launching a brief animated video providing an overview of the key aspects of our rdWRMP19, a stakeholder and customer email, web advertising, leaflets distributed to customers, social media, a news release and an internal communications campaign. Customers that did not have access to the internet were able to call a dedicated number and request a hard copy of the non-technical summary of the plan which contained the same questions as the online response form.

2.5 How customers have shaped our Plan

- 2.5.1 We selected the elements of our dWRMP19 that received endorsement from customers, stakeholders and regulators and built on these in developing our rdWRMP19. We published

our Statement of Response (SoR) on 31 October 2018 which documents how we have responded to feedback on our dWRMP19 and is available on our website at: <https://stakeholder.affinitywater.co.uk/water-resources.aspx>.

- 2.4.1 We have undertaken further consultation with customers and stakeholders on our rdWRMP19. The consultation questions we asked focused on the aspects of the Plan which have changed between our dWRMP19 and the rdWRMP19. We did, however, also consider any comments made about other aspects of the rdWRMP19.
- 2.4.2 Feedback from customers, stakeholders and regulators has strongly shaped our fWRMP19. We have taken all our customer and stakeholder consultation and developed a formal analysis of their preferences – Customer and Stakeholder Analysis (“CSA”). This fundamentally shaped our decision-making process as described in Section 5.3 of this document.
- 2.5.2 Throughout the process we welcomed the feedback and participation of our CCG in all aspects of our engagement activities. Further detail of the consultation process, as well as the findings, is provided in the fWRMP19 Technical Report 7.1: Engaging with Customers, Communities and Stakeholders. An overview of our PR19 customer engagement process is illustrated in Figure 5.




Figure 5: Overview of our PR19 customer engagement process

3 The scale of the challenge – baseline supply-demand balance

3.1 Introduction

3.1.1 This Chapter explains our forecasts of how much water we will have available to supply and how much water we need between 2020-2080. This gives us our baseline supply-demand balance, which is the position that we plan from. If it tells us that demand will outstrip supply in the future, then we need to plan to take action to close the gap between demand and supply and maintain the supply-demand balance. The WRMP process is outlined in Figure 6.




Figure 6: Detailed WRMP process

3.1.2 The steps calculating our baseline supply and demand balance are:

- Identify water resource zones, which we will use to build up our baseline supply and demand balance for each of our three supply regions (Section 3.2).
- Forecast baseline demand (Section 3.3 and Technical Reports 2.1 to 2.7).
- Forecast baseline supply (Section 3.4 and Technical Reports 1.1 to 1.5 and 3.1).
- Provide for uncertainty in the forecasts (Section 3.5 and Technical Report 3.2).
- Calculate the baseline supply-demand balance – the gap between the amount of water we have to supply and the predicted demand for that water (Section 3.6).

3.1.3 Our baseline supply-demand balance needs to reflect the level of drought resilience we wish to achieve which is resilience to a 1 in 200-year drought.

3.2 Water Resource Zones

3.2.1 We forecast the baseline supply-demand balance for each of our three supply regions. We build up the supply-demand balance for each region by calculating the supply-demand balance for each water resource zone following each of the steps above.

3.2.2 A water resource zone (WRZ) is the largest possible zone in which all water resources, including external transfers, can be shared, and hence an area in which all customers experience the same risk of supply failure from a water resource shortfall.

3.2.3 Each WRZ is given a number and name and are also known as our ‘communities’ as illustrated in Figure 1. Our Central region has six WRZs or communities; Misbourne (WRZ1), Colne (WRZ2), Lee (WRZ3), Pinn (WRZ4), Stort (WRZ5) and Wey (WRZ6). Our East and Southeast regions represent one WRZ each, Brett (WRZ8) and Dour (WRZ7) communities respectively, resulting in a total of eight WRZs across the company area.

Our Central region

3.2.4 The WRZs in our Central Region are shown in more detail in the schematic map in Figure 7 below. The map shows the major demand centres, typically a town, labelled with a two letter code. It also shows how water can move between and within the WRZs via major pipelines known as trunk mains. Finally, it shows how our Central region receives water from outside of our supply area from neighbouring water companies.




Figure 7: Map of the Water Resource Zone, connectivity and transfers in our Central region

3.2.5 In our Central region, around 60% of water supply comes from groundwater sources. The remaining 40% is abstracted from surface water sources on the River Thames or is imported from neighbouring water companies. We treat the water we abstract from the River Thames at four locations along the river. These treatment works are also fed by some groundwater sources, mainly from the gravels. When combined, these are capable of providing reliable quantities of raw water following prolonged dry spells. Thames Water has carried out an

investigation of the flows in the River Thames ⁵ that included our abstractions and, on the basis of this investigation, we conclude that our abstractions are environmentally sustainable.

- 3.2.6 We export water to neighbouring water companies. We currently have the capability to import up to 10% of our water supply from Anglian Water on a short-term basis (around one week), and 3% to 4% on a longer-term basis.

Our Southeast region

- 3.2.7 In our Southeast region we abstract 90% of water supply from Chalk boreholes, with the remaining 10% supplied from the shallow gravel aquifer of the Dungeness peninsula. We have no surface water abstractions in this area. Our internal transfers and transfers from Southern Water and South East Water can be seen in Figure 8.




Figure 8: Map of the Water Resource Zone, connectivity and transfers in our Southeast region

Our East region

- 3.2.8 In our East region, 80% of supply comes from groundwater, drawn from confined Chalk aquifer boreholes in the River Stour and River Brett valleys in Essex and Suffolk. The boreholes proved robust and reliable during the groundwater drought conditions of 1990-1992, 1996-1998, 2006-2007 and more recently in 2011-2012. The remaining 20% is sourced from the River Colne and stored in a reservoir which is jointly owned with Anglian Water. Our internal connections can be seen in Figure 9.

⁵ AMP4 Thames Water investigation into the impact of abstraction on the Lower Thames and AMP5 Options Appraisal.




Figure 9: Map of the Water Resource Zone, connectivity and transfers in our East region

3.3 Baseline demand forecast

Introduction

3.3.1 As part of the WRMP, a baseline demand forecast is required that calculates the demand for water in the chosen base year (2016/17) and forecasts it across the planning period (2020 to 2080). Our demand forecasting process has been undertaken in line with the latest EA WRPG and UKWIR technical guidance and uses the latest industry best practice methods. The text below provides a summary of our forecasting methodology. Relevant details of the methods that have been used are provided in the following reports:

- The overview of how we forecast demand is in the Overarching Demand report, Technical Report 2.7. this is supported by further details in technical reports 2.1. to 2.5.
- Our approach to forecasting population and properties is contained in Technical Report 2.3.

3.3.2 The resulting demand forecast represents the demand in an average dry year i.e. when demand for water is at its highest. A critical period scenario is also assessed; this is a short period of peak demand, for example during very hot weather.

3.3.3 The demand for water is made up of a number of components as illustrated in Figure 10. We calculate our demand (distribution input) and each of these components for our chosen base year (see paragraphs 3.3.5 to 3.3.19 below).

3.3.4 We then assess how future water demand may change over the next 25 years and beyond up until 2080 by reviewing how each component of demand in the base year may change in future years: this sets our baseline demand forecast (see paragraphs 3.3.20 to 3.3.44 below).




Figure 10: Components of demand

Base year

3.3.5 We selected 2016/17 as the base year for our rdWRMP19. The decision to use this base year, as opposed to 2015/16 at draft WRMP, was primarily made because 2016/17 was reflective of a ‘normal’ year (i.e. not particularly wet or dry, so demand from customers was around our average expectations).

Total demand – Distribution Input

3.3.6 We measure the quantity of water supplied from all our water treatment works into our pipe network using flow meters; this is known as our distribution input (DI). Within our pipe network we also measure flows going into specific areas known as district metered areas (DMAs), which are effectively local zones covering urban areas, towns and villages, where each DMA generally covers a few thousand homes. DMA flows are monitored continuously and enable us to assess daily changes in demand and consumption at a detailed level. This in turn allows us to vary our source outputs if needed and helps us to identify and tackle leaks on our network.

Household consumption

3.3.7 Some household properties are metered while others do not have meters and consumption is unmeasured. We calculate the annual consumption of measured households from meter readings logged on our billing system. We divide the total annual consumption by the number of measured households to work out how much water an average household uses. We deduct an amount to represent estimated leakage from customers’ pipes i.e. customer side leakage. This gives us the amount of water used by each house – per household consumption (“PHC”).

- 3.3.8 We then use this to calculate the amount of water used by each person by dividing the average household consumption by an average household occupancy rate. This is known as per capita consumption (“PCC”) and is expressed in litres per head per day.
- 3.3.9 We produce estimates of current average unmeasured household for each of our WRZs using our “unmeasured consumption monitor”. Our unmeasured consumption monitor operates only in our Central Region because meter penetration rates in our Southeast and East regions is much higher than that of our Central region. Therefore, we do not have unmeasured consumption monitors in those regions.
- 3.3.10 This monitor comprises a group of around 1,500 customers in our Central region who have had meters installed for our survey purposes but which are not used for charging. It has been in operation since 1995 and includes a wide range of property types (flats / apartments, terraced houses, semi-detached and detached properties) across the region to better understand how water use differs for different properties. For example, we would expect to see garden watering to be lower for those living in flats than for those living in detached properties. This information allows us to work out PHC and PPC for customers on unmeasured tariffs.

Non-household consumption

- 3.3.11 Non-household properties may also be measured or unmeasured. We calculate non-household consumption by summing measured non-household consumption and an estimate of unmeasured non-household consumption.

Leakage

- 3.3.12 We use information obtained from meters on our network to calculate leakage using the approach outlined in leakage reporting guidance produced by Ofwat and Water UK. Leakage includes both leakage on our network and customer side leakage. It also includes leakage from empty properties.

Minor components of demand

- 3.3.13 Other minor components of demand include usage such as builders’ temporary supplies from standpipes, water for fire-fighting purposes and water we use for operational purposes such as flushing of hydrants. We use a fixed estimate for these.

Water balance in our base year and our Annual Return 2017

- 3.3.14 We are required to submit information about DI and its components as part of our annual return to Ofwat about our water balance. The WRMP base year is largely based on the water balance submitted as part of the Annual Return 2017.
- 3.3.15 Some adjustments to the Annual Return water balance were made to reflect improvements in our understanding of some components of the water balance. The main changes involved:

- Occupancy rates and population estimates: a new occupancy model was created which more accurately represents the current occupancy rates.
- Baseline leakage calculations: the latest Water Resource Planning Guideline prescribes that water companies should determine their base year leakage using the approach outlined in leakage reporting guidance (Ofwat and Water UK, March 2018). Leakage in the base year was reviewed to accommodate the introduction of this ‘convergence’ method. The end of AMP6 forecast value was also adjusted to account for this change.
- PCC calculations in Southeast and East regions: unmeasured per capita consumption (uPCC) from our consumption monitor ‘Watcom’, was applied to unmeasured customers in our Southeast and East regions.

“Peak” and “Dry Year” factors

3.3.16 We made adjustments to our 2016/17 base year water balance to tell us what the water balance would have looked like if:

- the weather in 2016/17 had been normal – this is known as normal year dry average (“NYAA”)
- the weather in 2016/17 had been dry – this is known as dry year annual average (“DYAA”).

3.3.17 We calculated the adjustments we needed to reflect NYAA and DYAA in accordance with best practice guidance using the following data:

- a historic record of annual measured and unmeasured PCC for each region for the period 2005/06 to 2017/18
- monthly weather data for temperature and rainfall for Central, Southeast and East regions from the MET Office website
- daily weather data for the Central region from our MET Office model.

3.3.18 We also considered what demand would have been for a critical peak period, dry year critical peak (“DYCP”), when demand is high for a short period of time, for example because of warm weather. This is calculated on the basis of a rolling seven-day average.

3.3.19 In our modelling of the supply-demand balance we assume that demand restrictions allowing the temporary restriction of certain non-essential uses of water (Temporary Use Bans and Non-Essential Use Bans), would be in place at both DYAA and DYCP given our adoption of a 1 in 200 year design scenarios. These are assumed to reduce household demand by 3% while they are in place.

Forecasting demand

3.3.20 We forecasted total demand (DI), following UK Water Industry Research (UKWIR) best practice guidance, by first forecasting each of the components separately from the base year as described below. We then summed them in our spreadsheet-based Hub model to provide total demand. We produced forecasts for normal year annual average (“NYAA”), dry year annual average (“DYAA”) and critical peak (“CP”).

Household demand forecast

- 3.3.21 We forecast future household demand using a multi-linear regression (“MLR”) computer model. The model uses information relating to historic household consumption and forecasts population, property numbers and occupancy rates to predict how household demand will change in the future from its level in our base year. Our dWRMP19 Technical Report 2.1: Household Demand Forecast – MLR modelling, explains the various steps undertaken to test and validate our MLR model.
- 3.3.22 The MLR model predicts demand from different types of household property likely to have different patterns of water usage:
- **Optants** – these are customers who were previously on unmeasured tariffs and choose to have a meter installed; they will receive a bill based on their metered use straight away
 - **New builds** – these are new properties built in our supply area and the number of these was forecast to increase year on year
 - **Water Saving Programme (WSP) customers** – these are customers subject to compulsory metering; they receive a bill based on their metered use after two years unless they choose to opt for metered billing earlier
 - **Social tariff customers** – these are customers (measured and unmeasured) that are eligible for a lower tariff because of economic circumstances and/or health conditions that mean their water use is higher
 - **Existing metered customers** – these are customers that have a meter.
- 3.3.23 Two key inputs to the MLR model were population and property forecasts. To update our population and property forecast, we participated in a group project with four other water companies in January 2017 aimed at developing a range of different housing and population forecasts. The group commissioned Experian to produce a set of four different forecasts for the period 2020-2045:
- trend-based forecast
 - plan-based forecast
 - econometric forecast
 - hybrid forecast
- 3.3.24 Based on our review and taking into account the latest EA and UKWIR guidelines, plan-based forecasts have been selected and used in the fWRMP19 (see Technical Report 2.3). Experian plan-based forecasts have been adjusted to take account of knowledge of historic trends in housing formation and our billing system. We also added into the forecasts, properties that,

prior to the opening of the retail market in April 2017, were classified as commercial properties that since April 2017 are recognised as household properties.

- 3.3.25 Population figures were produced by applying the same Experian trend to the base year population, adjusted using new occupancy rates up to 2044/45. The population figures were extrapolated in a linear manner after 2045. All property, occupancy and population figures have been thoroughly checked and audited.
- 3.3.26 We have compared our revised property forecast (revised as set out above) with detailed information gathered from local authority plans to ensure alignment with those plans. In respect of the London Plan, which is currently at draft stage, we understand that the housing targets will not be finalised until 2020. The Greater London Authority (GLA) confirmed during pre-consultation that the draft housing forecasts are too uncertain to incorporate into our fWRMP19 at this stage. As a result, they have not formed part of our baseline assessment, but we have developed a “high-growth” scenario to test the robustness of our Plan to risks (see section 5.8).
- 3.3.27 The comparison between our fWRMP19 and other recently produced local plans shows that we are broadly aligned with local authorities’ figures in the first 15 years of our forecast. The difference between our forecast and local plans housing targets is very small, ranging between 0.07% and 1.94% of our total property count of approximately 1.4 million properties and therefore the difference is not material. Our forecast tends to diverge from local plans after approximately 15 years when local plans’ figures become less consistent or, for some local authorities, not available. Table 1 and Table 2 below set out our current and forecast population and property numbers.

Table 1: Current and forecast population numbers

Water Resource Zone	Base Year Population (2016/17)	Total population forecast by 2024/25	% increase by 2024/25	Total population forecast by 2044/45	% increase by 2044/45	Total population forecast by 2079/80	% increase by 2079/80
1	354,284	383,869	8%	373,898	6%	346,014	-2% ⁶
2	426,325	467,045	10%	513,652	20%	589,529	38%
3	699,038	796,455	14%	931,333	33%	1,155,194	65%
4	902,477	1,015,827	13%	1,184,769	31%	1,477,507	64%
5	288,591	334,520	16%	397,864	38%	503,498	74%
6	525,261	586,740	12%	644,758	23%	736,887	40%
Central region	3,195,976	3,584,457	12%	4,046,274	27%	4,808,631	50%
7 (Southeast region)	160,115	180,540	13%	210,832	32%	263,330	64%
8 (East region)	150,426	165,185	10%	183,050	22%	212,831	41%
Company total	3,506,516	3,930,182	12%	4,440,157	27%	5,284,792	51%

N.B: Totals in this table are subject to rounding.

Table 2: Current and forecast number of households

Water Resource Zone	Base Year number of properties (2016/17)	Total number of properties forecast by 2024/25	% increase by 2024/25	Total number of properties forecast by 2044/45	% increase by 2044/45	Total number of properties forecast by 2079/80	% increase by 2079/80
1	131,390	138,044	5%	153,338	17%	180,102	37%
2	167,829	179,530	7%	206,574	23%	253,901	51%
3	271,176	304,200	12%	384,117	42%	523,971	93%
4	331,554	367,482	11%	453,383	37%	603,710	82%
5	116,139	131,864	14%	169,236	46%	234,636	102%
6	195,508	217,393	11%	269,578	38%	360,901	85%
Central region	1,213,596	1,338,514	10%	1,636,225	35%	2,157,221	78%
7 (Southeast region)	70,050	79,733	14%	102,578	46%	142,557	104%
8 (East region)	67,811	73,707	9%	87,626	29%	111,984	65%
Company total	1,351,457	1,491,954	10%	1,826,430	35%	2,411,762	78%

N.B: Totals in this table are subject to rounding.

⁶ The long-term population decrease in WRZ1 is due to the method used to extend the forecast by applying a linear extrapolation. The methodology used is consistent with that followed in all other zones and the decrease reflects consistent application of this methodology. Population estimates after 2045 contain significant uncertainties and we will monitor any new evidence as it becomes available.

3.3.28 The resulting population and property forecasts are then fed into our occupancy rate model, which generates expected occupancy rates for both measured and unmeasured properties. These occupancy rates then feed into the MLR model to generate the PCCs, and generate the split between measured and unmeasured populations in the demand forecast model.

3.3.29 The result of modelling is a household consumption forecast, providing per household consumption (PHC) and PCC values per year, per zone, for both measured and unmeasured populations as shown in Figure 11. All consumption outputs are given as NYAA, with climate change effects being added (see later for further details of climate change impacts on demand).



Figure 11: Company level outputs for PCC, PHC, occupancy and MI/d

3.3.30 Our meter penetration (the percentage of properties that are metered) increases from 59.2% in 2020, to over 90% in 2045. Throughout this period, population and number of properties are steadily increasing, with total occupancy reducing. The falling occupancy rate is driving the increase in PCC seen after 2028.

3.3.31 We used the results of our MLR model to calibrate a micro-component model. This model provides an indication of the breakdown of household demand by different uses (or micro-components): WC flushing, shower use, bath use, dishwasher use, washing machine use). Technical Report 2.2 provides further detail.

Non-household forecast

3.3.32 We developed forecasts for non-household water demand along with those for household customers. Further detailed explanation on the methodology used is available in Technical Report 2.4.

3.3.33 Historic consumption data going back at least ten years was used to generate the non-household demand forecast using a regression model. Various sources of data were used to produce the forecast:

- Billing extracts containing annual water consumption data for each measured non-household customer for the period 2001-02 to 2015-16 for the Central region and 2006-07 to 2015-16 for the Southeast and East regions.
- Population data.
- Standard Industrial Classification (SIC) code for each non-household customer.
- Economic data.

3.3.34 The resulting non-household consumption forecast shows a downwards trend at a Company level from half way through the period, as illustrated in Figure 12.




Figure 12: Non-household consumption forecast

3.3.35 There are a number of developments in our supply area that are likely to impact on future non-household demand including:

- **Heathrow Airport** – this consumes approximately 5 Ml/d, split between WRZ4 and WRZ6; there is likely to be a substantial increase in this when the new third runway is constructed, currently planned to start in 2020.
- **Dungeness Power Station** in WRZ7 (the Southeast region) is scheduled to be decommissioned by 2028. The current consumption is 1.5 Ml/d. There is unlikely to be a replacement, with the generation capacity instead met through the planned nuclear reactor at Hinkley Point.

- **Luton Airport** in WRZ3 has an average consumption of approximately 0.45 MI/d. There is a current expansion plan to increase passenger numbers by 50% by the year 2020.
- **Oxford to Cambridge corridor (CaMKOx)** could result in an increase in population above that which is included in forecasts for this fWRMP19.
- **High Speed Rail 2 (HS2)** – the construction of a new high speed rail line into London is likely to temporarily require up to 5MI/d water resource during construction.
- **Crossrail** – running from Ealing Broadway to Maidenhead through the centre of the Central region. This would most likely have a similar impact to the current Crossrail project.
- **Western Rail Link to Heathrow** - a new rail link is proposed from Slough to Heathrow linking the airport to the Great Western main line.

3.3.36 Of these, the direct demand associated with airport expansion and Dungeness Power station have been included in our base forecasts.

3.3.37 The water demand for HS2 is considered temporary in nature (i.e. within AMP7), hence is dealt with outside of the WRMP and will be developed separately by HS2. Measures will be in place to ensure that our assets are protected from HS2 works during construction and are designed to cover peak demand periods. Moreover, a long-term monitoring plan will be in place to measure any deviation from the current baseline in terms of both source yield and water quality. Any additional infrastructure required to enhance resilience during the HS2 works, will be funded by HS2 directly. The demand from the construction of HS2 does not form part of our statutory duty of supply, our arrangements for supplying this water are not planned to the same level of resilience as for our statutory customers, and our levels of service to customers are not affected by the HS2 demand. We have not therefore included this demand in our baseline forecast or tables, but we do provide details of how we will manage the HS2 demand within Section 6.3 of this Plan.

3.3.38 The CaMKOx corridor risks have been quantified, but excluded from our baseline assessment as they are too uncertain at this stage. We have, however, developed a “high-growth” scenario to test the robustness of our Plan to risks (see section 5.8). There are no known direct demands from Crossrail or the Western Rail Link at this stage.

3.3.39 These infrastructure projects will also provide local employment and help to drive an increase in population. The forecasts used in calculating household demand already show levels of growth that are consistent with these and other projects taking place, and therefore the impacts of these (or alternative similar developments) are arguably already taken into account within the forecasts.

Leakage forecast

- 3.3.40 Our baseline and forecast leakage is calculated using the latest ‘convergence method’ specified by Ofwat and the EA. We have assessed the impact of applying the new method to forecast leakage for 2016/17, and concluded that this only resulted in a 2% increase in our base year leakage. The subsequent reporting year (2017/18) showed that the overall difference was negligible once the new methodology had been fully established. The difference between our latest forecasts of leakage and those from 2014 are therefore negligible and mainly relate to changes in the prioritisation of different WRZs and DMAs from our AMP6 (2015-2020) leakage strategy. This is explained in the Leakage Strategy Technical Report 4.8.
- 3.3.41 We forecast leakage by assuming that we will meet our target to reduce leakage by 14% by the end of AMP6. The forecast value for the last year of AMP6 (2019/20) is then kept constant to 2080. By doing that, we assume that, as a baseline, we will maintain the same level of leakage in the future.

Overall demand (DI) forecast

- 3.3.42 Adopting a bottom-up approach, the property and population, household and non-household forecasts are combined in the Hub model to produce a total demand forecast, known as Distribution Input (DI) per water resource zone, region and for the whole company.
- 3.3.43 The model has been developed to be consistent with the terminology and calculations in the Water Resources Planning (WRP) Tables for Normal Year Annual Average (NYAA), Dry Year Annual Average (DYAA) and Dry Year Critical Period (DYCP). It shows how each component of the demand forecast contributes to DI every year of the planning period, shown in Figure 13.




Figure 13: Forecast of Distribution Input (DI) from the base year 2016/17 until 2080/81

- 3.3.44 The final results show a general upward trend in DI. This is the result of combining the trends derived from each of the constituent forecasts (household, non-household, property and population). The increase in distribution input, notably in the long-term, is largely driven by a sustained increase in the property and population forecasts: a 27% population increase at company level and 30% increase in the property forecast results in a 55 MI/day increase in household consumption for NYAA by 2044/45.

3.3.45 The upward trend in population and household consumption is counterbalanced in the first ten years of the planning period (2020 to 2030) by a reduction in consumption arising from meter installations under the Water Saving Programme (WSP). Meter penetration increases from 59% in 2020, to over 90% in 2045 company-wide. This is the single most important factor influencing household consumption forecast in the near term.

Climate change impact on demand

3.3.46 The Multi Criteria model makes the required adjustments for climate change based on the latest UKWIR guidance⁷. Table 3 provides a summary of the uplift applied for climate change impacts on household demand throughout the forecast.

Table 3: Summary of the uplift applied for climate change impacts on household demand

		Unit	2015/16	2020/21	2025/26	2030/31	2035/36	2040/41	2045/46	2050/51	2055/56
CC Forecast	WRZ1	%	0.00%	0.18%	0.36%	0.53%	0.71%	0.89%	1.07%	1.25%	1.43%
	WRZ2	%	0.00%	0.18%	0.36%	0.53%	0.71%	0.89%	1.07%	1.25%	1.43%
	WRZ3	%	0.00%	0.18%	0.36%	0.53%	0.71%	0.89%	1.07%	1.25%	1.43%
	WRZ4	%	0.00%	0.18%	0.36%	0.53%	0.71%	0.89%	1.07%	1.25%	1.43%
	WRZ5	%	0.00%	0.18%	0.36%	0.53%	0.71%	0.89%	1.07%	1.25%	1.43%
	WRZ6	%	0.00%	0.18%	0.36%	0.53%	0.71%	0.89%	1.07%	1.25%	1.43%
	WRZ7	%	0.00%	0.18%	0.36%	0.53%	0.71%	0.89%	1.07%	1.25%	1.43%
	WRZ8	%	0.00%	0.18%	0.36%	0.53%	0.71%	0.89%	1.07%	1.25%	1.43%
	Central Region	%	0.00%	0.18%	0.36%	0.53%	0.71%	0.89%	1.07%	1.25%	1.43%
	Company	%	0.00%	0.18%	0.36%	0.53%	0.71%	0.89%	1.07%	1.25%	1.43%

⁷ UKWIR 13/CL/04/12 Impact of Climate Change on water demand.

3.4 Baseline supply forecast

Introduction

- 3.4.1 Our supply forecast represents the amount of water we can reliably supply to customers during our chosen baseline drought severity. For our fWRMP19 this is the 1 in 200 year drought, meaning that we want to be able to maintain supply in the event of a drought that occurs on average once every 200 years.
- 3.4.2 We also calculate the amount of water we can supply during specific parts of the drought, known as ‘critical periods’ which are likely to be during the summer, when the customer demand for water is significantly higher than during other parts of the year.
- 3.4.3 Our water available for use is deployable output (DO), the amount of water that we can abstract (see paragraphs 3.4.5 to 3.4.13), to which we add the net amount of water we receive from transfers (i.e. the amount of imported water less the amount of exported water) (see paragraphs 3.4.14 to 3.4.21). We then subtract the following:
- Sustainability reductions – reductions we need to make to our abstractions for environmental reasons (paragraphs 3.4.22 to 3.4.31).
 - Climate change allowance – reduction in water available as a result of climate change (paragraphs 3.4.32 to 3.4.35).
 - Outage – temporary loss of deployable output for failure process or other reasons (paragraphs 3.4.36 to 3.4.41)
 - Treatment loss – water lost during the treatment process (paragraphs 3.4.42 to 3.4.46).
- 3.4.4 The calculation of our supply forecast is presented in detail in Technical Report 1.1: Deployable output and climate change impact assessment, Technical Report 1.1.1 WRMP-DMP links and the DO Addendum Report.

Deployable Output

- 3.4.5 Deployable output (DO) is the amount of water that can be abstracted from a range of conditions but notably under dry year conditions and delivered into supply. The reliable supply over the course of a year is known as average DO (ADO) and the reliable supply during the summer is known as peak DO (PDO).
- 3.4.6 There are a number of constraints on supply which are incorporated into the calculation of DO such as the licence, or hydrogeological or physical constraints (such as the pump depth in a borehole, or a dewatering an adit⁸, or the capacity of the treatment works) and water quality issues (see further paragraphs 3.4.47 to 3.4.59 below).

⁸ An adit is a horizontal tunnel extending typically several hundred metres away from the vertical abstraction borehole. This is to enlarge the capture zone and hence the yield of the borehole.

3.4.7 Our rdWRMP19 uses average and peak DO figures for a 1 in 200 year return period drought as a baseline, which is beyond the worst historic drought experienced in the 20th century. The methodology we used to assess DO is a common method used widely in the water industry for hindcasting groundwater levels and linking them to source deployable outputs. In summary:

- we identified the worst historic drought based on hindcast groundwater levels for a number of observation boreholes (OBHs);
- we calculated the DO for the worst historic drought; and
- we used this to calculate DO for the 1 in 200 year drought; we also calculated the DO for a 1 in 500 year drought for comparison purposes.

3.4.8 The worst historic drought differs for each WRZ in terms of duration or severity but all occurred in the decades of the 1930s and 1940s and had return periods of between 1:60 to 1:80 years. We undertook further sensitivity testing that confirmed that the worst historic droughts in the 1930s and 1940s were indeed the worst in the area. This conclusion is consistent with work presented by the British Geological Survey and the Met Office, and is also consistent with Anglian Water’s assessment.

3.4.9 We calculated the 1:200 year DO figures using hindcasting. We made some adjustments to the average DO and peak DO values for some sources to reflect the latest information on our sources. This information was not available at the time of developing the DO figures for the fWRMP19 and has been derived through ongoing studies, pumping tests or recent changes in the operational patterns of some sources. This resulted in an overall increase in available DO during the 1 in 200-year event.

3.4.10 A comparison of the DO assessment for our last plan in WRMP14, our dWRMP19 and our fWRMP19 is shown in Table 4.

Table 4: Comparison of DO methodology between fWRMP14, dWRMP19, rdWRMP19 and fWRMP19

	fWRMP14	dWRMP19	rdWRMP19 & fWRMP19
DO assessment methodology	Basic assessment DO assessed using historic water level data against output data (UKWIR 1995, 2000).	Enhance assessment for drought vulnerable sources (c.65 sites) and DO re-assessed per source by developing source models and assessed in WRZ models.	As per dWRMP19, plus DO adjustment on a few sources to reflect latest operational understanding during drought conditions (overall increase).
Worst historic drought period	Assessments based on drought conditions in the 1990s, 2006 and 2012.	Assessments based on the worst historic drought in the hindcast record (1930s and 1940s) through an automated DO curve shifting approach.	Same methodology as dWRMP19 but with assessments based on a 1 in 200 year drought which goes beyond the worst historic droughts of the 20 th century.

	fWRMP14	dWRMP19	rdWRMP19 & fWRMP19
Levels of service (LoS) and return periods	Qualitative link between DO, drought return period and LoS.	It follows the existing LoS with explicit links between DO drought return periods and LoS. A range of DOs for different return periods (derived from WRSE stochastic climate data) and impact of drought conditions was tested in our EBSD model with or without demand restrictions and drought permits/orders (linking to Drought Plan).	Following EBSD testing and consultation responses, a 1 in 200 drought return period has been adopted as the baseline for the rdWRMP19, with no drought permits and orders post March 2024.

3.4.11 The ‘worst historic’, ‘severe’ and ‘extreme’ drought DOs are provided in Table 5 for the company area.

Table 5: Summary of region deployable outputs

Region	Plan	Worst historic ADO (MI/d)	1 in 200 year ADO (MI/d)	1 in 500 year ADO (MI/d)	Worst historic PDO (MI/d)	1 in 200 year PDO (MI/d)	1 in 500 year PDO (MI/d)
Central	fWRMP14	1,002	n/a	n/a	1,155	n/a	n/a
	dWRMP19	920	882	874	1,089	1,069	1,048
	rdWRMP19*	N/A	897	888	N/A	1,079	1,058
Southeast	fWRMP14	52	n/a	n/a	61	n/a	n/a
	dWRMP19	51	46	46	58	55	51
	rdWRMP19*	N/A	46	46	N/A	55	51
East	fWRMP14	38	n/a	n/a	53	n/a	n/a
	dWRMP19	38	38	38	53	53	53
	rdWRMP19*	N/A	38	38	N/A	53	53
Company Total	fWRMP14	1,093	n/a	n/a	1,269	n/a	n/a
	dWRMP19	1,009**	968	958	1,201*	1,177	1,153
	rdWRMP19*	N/A	981	972	N/A	1,187	1,162

Notes

* Figures did not change between the rdWRMP19 and fWRMP19

**The difference between fWRMP14 and fWRMP19 includes the AMP6 sustainability reductions and the move to best practice hindcasting techniques

- 3.4.12 The worst historic DO values have reduced relative to WRMP14, largely owing to the sustainability reductions and shift to a more severe worst historic drought. Changes between our dWRMP19 and fWRMP19 were based on better understanding of our sources. The EA has been consulted on the revised DO figures and at the time of publication it is understood that they endorse these changes for use in the fWRMP19.
- 3.4.13 Our Clay Lane group of sources is considered the most drought vulnerable group, because most of the boreholes within the group licence are vulnerable to a loss of pumping capability once groundwater reaches a certain level (usually the top of the horizontal tunnel deviating from the vertical borehole). During the historic droughts of 1997, 2006 and 2012 these levels were reached, resulting in partial loss of output. Considering that these relatively recent droughts have a return period less than 1 in 20, this suggests that under a more severe drought equivalent to 1 in 200, the loss of output would be even greater. Groundwater levels in this part of the aquifer also show more fluctuation with drought than other areas.
- 3.4.14 WRZs 4, 6 and 8 are assessed as not being sensitive to drought. In the case of WRZs 4 and 6, the DO is dominated by abstraction from the River Thames and the adjacent river gravels. We can abstract up to the licensed volumes and rates with no low-flow constraints. In WRZ8 the outputs of Ardleigh reservoir and the groundwater sources in the confined aquifer are also assessed to be not sensitive to drought.

Existing bulk transfers

- 3.4.15 We have a number of existing arrangements with neighbouring companies for bulk water imports. We also have arrangements to export water in bulk to neighbouring companies.
- 3.4.16 The national-level map in Figure 14 shows the location of Affinity Water in a wider geographic context where our company boundaries are shared with seven water companies⁹.

⁹ We also share boundaries with and provide bulk supplies to new appointees. These are companies appointed by Ofwat to provide water and/or sewerage services for a specific geographic area, within an existing water company's water supply area. The scale of our bulk exports to new appointees is small and we have therefore not provided information about these supplies in our fWRMP19.




Figure 14: Map of Water Companies in England and Wales

3.4.17 Our Central region shares borders with Thames Water, Anglian Water, Cambridge Water (South Staffs Water), Essex & Suffolk Water (Northumbrian Water), Sutton & East Surrey Water and South East Water. Our Southeast region shares borders with Southern Water and South East Water while our East region shares a border with Anglian Water. In a region which is so densely populated, the levels of resilience provided by bulk supply agreements is critically important. Figure 15 shows the indicative locations of our existing transfers, which are numbered according to Table 6.




Figure 15: Location of existing import and export arrangements (numbers relate to transfer IDs in Table 6).

3.4.18 Table 6 provides a summary of the volumes for each of existing transfers. The volumes stated are the available capacity under the applicable agreement or arrangement, rather than utilisations which can vary depending on needs.

Table 6: List of existing bulk transfer capacities for our fWRMP19

ID	Existing transfer	Providing Company	Receiving Company	Maximum capacity at average MI/d	Maximum capacity at peak MI/d
1	Existing	Anglian	Affinity Water WRZ3	91*	109.0
2	Existing	Thames	Affinity Water WRZ4	12	27.0
3	Existing	Thames	Affinity Water WRZ4	0.2	0.2
4	Existing	Thames	Affinity Water WRZ4	2.0	2.0
5	Existing	Thames	Affinity Water WRZ6	2.27	2.27
6	Existing	Cambridge	Affinity Water WRZ5	0.30	0.30
7	Existing	Affinity WRZ3	Anglian Water	0.14	0.14
8	Existing	Affinity WRZ6	South East Water	36.0	36.0
9	Existing	South East Water	Affinity Water WRZ7	2.0	2.0
10	Existing	Southern Water	Affinity Water WRZ7	0.0714	4.0

*We have capped the average capacity of this transfer to 50 MI/d, until 2023/24 when we expect to have installed conditioning treatment at Sundon.

- 3.4.19 We have a statutory arrangement with Anglian Water for a supply to our WRZ3. The maximum amount of water we are authorised to take under average conditions is 91 MI/d. At present, we are unable to utilise all of this import for water quality reasons. We are planning to build a treatment plant during AMP7 to condition the water imported to ensure that the full 91 MI/d peak capability can be transferred. Within our investment modelling we have therefore capped the average capacity of this transfer to 50MI/d, until 2023/24 when we expect to complete the new treatment plant at Sundon.
- 3.4.20 We have two existing imports to our WRZ7 in our Southeast region; one from South East Water at Barham and one from Southern Water at Deal. These imports are both subject to agreements which end on the 31 of March 2020.
- 3.4.21 In our East region we operate a shared reservoir with Anglian Water under a statutory arrangement. We are entitled to take 50% of the output from the reservoir but have agreed with Anglian Water a share of 70%/30% (in favour of Anglian Water) until 2025. We will revert to a 50%/50% share from 2025.
- 3.4.22 We also retain a number of emergency inter-company connections that can provide additional resilience but which are not large enough to be considered bulk transfers. These are used to help meet customer demand in instances when our normal supplies are insufficient; for example, due to drought, high demand or outage.

Sustainability Reductions and Water Industry National Environment Programme

- 3.4.23 Our fWRMP19 provides for reducing our abstractions from the environment by 36.31 MI/day during AMP7. Table 7 sets out our sustainability changes and reductions agreed with the EA following publication of its Water Industry National Environment Programme (“WINEP”).

Table 7: WINEP3 AMP7 (2020 to 2025) Sustainability Changes and Reductions for Central and East regions and presented at a Company level

Used in rdWRMP19	Average Sustainability Change to licence MI/d	Peak Sustainability Change to licence MI/d	Average Sustainability Reduction to DO MI/d	Peak Sustainability Reduction to DO MI/d
Central (Green)	39.2	19	27.33	13.4
Central (Amber)	5.22	9.14	6.38	7.66
Central (Total)	44.42	28.14	33.71	21.06
East (Green)	0	0	0	0
East (Amber)	2.597	2.597	2.6	2.6
East (Total)	2.597	2.597	2.60	2.60
Total Company			36.31	23.66

- 3.4.24 Our fWRMP19 plans to deliver all green and amber sustainability reductions included on WINEP and we have deducted these volumes from our DO in calculating our baseline supply.
- 3.4.25 There are two sources in Central region (WRZ1) with a combined amber sustainability reduction of 6.38MI/d average and 7.66MI/d at peak. A further 2.6MI/d amber sustainability reduction at peak and average has been included for WRZ8. Uncertainty remains over the required volume of reduction from these amber sources and we will continue to work with the Environment Agency to confirm any volumes for implementation in AMP7.
- 3.4.26 The WINEP is a list of environmental improvement schemes defined by the EA. In addition to sustainability reductions, it includes other measures to support achievement of the water body environmental objectives under the WFD, such as morphological works. Our fWRMP19 includes the full programme of river morphology actions listed on WINEP3, in discussion with the EA. We are working with the EA to refine the location and projects to start work in AMP7 (2020-2025). We have also included biodiversity enhancement works on our landholdings, to meet our duties under the Natural Environment and Rural Communities Act 2006 and our catchment management planned work.
- 3.4.27 WINEP also provides for us to carry out investigations where it is suspected that abstraction may be impacting on achievement of environmental objectives. Where an investigation confirms an impact then an options appraisal is carried out to assess the most appropriate way forward. This is assessed against a cost benefit ratio context to understand the viability of the different options, e.g. river restoration and habitat enhancement, river support schemes or changing an abstraction licence. The EA has identified 25 new investigations and options appraisals in WINEP all with “green” level of certainty.

Table 8: Investigations and options appraisals identified for AMP7 with a green level of certainty in WINEP3

Watercourse study	Type of investigation	Source(s) under investigation
Nailbourne and Little Stour	No deterioration surface water investigation and/or options appraisal WFD_NDINV_WRFflow	Broome, Rakeshole, Tapping, Denton South, Ottinge, Worlds Wonder, Skeete,
Upper Dour		Drellingore and Lye Oak
Dour		Buckland Mill, Dover Priory, Connaught, Coombe Farm, Primrose, Elms Vale
North and South Streams		Kingsdown, Lighthouse
Stutton Brook		East Bergholt, Lattinford
River Chelmer		Hempstead, Armitage Bridge, Thaxted
River Ash		Thundridge and Hadham Mill
River Rib		Thundridge, Wadesmill, Sacombe, Chipping and Standon
Stort and Bourne Brook	Investigation and/or options appraisal WFD_INV_WRFflow	Causeway, Stansted and North Stortford
River Lee (Hertford to Fieldes Weir)		Thundridge and Musley Lane
River Brett		Shelley, Higham, Stoke-by-Nayland, Stratford St Mary, Lattinford, Dedham, Lawford
River Colne		Netherwild, Bricketwood, Wall Hall, Berry Grove, Bushey Hall, Bushey, Eastbury, Tolpits

Watercourse study	Type of investigation	Source(s) under investigation
Upper Bedford Ouse Chalk	Groundwater investigation and options appraisal WFDGW_NDINV_GWR	Crescent Road, Kings Walden, Watton Road, Aston, Broomin Green, Baldock Road, Fuller and Bowring
North Essex Chalk		Armitage Bridge, Thaxted, Hempstead, Dunmow, Higham, Lattinford, Shelley, Stoke-by-Nayland, Dedham, Lawford, Stratford St Mary and East Bergholt
Mid Chilterns Chalk		Chesham, Chartridge, Berry Grove, Bricket Wood, Bushey, Netherwild, Blackford, Chorleywood, Mill End, Wall Hall, Northmoor, Springwell, Stockers, West Hyde, Gerrards Cross, Kensworth Lynch and Great Missenden
Upper Lee Chalk		Crescent Road, Kings Walden, Watton Road, Aston, Broomin Green, Porthill, Thundridge, Hadham Mill, Causeway, Stansted, North Stortford,
North Essex Chalk	Groundwater investigation and options appraisal WFDGW_INV_GWR	Armitage Bridge, Thaxted, Hempstead, Dunmow, Higham, Lattinford, Shelley, Stoke-by-Nayland, Dedham, Lawford, Stratford St Mary and East Bergholt
Mid Chilterns Chalk		Piccotts End, Mud Lane, Holywell, Amersham, Chalfont St Giles and Marlowes
Upper Lee Chalk		Digswell, Whitehall, Sacombe

- 3.4.28 In addition to the above, we are currently at risk of losing 2.9 MI/d ADO at Friars Wash, which is the subject to an ongoing discussion with the EA. We have included this as a reduction in the baseline for all of the economic analyses carried out for the decision-making process, as detailed in Section 5 of this Plan.
- 3.4.29 Our groundwater licence (8/36/17/G/0082) includes a provision to support flows in the River Brett when instructed to do so by the EA. This requires up to 25 litres per second (2.16MI/d) to be discharged to the River Brett. As there is no flow trigger on the licence for the river support, this is not included within our DO assessment but can be accommodated within our existing supply surplus. The requirement for river support will be assessed as part of the Brett AMP7 WINEP investigation and options appraisal. We have also made provision for a sustainability reduction of 2.6MI/d from this group licence, as shown in Table 7 above.
- 3.4.30 As part of this process, we are adding to our already extensive monitoring programme. This will allow us to identify the benefits to river flows and ecology where reductions are made, as well as improve our understanding of the way in which river catchments and Chalk aquifers behave across a range of drought conditions.
- 3.4.31 Our evidence shared with the EA from the AMP6 WINEP investigations indicates uncertainty around the environmental benefit of implementing some abstraction reductions included in WINEP3. We will continue to discuss reductions with the EA as more evidence becomes available to help ensure reductions are made in locations where environmental benefit will be realised. The timing and extent of the AMP7 schemes is currently as laid out in the WINEP, and we will implement these changes as soon as is practicable through our investigation and options implementation programme. We commit to investigating and implementing voluntarily changes to our Chalk abstraction licences beyond the current WINEP programme in future AMP periods where it is sustainable and beneficial to do so and we are able to maintain security of supply to customers.

3.4.32 More detail on these schemes can be found in Technical Report 1.4.1 AMP6 NEP Progress and Summary of WINEP PR19 Schemes.

Impacts of climate change on supply

3.4.33 The worst historic, severe and extreme drought DOs are representative of the reliable outputs that could have been achieved in the past (but with current levels of demand and abstraction). However, the DOs that might be available in a current or future drought could vary in response to the changing climate.

3.4.34 The impact of climate change on the worst historic DO is provided in Table 9 for 2020 and for the 2080s calculated using two methods: one is based on a revised equation within the regulator’s Water Resources Planning Guideline (WRPG) for the WRMP19 and the other based on the equations within the WRPG for WRMP14. The Clay Lane group is considered to be the most vulnerable to climate change because most of the boreholes in this group are vulnerable to loss of pumping capability once groundwater levels fall to a certain level (see further section 3.4 above).

3.4.35 WRZs 4, 6 and 8 are assessed as being not sensitive to climate change (for the same reasons as given above with respect to drought sensitivity) and show no predicted change to DO as a result of climate change. Climate change is predicted to impact on WRZs 1, 2, 3, 5 and 7, with the greatest impact occurring in WRZ2. Further detail of our climate change assessment is provided within Technical Report 1:1 Deployable output and climate change impact assessment.

Table 9: Summary of climate change impacts on supply

Region	Median Impact on ADO (MI/d) in 2020 (WRMP14 equations)	Median impact on ADO (MI/d) in 2020 (dWRMP19 equation)	Median impact on ADO (MI/d) 2079/80 (and 2045 in brackets)	Median impact on PDO (MI/d) in 2020 (WRMP14 equations)	Median impact on PDO (MI/d) in 2020 (dWRMP19 equation)	Median impact on PDO (MI/d) 2079/80 (and 2045 in brackets)
Central	-9.42	-17	-41 (-26)	-6.2	-11	-27 (-17)
Southeast	0	0	0	0	0	1 (1)
East	0	0	0	0	0	0
Company Total	-9.42	-17	-41 (-26)	-6.2	-11	-26 (-16)

3.4.36 For this fWRMP19 we have adopted a ‘hybrid’ approach of the two methods whereby we have adopted the long term 2080 impact and glidepath but included the increase that this has in comparison to WRMP14 incrementally over the 2020 to 2025 period. The resulting climate change impact for the central region for DYAA and DYCP can be seen in Figure 16 and Figure 17.




Figure 16: Climate change impact Central region (DYAA)




Figure 17: Climate Change impact Central region (DYCPP)

Outage allowance

- 3.4.37 Outage is defined as a ‘temporary loss of deployable output’ within the UKWIR report ‘Outage allowances for Water Resource Planning’ (UKWIR, 1995). Outage events can be planned because of the need to carry out maintenance. Alternatively, they can be unplanned, caused by events such as pollution of a source, power failures or system failures.
- 3.4.38 The outage allowance was calculated following the methodology as set out in the ‘Affinity Water Method Statement: Outage Assessment WRMP19’ as well as the UKWIR (1995) methodology for assessing outage allowances within Water Resource Planning. Detailed information on this assessment can be found in Technical Report 3.1 – Outage.
- 3.4.39 An outage assessment was undertaken for seven of our eight WRZs (WRZs 1-7). WRZ8 was not assessed because guidance indicates this is not required where deployable output exceeds demand by a comfortable buffer, as it does in WRZ8.

3.4.40 The assessment made use of data about the duration and magnitude of outages obtained from our outage recording system (TRACE) for our Central region (WRZs 1-6) for the period 2012 to 2017 and from an operations log for our Southeast region (WRZ7).

3.4.41 We used this data in a Monte-Carlo computer model to obtain an outage allowance for each WRZ, which are shown in Table 10 alongside the PR14 and PR09 outage figures for direct comparison.

Table 10: Summary of outage allowance - all zones.

	WRMP09		WRMP14		WRMP19	
	Average	Peak	Average	Peak	Average	Peak
WRZ1	2.96	6.69	5.82	7.36	5.76	1.20
WRZ2	7.02	9.38	6.31	4.83	4.03	0.59
WRZ3	4.82	10.36	14.59	13.77	12.50	2.70
WRZ4	24.05	8.86	6.28	4.56	15.86	2.31
WRZ5	2.45	6.35	2.76	2.6	2.84	0.75
WRZ6	20.21	9.13	6.05	6.7	6.72	2.88
Central Region	61.51	50.77	41.81	39.82	47.69	10.43
WRZ7 Southeast	3.6	2.2	2.02	1.58	1.33	1.01
Company	65.11	52.97	43.83	41.40	49.02	11.43

3.4.42 During periods of average demand, the total outage in our Central and Southeast regions was found to be 49MI/d, whilst at critical periods of demand, the total outage was found to be 11MI/d. The critical period was defined as the peak week with a two-week buffer either side. The outage type contributing most to our outage is shutdowns associated with raw water quality at our large surface works. The only option for reducing this is the provision of either bankside storage or additional emergency supply routes at our key surface water site.

3.4.43 We have included this in the investigations and potential design of our preferred strategic option, as described in Section 6.3 of this Plan.

Treatment works adjustment

3.4.44 Some water will be lost during the treatment process. We calculated an allowance for these by using information about typical losses at our treatment works.

3.4.45 At our surface water works and more complex groundwater treatment works, we meter the amount of water abstracted and the amount of water leaving the works, being the distribution input (“DI”). The difference between the two represents the quantity of water that is lost during treatment. These meters are calibrated to ensure accuracy (although even then they can have an error of 2-3%) and operate continuously.

3.4.46 We also meter at other points around our works; only the waste from small water quality monitors such as residual chlorine or turbidity instruments are unmetred. We have progressively reduced treatment works losses by adding secondary treatment in many cases

with supernatant returning to the head of the works after abstraction metering, therefore total losses are small.

3.4.47 At other groundwater sites, where raw water quality is good such that it requires minimal treatment, we meter only at the point of abstraction. Waste at these sites has only two elements: pumping to waste at start-up or as a result of maintenance and continuous water quality monitoring instruments. Records are kept at each site for periods of pumping to waste and copied to our control room where adjustments to daily integrated flow reports are recorded.

3.4.48 Our treatment losses amount to 13.72 MI/d at DYAA and 13.92 at DYCP. This represents less than 2% of DI, and is low as a result of the improvements that we have made in previous years. We carried out a full review of potential options as part of our unconstrained options report (see Section 8.2 of that report) and concluded that there were no more significant reductions that we could achieve whilst maintaining our commitments to water quality.

Water quality

3.4.49 Water quality considerations are an essential part of water resources planning. They may:

- put at risk, from diffuse or point pollution of raw water, the amount of water available to us to treat and supply
- constrain how we transfer water within our water supply area.

3.4.50 As part of our planning process we have reviewed the implications that risks to water quality might have on our fWRMP19. That evaluation includes risks to our current sources and consideration of the water quality implications of new supply options.

3.4.51 Historically we have seen a significant effect from diffuse and point source pollution on our sources. We have been proactive in monitoring and investigating pollution threats. Our Drinking Water Safety Plan risk assessments have identified that there are a number of ongoing risks to our sources, including from pesticides, lead, nitrates and discolouration.

3.4.52 We have adopted a twin track approach to managing and mitigating these risks. This comprises:

- Catchment management (including investigating and quantifying risks using catchment surveys, water quality monitoring, nitrate source apportionment modelling and groundwater level and abstraction data).
- Optimisation of existing treatment assets and, where appropriate, the provision of new treatment assets.

3.4.53 Our Catchment Management programme for water quality was established in 2010 to help deliver our commitment given in water quality undertakings provided to the Secretary of State in respect of metaldehyde. Since then, our programme has evolved significantly and is now aligned to the WFD National Environment Programme (water quality).

- 3.4.54 In 2013, we stopped abstracting from a groundwater source due to increasing nitrate concentrations. There is a significant risk of further loss of groundwater supplies between now and 2040 as a result of increasing nitrate concentrations. Our catchment management investigations conclude that it could take decades to see the benefits of catchment management activities in respect of nitrates.
- 3.4.55 Our surface water treatment works have no bankside storage (raw water reservoirs) to enable us to manage the risk of temporary river pollution events. To mitigate this risk, we plan to:
- enhance water quality monitoring in the catchment and at the treatment works
 - apply advanced modelling techniques to enable us to predict and forecast scenarios
 - optimise existing treatment assets and, where appropriate, provide new treatment assets.
- 3.4.56 Even with our ‘twin track’ approach of catchment management and investment in treatment processes, there is still a risk that we will have to reduce or discontinue abstraction at some of our sources due to trends in pollution risk. We have fully accounted for these residual risks within our assessment of Target Headroom using industry standard techniques, as described in section 3.5.
- 3.4.57 The only significant residual water quality risk that we have not included within our Target Headroom calculation relates to the bromate contamination plume that caused us to stop using our Hatfield source for water supply in 2000.
- 3.4.58 Currently, we are using this source in a mitigation capacity where we abstract and pump the polluted water to waste to prevent the bromate from polluting our Essendon source. In the medium term, the existing arrangement will not be adequate once the contamination within the Chalk matrix reaches Hatfield and puts at risk other sources. We expect the EA to use its powers under Part IIA of the Environment Act 1990 to mitigate this risk as far as is reasonably practicable.
- 3.4.59 We are constrained by water quality considerations in how we transfer water across our supply area. For example, we can only use imported water from Grafham to supply local areas in the north of the Central region of our supply area (or to other locations only for limited periods of time). This has the effect of limiting our maximum import from Grafham WTW to 50 MI/day average and prevents us from supplying the treated water from Grafham WTW widely within our supply area. The construction of the planned conditioning treatment at Sundon would remove the current constraint.
- 3.4.60 The Drinking Water Inspectorate (DWI) has produced guidance that explains that the duty in section 68(1)(b) of the WIA 1991 may impact on transfers of water within a company’s supply area and for exports and imports across company boundaries.
- 3.4.61 The DWI Guidance explains that the standard of no deterioration (referred to in Section 68(1)(b)) should be measured by reference to compliance with the standards of wholesomeness (paragraph 4.3.6). Paragraph 4.3.7 specifically states:


“Proposals to transfer water that increase the risk of non-compliance, or of consumer complaints about the aesthetic character of the water supply, such as by taste and/or odour, discolouration, nitrates, pesticides or bacteriological challenge, will not be permitted until steps to mitigate those risks are in place.”

3.5 Risk and uncertainty – target headroom

- 3.5.1 WRMPs are based on the best available and most appropriate data and methods, but due to the long-term planning nature it is inevitable there will be a degree of uncertainty in the forecasts.
- 3.5.2 We address this uncertainty in our fWRMP19 in two ways which are provided for in the current Water Resources Planning Guideline:
- by calculating a volume of water (or buffer) that is subtracted from our supply-demand balance to cater for supply-side and demand-side uncertainties – target headroom
 - through our decision-making process to arrive at an adaptive plan.
- 3.5.3 We have used target headroom to allow for risks and uncertainties associated with calculation of our baseline and our adaptive planning to address risks and uncertainties associated with future policy considerations. We have ensured there is no double-counting such that each risk and uncertainty is only taken into account through one of target headroom or adaptive decision-making. We explain target headroom in the rest of this section. The way in which our adaptive planning takes account of future uncertainty is explained in Chapter 5.
- 3.5.4 Target headroom is determined by applying a risk profile to total headroom uncertainty. The planning risk allowance reflects a range of uncertainty. For the different forecast time horizons in our Plan we include a different proportion of the full uncertainty range as a planning risk allowance. The proportion of the potential uncertainty range that we include reduces over time in accordance with standard water industry practice. Until 2024/25 we have included most of the full range of uncertainty in our Target Headroom allowance (statistically this is equivalent to the ‘95th percentile’). We have then taken less of the full uncertainty range, decreasing our allowance to the 75th percentile in 2044/45 and the 60th percentile in 2079/80 (to set this in context, the 50th percentile of the range is equal to our expected central estimate - i.e. effectively no Target Headroom allowance). The headroom results have then been interpolated between the 2019/20 and 2079/80 values to permit a smooth target headroom profile to be derived.
- 3.5.5 Baseline dry year (DYAA) target headroom varies from 94.05 MI/d (or 9.95% of the company 1 in 200 DO) in 2020/21, the base year, to 62.43 MI/d (or 6.60% of DO) in 2079/80, the final year of the plan. Baseline critical period (DYCP) target headroom varies from 148.58 MI/d (or 12.91% of DO) in 2020/21, the base year to 95.12 MI/d (or 8.27% of DO) in 2079/80.
- 3.5.6 We acknowledge that it is unusual that target headroom is higher at the start of the planning period than the end. This is because we have included the risk associated with the WSP and the associated delivery risk within our demand forecast, rather than as an option for development in our decision-making process. This includes the reduction in demand between

2016/17 (our base year) and 2020, which means target headroom is high as a result of this demand uncertainty at the start of the planning period.

3.5.7 The impact of the WSP on the Target Headroom allowance is demonstrated in the figures below for two of the higher Target Headroom WRZs.



This figure illustrates the relative contribution (in MI/d terms) of the individual elements of risk and uncertainty (Target Headroom 'components'), labelled S3 to D4. The uncertainty over future demand attributed to the WSP is shown under component 'D2'

Figure 18: Proportional Contribution of Target Headroom Factors in WRZ5.




Figure 19: Proportional Contribution of Target Headroom Factors in WRZ6.

3.5.8 Since these example WRZs fall within the Central region, the effect of the WSP will be significant in these areas. Therefore, the uncertainty relating to WSP saving in the household demand forecast will be large and is reflected in the D2 component. Clearly the D2 component

makes up a large proportion of headroom throughout the planning period. It is the early years where this is of the greatest volumetric impact.

3.5.9 Because this results in a relatively large Target Headroom allowance in the Central region, we have undertaken a comparison between our allowance and those of other water companies across England. The findings of this assessment are presented in the graph below. This demonstrates that it is only in the early years of the Plan that we are an outlier, which is caused by the way that we have allowed for WSP uncertainties, but the allowance drops below other water companies between years 10 and 30 (2030 to 2050) of our Plan.

3.5.10 By the earliest date for delivery of a strategic supply-side scheme (2038) our overall Target Headroom is similar to Southern Water's, and below South East and Severn Trent.




Figure 20: Comparison of Target Headroom

3.5.11 It should also be noted that the allowance towards the end of the statutory planning period (2040, or year 20 in the above chart) for the Dry Year Annual Average (DYAA), which is the key driver for strategic investment, is also almost identical to the value that we used in WRMP14.

3.5.12 There are some changes to target headroom compared to that calculated for WRMP14. Dry year baseline target headroom as a percent of total DO:

- is similar to WRMP14 for WRZ1, WRZ2, WRZ3 and WRZ6
- has decreased for WRZ7
- has increased for WRZ8 for the first years but broadly similar from 2029/30
- has almost approximately doubled for WRZ4 and WRZ5.

3.5.13 The picture is more complex when comparing critical period target headroom to WRMP14 as a percent of DO, where it has:

- increased notably in WRZ3, WRZ4 and WRZ5
- has increased in WRZ3

- is broadly similar in WRZ2 and WRZ8
- has decreased in WRZ1, WRZ6 and WRZ7.

3.5.14 The most significant change in baseline target headroom as a percent of DO was in WRZs 4 and 5, where it has approximately doubled. This is related principally to increase in demand forecast uncertainty including uncertainty in savings expected from WSP (as described above), increase in uncertainties of source yields and an updated method to calculate climate change uncertainties.

3.5.15 Technical Report 3.2 contains supporting evidence and sets out clearly the assumptions behind the ambitious levels of demand management savings contained in our fWRMP19 and the impact of climate change on headroom.

3.6 Baseline supply demand balance

3.6.1 We calculated our baseline supply-demand balance as:

	Water available for use (or supply)
Minus	Water demand (Distribution Input, DI)
Minus	Target headroom

3.6.2 Water Available for Use, or WAFU, is simply the water that is available for supply within each WRZ and is equal to the Deployable Output, minus outage, minus treatment losses plus or minus the net imports and exports from the WRZ.

3.6.3 We calculated a baseline supply-demand balance for each WRZ and combined them to produce a baseline supply-demand balance for each of our supply regions. They are summarised in Table 11, which shows we are facing a significant supply-demand deficit in our Central region from 2020 onwards, a small deficit in our Southeast region and a small surplus in our East region.

3.6.4 It should be noted that the ‘deficit’ in the Central region that is highlighted in 2020 is reflective of our desired change to drought resilience moving from the worst historic drought to 1 in 200 year drought. We cover this ‘deficit’ in the first few years of our Plan through the use of drought permits and orders (emergency abstractions during drought events), but stop reliance on those interventions as early as we practically can, at the latest by December 2024. Section 6.10 provides further information on our drought levels of service before and after implementation of our fWRMP19.


Table 11: Supply-Demand balance for 2020, 2045 and 2080 for all regions at DYAA and DYCP

Region		Supply-Demand Balance (MI/d)		
		2020	2045	2080
Central	DYAA	-54.5	-107.9	-255.7
	DYCP	-26.8	-100.7	-279.5
Southeast	DYAA	1.3	-0.1	-4.3
	DYCP	-0.65	-3.8	-11.1
East	DYAA	7.2	3.2	0.2
	DYCP	13.9	9.8	6.2

3.6.5 We present our supply-demand balances for each region in more detail (paragraphs 3.6.6 to 3.6.11 below) and then at a more detailed WRZ level below (paragraphs 3.6.12 to 3.6.14 below). We conclude by explaining why our baseline position appears to have worsened since our WRMP14.

Central region

3.6.6 Figure 21 shows the baseline supply / demand balances at Dry Year Annual Average (DYAA) and Dry Year Critical Period (DYCP) for our Central region. The water available for supply is reduced by 33.7 MI/day by 2024/5 as a result of sustainability reductions; this is off-set by use of our full statutory entitlement of Grafham Water from 2024/5 onwards following installation of conditioning treatment at Sundon. The water available for us then falls through the planning period due to the impact of climate change.






Figure 21: Central region baseline supply / demand balance at DYAA and DYCP

- 3.6.7 Demand initially falls under average and peak conditions as a result of our WSP. It rises from 2027/28 due to population growth, estimated to be 12% by 2025, 27% by 2045 and 50% by 2080, equivalent to 1.6 million more people living in our Central region.
- 3.6.8 The baseline supply-demand balance shows that by 2045 there is a shortfall of water of 100.7 ML/d under peak conditions and 107.9 ML/d under average conditions. This shortfall increases by 2080 to 279.5 ML/d at peak and 255.7 ML/d under average conditions.

Southeast region

- 3.6.9 Figure 22 shows the baseline supply-demand balances at Dry Year Annual Average (DYAA) and Dry Year Critical Period (DYCP) for our Southeast region.
- 3.6.10 There is no significant change in the amount of water available for use between 2020 and 2080. Demand increases from about 2026 onwards due to population growth in the region of 13% by 2025, 32% by 2045 and 64% by 2080, equivalent to over 100,000 more people living in our Southeast region. This growth in demand results in the small surplus of 1.3 ML/ under average conditions in 2020 moving to a small deficit of 0.1 ML/day under average conditions in 2045 to a larger deficit of 4.3 ML/day under average conditions in 2080.




Figure 22: Southeast region baseline supply / demand balance at DYAA and DYCP

East region

3.6.11 Figure 23 shows the baseline supply-demand balances at Dry Year Annual Average (DYAA) and Dry Year Critical Period (DYCP) for our East region. Our East region is in surplus under both average and peak conditions from 2020 to 2080. The water available for use drops in 2024/25 in response to a sustainability reduction; it also reflects reversion to a 50:50 share with Anglian Water for our jointly owned Ardleigh Reservoir from 2024/25 from the current 70:30 share. We note that we tend to require a small surplus within our East region due to operational constraints on transfers within the WRZ, as we can encounter operational issues in the area served by Ardleigh reservoir if the zone as a whole only just meets a supply-demand balance.




Figure 23: East region baseline supply / demand balance at DYAA and DYCP

Baseline supply-demand water balance by WRZ

3.6.12 Table 12 and Table 13 present the supply-demand balance by WRZ for the beginning, mid and end of our planning horizon. The information is displayed in a map format in Figure 24.

Table 12: Baseline zonal supply-demand balance for DYAA

DYAA	2020/21	2044/45	2079/80
WRZ1	-0.53	-3.38	-2.29
WRZ2	-17.14	-40.27	-59.22
WRZ3	-9.76	-20.47	-66.92
WRZ4	-17.36	-21.44	-67.02
WRZ5	-28.80	-38.00	-52.20
WRZ6	19.06	15.68	-8.03
WRZ7 – Southeast region	1.30	-0.09	-4.28
WRZ8 - East region	7.19	3.22	0.18
WRZ1 to 6 - Central region	-54.53	-107.88	-255.68

Table 13: Baseline zonal supply-demand balance for DYCP

DYCP	2020/21	2044/45	2079/80
WRZ1	14.48	9.77	9.41
WRZ2	6.51	-0.03	-16.98
WRZ3	31.59	-13.79	-68.14
WRZ4	-73.61	-77.51	-137.53
WRZ5	-37.83	-49.19	-67.91
WRZ6	32.05	30.04	1.60
WRZ7 -Southeast region	-0.65	-3.75	-11.18
WRZ8 - East region	13.96	9.82	6.20
WRZ1 to 6 - Central region	-26.81	-100.70	-279.55




Figure 24: Baseline Supply-Demand balance by WRZ for 2020, 2045 and 2080

3.6.13 These show the baseline supply-demand balance by WRZ under average and peak conditions for 2020, 2045 and 2080. Under average conditions at the beginning of the planning period in 2020 there is a surplus of water in the Wey community (WRZ6) to the south of the Central region and a deficit across the other WRZs in the Central region increasing in severity in a north-easterly direction.

3.6.14 In 2045 there is a similar pattern but with a more severe shortfall of water. By 2080 all WRZs in the Central region are in deficit with the largest shortfall of water existing in the north-western areas. This shows a clear need to increase the connectivity between WRZs in our Central region in a broad south-westerly to north-easterly direction. We propose to carry out a programme of work to provide additional connectivity to move water from the south-west (WRZ6), an area of surplus, to feed the WRZs further north in deficit. This is known as “Supply 2040” and is described in Section 6.3.

Changes since WRMP14

- 3.6.15 Since WRMP14 there has been a significant change in baseline. The key reasons for this are:
- A change in methodology to assess DO, which has tended to result in lower assessments of DO.
 - Incorporation of additional sustainability reductions.
 - Increase in severity of baseline drought to a 1 in 200-year design drought from the worst historic drought, which was used for WRMP14.
 - Reduction in use of import from Anglian Water at average conditions to a maximum of 50 Ml/day until 2023/24 due to water quality constraints; this was previously included at full statutory entitlement of 91 Ml/day even though we could not make use of this volume operationally.
 - Higher demand at 2020 because population and PCC is higher in the 2016/17 base than was forecast in the WRMP14.

4 Appraisal of future options

4.1 Introduction

4.1.1 Our baseline supply-demand balance shows that without action being taken there would not be enough water to meet our forecast demand. Our next step is to work out what options we have available to us to increase our supply of water and to reduce our demand for water. This process is known as an options appraisal.




Figure 25: WRMP Process

4.1.2 Our options appraisal follows the industry standard approach as set out in UKWIR (2002) as updated in the Decision-Making Process: Guidance (2016) referred to in the WRMP Guidelines. It has three stages:

- Stage 1 Unconstrained options – we compile a list of all possible options for increasing our supply or reducing demand for water, which are technically feasible (see Section 4.2 below and Technical Report 4.1).
- Stage 2 Options screening – we subject all of the unconstrained options to a screening process to create a shorter list of “feasible options” (see Section 4.3 and Technical Reports 4.2 and 4.3).
- Stage 3 Feasible options development – we develop the feasible options in more detail, assessing the cost to construct and operate them, assessing their environmental and social costs and further evaluating them (see Section 4.4 and Technical Reports 4.4 to 4.7 and 4.9).

4.1.3 Our list of feasible supply options include six strategic supply options, which are options capable of delivering a minimum of 50 MI/day additional water but which require significant investment to bring them forward. We describe these in section 4.6.

4.1.4 Stages 2 and 3 above have been informed by the work carried out in preparing our SEA, our HRA and our WFD Assessment. At the options screening stage, we screened out any options having an unacceptable environmental impact. These included options where there was no further water in the catchment or where the option may have a significant impact on a designated site. Information from the SEA assessment was then used as one of the three key factors taken into account at the secondary screening stage. Further detail of how this has

been done is provided in section 4.5 and we set out the results of our SEA, HRA and WFD Assessment in section 6.8.

4.2 Unconstrained options – Stage 1

Unconstrained supply option types

4.2.1 Our list of unconstrained options for increasing our supply include the following option types:

- **Surface water** – increasing the amount of water we take from surface water sources, including reservoirs and river augmentation schemes, where the flow in a watercourse is supported (for example by a release of water from a reservoir) enabling more water to be abstracted.
- **Groundwater** - constructing new boreholes, improving the performance of existing boreholes and drought options, temporarily increasing abstraction during times of drought.
- **Transfers and trading** – transfers within a WRZ, transfers between our WRZs and transfers from our neighbouring water companies, known as bulk supplies.
- **Treatment** – improving the treatment of water (e.g. new treatment processes or reducing the losses of water during the treatment process) so that more of the water abstracted can be used for public water supply (e.g. new treatment works and process losses).
- **Effluent reuse** – making use of waste water from sewage treatment works.
- **Third party options** – transfers from third parties or trading of abstraction licences. An abstraction licence is granted by the EA and fixes the amount of water that the holder may abstract from the environment. The holder of an abstraction licence can choose to transfer all or part of its licence to another person subject to satisfying the EA that this will not adversely affect the environment.
- **Outage** – reducing the amount of time that an existing source is unavailable.
- **Catchment management** – addressing issues with the quality of the raw water we abstract allowing us to use that water.
- **Desalination** – treating seawater to make it suitable for drinking.

4.2.2 In relation to outage, we have included provision of bank-side storage and/or emergency supply routes in our design of our strategic options, as described in Section 6.3 of this Plan. For other outage types, we carried out a review of sites and options, which is referenced in our unconstrained options report (Technical Report 4.1). This concluded that there were only a small number of options and that the savings achieved were minimal (<0.5MI/d).

4.2.3 We propose to continue with and increase our catchment management programme during AMP7, which is intended to offset the risk of increasing outage due to catchment issues such

as rising nitrates. These have significant benefits, but we have elected to exclude both the risks and the benefits from the fWRMP19 as they are complex and uncertain. We also have proposals relating to intake protection in our Business Plan to allow us to shut down our surface sites to avoid water quality failures. However, these by their very nature result in outages at the works, so they do provide benefit to the supply/demand balance.

4.2.4 We also considered options to provide additional resilience to our operations or networks. Within our unconstrained options review these types of options are often to replace or twin an existing asset, e.g. a new treatment works, or a new mains connection. These options do not increase the water supplied but they ensure that we can make best use of the water we have available and increase resilience of our network.

Unconstrained demand option types

4.2.5 The demand option types are as follows:

- **Leakage** – reducing the amount of water lost from our network.
- **Metering** – improving our measurement of water used to enable customers to better understand and control their usage and allow us to identify leaks more easily.
- **Reuse** – small scale re-use of grey water, which is water from baths, showers and washing.
- **Water efficiency** – reducing the amount of water that customers use.
- **Tariff** – adjusting the price customers pay for water to provide an incentive to reduce use.

4.2.6 The number of unconstrained options of each type is set out in Table 14 and the full list is available in Technical Report 4.1 and Technical Report 4.2.

Table 14: Unconstrained option numbers by option type

		Unconstrained Options	
		Option Types	Number of Options
Supply	Surface Water		56
	Groundwater		111
	Conjunctive Use		0
	Transfers and trading		134
	Treatment		17
	Effluent Reuse		10
	Third Party		Included in transfers and groundwater options
	Outage		4
	Catchment Management		1
	Desalination		18
	Effluent Reuse		10
Demand	Leakage		11 (plus ALC)
	Metering		5
	Reuse		4
	Water Efficiency		7
	Tariff		1
TOTAL			389

4.3 Options screening – Stage 2

Screening our supply options

4.3.1 We used a two-stage approach to screen our supply options:

- a high-level screening; and
- a more detailed secondary screening.

4.3.2 Our high-level screening was on the basis of a traffic light system, which allocated each option to one of three categories:

Green – no major issues or sensitivities identified for this option.

Amber – some issues or sensitivities identified, which may not be showstoppers but which could result in risks or complicated design and implementation strategies. For example, this could be an option located within an Area of Outstanding Natural Beauty (AONB).

Red – significant issues or sensitivities that affect the ability to implement this option. This included options in areas where there is no further water available within the catchment (under the EA Catchment Abstraction Management Strategies or CAMS) or where the option may have a significant detrimental impact on a designated site.

4.3.3 We took forward 104 green and amber options. Green options were included on the constrained options list on the basis of the traffic light screening. Amber options were subject to the secondary screening stage.

4.3.4 Our secondary screening consisted of a peer review of these options focused on the following factors to decide whether each option should be developed into a constrained option:

- **Technical feasibility** – the option yield, being the amount of additional water resulting from implementing an option, whether there are any major risks or uncertainties that impact on the viability of implementing an option (e.g. adverse site conditions or lack of land availability) and the quality of the source water.
- **Environmental considerations** – we assessed the environmental impact and risk of the option using the results of the SEA, HRA and WFD assessments.
- **Stakeholder acceptability** - whether the option is likely to be contentious or liable to objections based on previous experience and knowledge of the area.

Screening our demand options

4.3.5 Our unconstrained demand management options were also screened, using a qualitative screening methodology for the following criteria:

- Yield uncertainty – how certain we are that an option will help to reduce demand.
- Lead-in time – how long it will take to deliver an option.
- Flexibility – can the option be enlarged in the future, or combined with other schemes if required.
- Security of supply – how robust the scheme is; the likelihood of savings varying over time e.g. ‘bounce back’ from metering.
- Environmental impact – the extent to which the option impacts on the environment.
- Sustainability and promotability – the scheme’s impact on energy use, carbon footprint. If the scheme is socially acceptable and customers approve.
- Suitability – will the option provide the right amount of savings at the right time – seasonality impact.
- Technical difficulty – how difficult an option is to deliver.

4.3.6 A score of 1 to 5 was allocated to each of these criteria with 5 being the worst score and 1 being the best. The maximum worst score available was 40. We took forward options that scored 24 or lower. The only exception to this was the inclusion of non-household schemes to tackle high consumption at airports.

Our feasible options list

4.3.7 The number of options considered for each type at the feasible option stage are presented in Table 15.

Table 15: Number of feasible options in each category

		Feasible Options		
		Option Types	Number of Feasible Options	Number of Options 'Screened-out'
Supply	Surface Water		8	47
	Groundwater		29	81
	Transfers and trading		55	75
	Treatment		6	11
	Effluent reuse		7	2
	Third Party	Included as part of groundwater and transfer options		
	Outage		0	4
	Catchment Management		0	1
	Desalination		14	4
	Effluent Reuse		7	2
Demand	Leakage		11 (plus ALC)	0
	Metering		5	0
	Reuse		4	0
	Water Efficiency		7	0
	Tariff		1	0
TOTAL			147	225

N.B: The total of feasible options and options screened out is seven less than the total unconstrained options in Table 14. This is due to the merging of two groundwater, one effluent reuse, one surface water and two transfer schemes and there is one trading scheme which is yet to be screened.

4.4 Developing our feasible options – Stage 3

Developing our supply side options

4.4.1 For each of our feasible supply options (including third party options) we developed an “option dossier” containing the following information:

- A description of the option, including expected yield and any links or dependencies to other options.
- An estimate of the time needed to investigate and implement the option, including the earliest start date.
- An assessment of the risks and uncertainty associated with the option yield and deliverability.
- Option costs over 80 years, for the cost of construction (capex) and the cost of operating (opex).

- Any other factors or constraints specific to the option.
- 4.4.2 Our options dossiers are presented in Technical Report 4.6. Information on the environmental and social impacts of the options is found in our SEA, HRA and WFD Assessment reports. Following representations on the rdWRMP19, we have expanded Technical Report 4.6. to include details of the costing approach that we used for our options, including the strategic supply side options contained within the next section.
- 4.4.3 We scored how well the options performed against the following criteria to provide a “multi-criteria analysis” for each option:
- Option deliverability – this assessed how easy an option is to deliver on a scale of 1-5, considering risk around obtaining planning permission, construction, technology and other implementation risks.
 - Option yield uncertainty / Cost uncertainty – this assessed how much uncertainty there is regarding how much water will be made available and how certain the costs information is on a scale of 1-5. Between the draft Final submission and Final submission we also slightly amended our Lower Greensand groundwater development strategy to account for the implications of the rejection of our licence application to extend the abstraction at Runleywood. This is described within Sections 4.7 and 6.3 of this Plan.
 - Environmental Impacts – this assessed the environment impact of an option based on our SEA work on a scale of -5 (being negative impact) to +5 (positive impact).

The “multi-criteria analysis” scoring for each option is presented in Technical Report 4.9.

Developing our feasible demand options

- 4.4.4 We ensured that we had equivalent information available for our demand management options and these are presented in Technical Report 4.7.

Impact of climate change on options

- 4.4.5 Our assessed yields for each option took into account the effect of climate change. This is reflected in the assessment of yield uncertainty. We therefore incorporated this into our calculation of target headroom allowance associated with new options. Typically, the full range of uncertainty (i.e. maximum potential climate change risk) was between 5% and 10%, depending on scheme type. The effective impact on yield then depends on the Target Headroom risk profile used for each WRZ. Further information about the impact of climate change on potential yields of our supply options can be found in Technical Report 4.6., which includes the rationale behind the percentage impacts that were assumed.
- 4.4.6 The impact of climate change on potential savings from implementation of demand management options has been assessed as negligible.

4.5 Strategic supply options

- 4.5.1 Our list of feasible supply options includes six “strategic supply options”, capable of providing significant additional water resource in the mid-term. These strategic supply options require significant investment, take time to develop and need us to work collaboratively with other water companies and third parties.
- 4.5.2 Our strategic supply options are illustrated in Figure 26 and are summarised in Table 16. All of the strategic options other than the Thames-Affinity trading option were included within the economic (EBS) modelling described in Section 5 of this report. None of them were “screened out” prior to formal economic analysis carried out in the decision-making stage of the WRMP.

Table 16: Summary of potential strategic schemes for the Central region

Scheme	Development partner	Description and Options Developed
South East Strategic Reservoir (SESR)	Thames Water	This scheme is a relatively simple winter storage and release, where we would reserve the volume required to provide our required yield. We developed costs and updated metrics for three options which are: <ol style="list-style-type: none"> Treating 50MI/d of water at Iver Treating 50MI/d of water at Harefield Treating 100MI/d at Iver
Severn-Thames Transfer	Thames Water	We worked with Thames Water on the feasibility of the option to transfer water from the River Severn to the River Thames. As a result, we developed the following three possible options: <ol style="list-style-type: none"> Treating 50MI/d of water at Iver Treating 50MI/d of water at Harefield Treating 100MI/d at Iver
River Thames trading and transfer	Thames Water, Severn Trent or United Utilities	This is an option for trading and transfer on the River Thames using source water from a new transfer through the Severn-Thames scheme, or a licence trade with Thames Water on the River Thames (offset by, or directly using water from, developments such as effluent re-use by Thames Water). The abstraction and transfer from the River Thames would be the same as described for the Severn Thames transfer and SESR options above.
South Lincolnshire Reservoir	Anglian Water	We have discussed a number of strategic options with Anglian Water. The feasible option is for Anglian Water to build a new reservoir in South Lincolnshire, which would allow us to increase our take from Grafham. Anglian Water would then provide us with a bulk supply. We have considered two schemes (both of these represent a share of the water that might be made available): <ol style="list-style-type: none"> A 100MI/d scheme (share of a 150MI/d total yield). Under this option Anglian Water would transfer water from the River Trent to the River Witham to augment yield.

Scheme	Development partner	Description and Options Developed
		<ul style="list-style-type: none"> b. A 50 MI/d scheme (share of a 75MI/ total yield). Under this option there would be no transfer from the River Trent.
Minworth Effluent Transfer	Severn Trent Water	<p>This feasible option is to take treated waste water from Minworth Waste Water Treatment Works (WWTW), which is operated by Severn Trent Water, and transfer it via pipeline to our supply area and then treat it close to our existing Sundon Treatment Works. We have considered two options.</p> <ul style="list-style-type: none"> a. A 100MI/d scheme b. A 50 MI/d scheme
Grand Union Canal Transfer	Canal & River Trust	<p>We have worked with the Canal & River Trust to update the costs at different levels of yield for a scheme to transfer water from Minworth WWTW and use the canal system to convey the water. The Canal & River Trust have provided updated information for two options.</p> <ul style="list-style-type: none"> a. A 100MI/d scheme b. A 50 MI/d scheme (this option requires significantly less engineering of the canal system itself to allow the transfer of water).

- 4.5.3 One of the key inputs for our economic modelling relates to the cost uncertainties associated with large strategic infrastructure development, and how we have handled those uncertainties in our cost estimates. This is particularly relevant where costs have been provided by third parties.
- 4.5.4 As noted in Technical Report 4.6, the large scale and innovation involved in these schemes means that there is a case for applying ‘optimism bias’ to the cost estimates, as described in the HM Treasury Green Book. This accounts for the fact that costs for these schemes typically rise from initial proposals through to final construction. In our case we did not apply any optimism bias to the components that we costed (e.g. the transfer and treatment element of the River Thames options), as our costing methodology uses full ‘outturn’ costs and was generally applied to elements of the schemes that can be described through unit cost models. However, some of the costs of the core elements of the schemes (e.g. reservoir construction or canal upgrades) that were provided to us by third parties do warrant the inclusion of such costs, and in some cases the third parties had already made allowances.
- 4.5.5 We reviewed these third-party costing methods and, ultimately did not adjust their costs for the reasons outlined in Technical Report 4.6. This does mean that some options such as the SESR, which included specific allowances for optimism bias, may actually prove to be more cost effective in comparison to the other options than we have currently assumed within this fWRMP19, but at this stage we do not think that this has affected the validity of the economic assessment. The investigation and costing of regional strategic options to bring them to a consistent level forms a fundamental part of the collaborative investigation activities and regional modelling proposals described in Chapter 6.

4.6 Impacts of growth and new abstraction on regional water availability.

- 4.6.1 We understand the importance of the regional context when planning our investment. Our economic modelling takes account of the regional context in terms of option availability, and we have considered impacts on the environment in combination between schemes and with other plans (see Section 4.7. below). However, it is likely that our investment strategy will also affect river flows as a result of changes in abstraction and the introduction of new strategic supply schemes, and these changes could affect other water companies in the South East region of England. The relevant ‘conjunctive use’ models do not currently exist to allow us to *quantify* such impacts. Nevertheless, as part of the fWRMP19 we have *qualitatively* considered the logical implications of our proposals on river hydrology to determine if there are any potential impacts on other water companies that need to be considered as part of the options appraisal and decision-making process.
- 4.6.2 The only significant implication that has been identified through discussions with other water companies, regulators and from representations from stakeholders relates to the interactions between our proposals in the Central region and the flows and resources that Thames Water needs to plan for in its London WRZ.
- 4.6.3 Our proposals for investment could affect flows in the Chalk rivers that form tributaries of the River Thames in two ways:
- As our overall demand rises or falls, then we would expect effluent returns to the river via wastewater treatment works, such as Maple Lodge, to increase or decrease proportionally. The amount of customer demand in our area that would be returned to the River Thames upstream of Thames Water’s abstractions varies by WRZ, from very little (in WRZs 5 and 6) to most of the WRZ (e.g. in WRZ 2).
 - As we reduce abstraction from the Chalk streams then the flows in those streams, and hence the downstream River Thames, will tend to increase.
- 4.6.4 The impact from effluent returns is larger and more immediate than the Chalk stream flow changes under low flow conditions. Any changes in demand will have a proportional impact on flows, based on the level of demand at the time (that includes both drought and non-drought periods) and the proportion of customers that discharge their wastewater to treatment works upstream of Thames Water’s London intakes.
- 4.6.5 The response in Chalk stream flow to reduced abstraction is currently being monitored, but to date, in the areas monitored, the response appears greater at times of above average flows, with limited proportional response at low flows. The Chalk hydrogeology in the Chilterns means that, at this stage, it appears that much of the increase in flows from our reductions in abstraction would occur either before drought periods or during the recharge immediately after the drought event. Only a relatively small percentage of the reduction in abstraction is therefore realised as a benefit under low flow conditions.

- 4.6.6 In the shorter term, the balance of impact of our investment strategy on flows at Thames Water’s intakes therefore depends on the balance between the reduction in effluent returns that our demand management options will create, and increases in Chalk stream flows due to sustainability reductions and imports to the region from schemes such as Grafham.
- 4.6.7 In the longer-term there will be some benefit to flows at Thames Water’s intakes when we start to construct our strategic options. However, at this stage it is not clear what form the EA licensing strategy might take in relation to this. For example, the impact that increasing effluent returns might have on water quality may require that additional water is left in the environment.
- 4.6.8 The likely net impact of these potential changes in hydrology depend on the final selection of options identified through our decision-making process, and is therefore detailed in Chapter 6 of this fWRMP19.

4.7 Assessing the environmental impact of options

- 4.7.1 We have used our SEA, HRA and WFD assessments to inform our appraisal of our options.

Strategic Environmental Assessment of options

- 4.7.2 The SEA informed decision-making at two key stages of our appraisal of supply options:
- **Screening of unconstrained supply options** – information from our SEA formed part of our detailed secondary screening assessment of unconstrained options, informing our decision to either reject or progress options to the next stage.
 - **Development of feasible supply options** – a detailed assessment of environmental impacts for each feasible supply option was made in carrying out our SEA.
- 4.7.3 Development of our feasible supply options included scoring each option against each of twelve SEA scores to determine if any positive or negative effects existed prior to mitigation being proposed or indeed implemented. This was used as a basis for scoring the environmental impact of an option as part of our “multi-criteria analysis”.
- 4.7.4 The SEA also considered demand options and concluded that environmental impacts of the demand options are similar for each option and are generally positive because they reduce water use and loss. Any negative impacts were found to be minimal.
- 4.7.5 Further information about our SEA can be found in Section 6.8 below and Technical Reports 4.10 and 4.11.

Habitats Risk Assessment (HRA)

- 4.7.6 We carried out an HRA on each of our feasible options. Our HRA concluded that options relating to SESR would be likely to have a significant effect on the South West London Waterbodies Special Protection Areas (SPAs) and we carried out an appropriate assessment of these along and in combination with schemes in Thames Water’s plan. Our appropriate assessment concluded that with appropriate mitigation these would not have an adverse

effect on the integrity of the site. Further information about how we carried out the HRA can be found in Section 6.8 below and Technical Report 4.12.

Water Framework Directive Assessment

- 4.7.7 Our Water Framework Directive (WFD) assessment considered each of our feasible options. It identified potential issues with two groundwater options: the Lower Greensand developments at SGK/Slough and Iver. These were identified as potentially posing a WFD compliance risk if abstractions start to affect the northwards flow of groundwater, although the locations of these developments in the centre of the basin means that such impacts are highly unlikely. It will only be possible to assess this through a pumping test and monitoring of the impact of pumping on groundwater flows. We would carry out these tests prior to implementation of any these options. We would only abstract a volume of water that was demonstrated not to risk deterioration of WFD status or achievement of good status.
- 4.7.8 We would also implement these options incrementally. GlaxoSmithKline (GSK) and Slough comprises two sub-options that can be implemented on an incremental basis and would form the first stage of development. The next stage of development, at Iver, will require exploratory drilling and initial yield tests, and would take into account the findings of the GSK/Slough investigations. In this way, we will ensure that we only abstract a volume of water that it is demonstrated does not cause a risk of deterioration or failure to achieve good status.
- 4.7.9 Because of the uncertainty associated with the yield of the proposed boreholes and the relative lack of information about environmental risks, we will work closely with the Environment Agency during the development of these schemes.
- 4.7.10 The WFD assessment also identified a potential issue in relation to the Brent Reservoir. There is uncertainty around how much yield could be obtained without affecting the benefits from the river support that is currently effectively provided by the reservoir. We will carry out further assessment of this impact and will ensure that we only abstract a volume of water from the reservoir that is demonstrated not to cause deterioration or to risk not achieving good status.
- 4.7.11 Further information about our overall WFD assessment is provided in Section 6.8 below and Technical Report 4.13.

5 Formulating our Plan

5.1 Introduction

5.1.1 We have identified all the feasible options available to us to increase our supply of water and to decrease demand for water. We now have to decide on the best mix of these options to arrive at our “Best Value Plan” taking into account:

- government policy
- customers’ preferences
- costs and benefits (both monetary and non-monetary)
- impact on the environment
- long-term best value.

We do this using the decision-making process described in this Chapter and in more detail in Technical Report 4.9.

5.1.2 Our decision-making process makes use of three inputs: our baseline supply-demand balance presented in Chapter 3, the results of our customer and stakeholder engagement presented in Chapter 2 and our options appraisal presented in Chapter 4.




Figure 27: WRMP Process

5.1.3 There were two key stages in our decision-making process:

- We identified the best approach to selecting our preferred mix of options by carrying out “problem characterisation” - see section 5.2 below and Technical Report 1.7;
- We developed a decision-making approach that reflects the conclusion of our “problem characterisation” – see sections 5.3 below, for our Central region, and section 5.4 for our East and Southeast regions and Technical Report 4.9.

5.1.4 We describe the results of our decision-making process in section 5.5 for our Central region and in section 5.6 for our East and Southeast region.

5.1.5 The final stage in developing our Plan is to test it to make sure it caters for risks that may arise that have not already been accounted for in our baseline supply and demand balance or in our decision-making process – see section 5.7 below.

- 5.1.6 We have taken into account our SEA, HRA and WFD assessments in our decision-making and Section 5.8 provides a summary of how we have done this.
- 5.1.7 We designed our decision making to be tailored to our specific circumstances while meeting the requirements of the EA's Water Resources Planning Guideline: Interim Update July 2018 and the UKWIR Decision Making Guidance. We have compiled a checklist of how our decision-making process meets the key requirements from this guidance (section 5.9).

5.2 Allowing for the Regional Context

- 5.2.1 The purpose of our WRMP is to ensure that we manage and develop water resources to be able to continue to supply water to customers over the planning period, so the decision-making process described below focuses on identifying the 'best value' plan for us to meet that requirement in our own supply area.
- 5.2.2 We recognise, however, that we are part of the wider South East region of England, which is water stressed and requires investment by other water companies to meet their own requirements. Therefore, although the modelling has been carried out for our own supply area, the derivation of strategic options (as described within Section 4), including the shared costs and benefits to expect from those options, has been done in collaboration with our potential regional partners.
- 5.2.3 As described in Section 4.6 we have also considered the regional environment and needs of other water companies when considering the implications of our proposals. Finally, the adaptive strategy that we formulate in this Chapter and describe in Chapter 6 contains detailed proposals to investigate and develop options collaboratively across the South East and East Anglia within AMP7 (2020 – 2025).

5.3 Selection of the modelling process – Problem Characterisation

- 5.3.1 Problem Characterisation is the industry standard method used for identifying the best approach to decision making based on how big the gap is between supply and demand (the "deficit") and how difficult it will be to address the deficit in the baseline supply-demand and the scale of the deficit. Problem characterisation is set out in full in Technical Report 1.7.
- 5.3.2 The final assessment matrix from this process is replicated below.

Table 17: Problem Characterisation for rdWRMP19

Problem Characterisation		Strategic needs score ("How big is the problem")			
		0-1 (None)	2-3 (Small)	4-5 (Medium)	6 (Large)
Complexity factors score ("How difficult is it to solve")	Low <7		East Southeast		
	Medium 7-11				
	High (11+)				Central

Problem Characterisation – Central region

- 5.3.3 The Problem Characterisation for the Central region falls in the “High” complexity factor score and “Large” Strategic Needs score. The UKWIR Decision Making Methods guidance document indicates that this means a company should consider whether it would be useful to apply an “Extended” or “Complex” approach to decision-making. We decided we needed to adopt an “Extended” or “Complex” approach.
- 5.3.4 The UKWIR Decision Making Methods guidance indicates that where companies decide to make use of an “Extended or “Complex” approach they need to decide between an “aggregated” or “system simulated” approach depending on the nature of their supply system.
- 5.3.5 A “system simulated” approach would involve complex modelling of the supply system and tends to suit supply systems that rely on raw water storage. In contrast, an “aggregated” approach considers the supply-demand balance of water using total deployable output and total demand during each year in the planning period.
- 5.3.6 We concluded that our supply system suited an “aggregated” approach because our supply system does not have raw water storage, and available supply can be well represented by deployable output.
- 5.3.7 Some of the strategic supply solutions would benefit from system simulation to evaluate yield and resilience on a cross company basis. This is a regional level need that will have to be addressed during the next round of regional planning in the first two years of AMP7. We have accounted for this within the adaptive strategy described within Section 6.
- 5.3.8 UKWIR Decision Making Methods guidance sets out a number of “aggregated” approaches. We selected the “Adaptive Pathways Planning” decision-making approach for our Central region. This type of plan “adapts” as new information becomes available. We chose this approach because it is specifically designed to respond to uncertainties over future risks in a structured way. In our case we know we have uncertainties regarding the size of demand reductions that can be delivered by our long-term demand management options and also supply-side risks. We explain our approach to decision-making in the Central region in more detail in sections 5.3-5.6 below.

Problem Characterisation – East and Southeast regions

- 5.3.9 Problem characterisation for our East and Southeast regions concluded that a “Current” approach to decision-making is appropriate and this is explained in further detail in section 5.4 below.

5.4 Our decision-making process for our Central region

Overview of decision-making process

- 5.4.1 An overview of the decision-making process that we used for our Central region (covering stages 6 to 8 of the UKWIR guidance) is provided in Figure 28 below.




Figure 28: Summary of the decision-making process

5.4.2 Our approach involved four steps:

- **Step 0** – Prior to the modelling process we incorporated high level customer and stakeholder feedback to constrain the scope of the modelling carried out in all subsequent steps (see paragraph 5.4.3).
- **Step 1** – we ran a conventional Economic Balancing Supply and Demand (“EBS”) model, which selected a mix of options that would balance supply and demand at the least cost, without allowances for non-monetary considerations or management of future uncertainties (see paragraphs 5.4.4 – 5.4.6).
- **Step 2a and 2b** – we took account of customer and stakeholder preferences (customer and stakeholder analysis or “CSA”) and of our multi-criteria analysis (“MCA”) of options described in paragraph 4.4.2 above (see paragraphs 5.4.7-5.4.9).
- **Step 3** – we developed an adaptive plan by developing “four futures” informed by our CSA and MCA. We then re-ran our EBS model to identify the least-cost mix of options for each of our four futures, which were then tested which were then tested against multi-criteria scoring to check they represented best value for each of the futures. This allowed us to develop adaptive pathways to ensure that the proposed investment is timely and manages future risks through the identification of up front ‘enabling actions’ on the major investment proposals (see paragraphs 5.3.10-5.3.13).

Step 0: Defining the problem constraints

5.4.3 We included the following constraints to all our decision-making modelling analyses on the basis of stakeholder feedback:

- Groundwater options involving new Chalk groundwater abstraction were not allowed for selection under any stage or scenario. A list of the options excluded at this stage is provided in Technical Report 4.5.
- Because we are seeking to improve our drought resilience and stop having to rely on Drought Orders and Permits for droughts that are less severe than a 1 in 200 year event, the models were not able to use Drought Orders and Permits to balance supply and demand from 2024 onwards.
- The full 36.3Ml/d of sustainability reductions contained in the ‘green’ and ‘amber’ WINEP list was included in all of the economic analyses (Step1 least cost, Step 3 adaptive pathways and the sensitivity testing stage).

Step 1: Derivation of the least cost plan

5.4.4 We used the EBS model to generate the plan that comprises a mix of options that is least cost. The inputs to the EBS model include information from our baseline supply-demand balance and options for closing the gap between supply and demand. These options include existing transfers from other water companies and our constrained options derived from our options appraisal process. As we explained at paragraph 3.4.18, we are not currently able to make full use of our transfer from Grafham, and within our EBS model we therefore capped

the average capacity of this transfer to 50Ml/d, until 2023/24 when we expect to complete the new treatment plant.

Step 2a: Taking into account customer and stakeholder preferences

- 5.4.5 In Step 2a we analysed feedback from customers and stakeholders provided in consultations on our dWRMP19 and Business Plan and further customer pre-consultation during preparation of this fWRMP19. The findings of this Customer and Stakeholder Analysis (“CSA”) were used in two ways:
- to modify the selection of schemes in the subsequent Step 3 analysis; and
 - to develop the adaptive pathways futures for the Step 3 analysis.

Step 2b - Multi-Criteria Analysis (“MCA”)

- 5.4.6 In Step 2b we considered our MCA that we carried out as part of our options appraisal (see paragraph 4.4.2) above. This was used to further inform the Step 3 development of the adaptive strategy.

Step 3 – Developing our four futures and adaptive pathways

- 5.4.7 We developed “four futures” that could occur and need to be solved if we are going to be able to plan our supplies resiliently over the next 60 years using our CSA and MCA. We carried out EBSD modelling for each future to determine the lowest cost plan for that future. This identified some options that are needed under all our futures. We tested these economic solutions against our MCA for the options to determine whether or not the economic solution represents ‘best value’, and adjusted the outputs if appropriate.
- 5.4.8 We then examined when key investments and decisions (“tipping points”) need to be made to ensure that we can respond in a timely way under each future. This allowed us to develop our adaptive pathways.
- 5.4.9 We then determined what actions we need to take in AMP7 (2020-2025) to ensure we are able to balance supply and demand under any of our four futures. These are our “enabling actions”.
- 5.4.10 As some of this investment could turn out not to be necessary under one or more of our four futures, we have carried out a review of long-term cost effectiveness. We carried out a “least regrets” analysis. This involved comparing our adaptive plan, including enabling actions against a “wait and see” approach that did not include the relevant enabling actions. It has allowed us to establish whether or not the longer-term benefits of the enabling actions outweigh the shorter-term costs, on an economic, probability weighted basis.

5.5 Our decision-making process for our East and Southeast regions

- 5.5.1 For the East (WRZ7) and Southeast (WRZ8) regions the initial EBSD modelling indicated that very little investment beyond the core demand management programme and a small number of low cost supply side schemes in the Southeast region was required, and that none of the required schemes had a high environmental or social impact. The decision-making modelling did not therefore need to progress beyond Step 2 of the framework in those two regions (i.e. no requirement for formal adaptive pathways analysis).

5.6 Results and key decisions – Central region

Step 1. The Economic Least Cost Plan.

5.6.1 The simple least cost EBSD run selected all of the smaller, more cost-effective supply side options that we have available to us, along with most of the main demand management options before the first strategic option needs to be developed. The key exception to this was the smart metering programme, which was found not to be cost effective in comparison to the strategic options. Under this least cost plan the first strategic option was the SESR scheme in 2035.

Step 2. Customer and Stakeholder Analysis, plus Initial Multi-Criteria Assessment

5.6.2 The CSA drew a number of key conclusions. **Error! Reference source not found.** The Table below sets out each of our findings from CSA and how we have responded to these findings in developing our fWRMP19.

Table 18: The influence of customer and stakeholder feedback on our decision-making process in the Central region

Key findings	Data sources and evidence	Modelling implications for the 'best value' adaptive pathways in Step 3.
Preference for data information to improve awareness, support demand management and leakage reduction	Customer consultation on the dWRMP19 and the customer engagement on the Business Plan, supported by rdWRMP19 pre-consultation customer focus groups.	Rollout of a smart metering programme with an associated fixed network to allow behavioural changes and supply pipe leakage reductions were mandated in all Step 3 investment programmes.
Lack of support for variable tariff options.	rdWRMP19 pre-consultation customer focus groups, plus the rising block tariff trial carried out prior to PR19.	We considered including tariff options, which had been screen out at the options appraisal stage. Given lack of policy and customer support we did not include these.
Preference for strategic schemes that use existing infrastructure	rdWRMP19 pre-consultation customer focus groups.	We have two options that make use of existing infrastructure: the Grand Union Canal Transfer that was described in section 4 above and the Brent Reservoir, which is a reservoir owned by the Canal & River Trust. We have included enabling actions to further develop [both of these options] – see sections 5.5.12 to 5.5.18 below. Brent Reservoir has a yield risk and we have included this risk in our adaptive planning rather than reducing the yield – see section 5.5.
Support for strategic reservoirs	rdWRMP19 pre-consultation customer focus groups.	General support for these options, but no change as strategic reservoirs already performed well on an economic basis.
Requirement to include 'stretching' ambitions of demand management and	Stakeholder consultation (Defra, Ofwat, NIC). rdWRMP19 Customer focus groups (N.B. whilst	The delivery of very low leakage and PCC targets (50% leakage and 110l/h/d PCC @ 2050) was included as an adaptive pathways branch in the analysis – see section 5.5.

Key findings	Data sources and evidence	Modelling implications for the 'best value' adaptive pathways in Step 3.
leakage as part of the analysis. Include consideration of greywater re-use.	customers support the concept, they are not in favour of subsidising devices in new homes)	The option of delivering low PCCs through highly water efficient new homes was included as an option in all analyses, but additional costs from this clearly identified – see section 5.5.
Requirement to consider how we would manage the risk of lower levels of benefits from our demand management and leakage initiatives.	Stakeholder feedback on the dWRMP19 and stakeholder pre-consultation	This risk was included as a core part of our adaptive pathways analysis for the Central region – see section 5.5.
Requirement to consider further reductions in abstraction on Chalk rivers.	Stakeholder consultation	The potential need to meet a greater level of challenge was included in one of the adaptive pathways branches.

5.6.3 The step 2 MCA identified the following key risks, which were also used in developing the adaptive pathways for the Step 3 analysis:

- The large uncertainty ranges of forecast benefits of our two long-term, largest demand management options (concerted action on water efficiency and smart metering fixed networks). These potentially affect both the deliverability and timing of our Plan.
- There are relatively large uncertainties around the potential yields that might be realised from the Lower Greensand developments and Brent reservoir options without compromising achievement of WFD objectives. These uncertainties associated affect the supply/demand balance in the shorter term and hence the timing of the larger strategic developments.

Step 3. Adaptive Pathways Analysis.

Our four futures

5.6.4 Based on the Step 2 findings we identified four potential futures for consideration in our Step 3 adaptive pathways analysis. The choice of four futures represents a pragmatic selection and was designed to allow us to test the full range of supply/demand uncertainty (around 100MI/d) in a reasonably small number of discrete futures. The four futures are described below:

Future 1: Our ‘Challenging’ future. There are two key challenges that we are reasonably likely to face:

1. *Supply side challenges.* These are challenges affecting just over 18 MI/day of the water that we have to supply. There are three elements:
 - Sustainability reductions - Our CSA identified that there may be a need to further reduce abstraction from Chalk catchments (this represents 7 MI/day).
 - Yield risks - Our WFD assessment identified that we may not be able to realise the full yield of our first groundwater option (Slough/GSK) and the Brent Reservoir option without compromising achievement of WFD objectives. We consider 50% of the yield of these options to be at risk (5.3 MI/day). We also recognise that the development potential for the Lower Greensand at Iver is very uncertain until exploratory drilling has been carried out, so we have discounted this option in the ‘challenging future’ (3MI/d, bringing the total yield at risk to 8.3MI/d).
2. *Demand side challenges.* There is a risk that longer term demand management measures will not provide the benefits we have included in our ‘expected’ future. We assessed that the probable risk from this is also in the order of 18MI/d, which equates to PCC of 128 l/h/d.

We have modelled this future as an either/or challenge (i.e. we have not incorporated supply and demand challenges into the pathway), with the supply side challenges representing a marginally higher risk. We accounted for the risk that these might be combined through our final plan target headroom allowance, as detailed in section 5.7.

Future 2: Our ‘Expected’ future. Under this future our longer-term demand management schemes perform as we expect. We achieve a PCC of 124 l/h/d and we reduce leakage by 39% from its 2015 level by 2045. These reductions are consistent with the 2018 National Infrastructure Commission “Preparing for a Drier Future” report. The leakage reduction is the maximum reduction we can deliver without either replacing our mains or finding unknown efficiencies beyond even the optimistic stretch targets we have allowed for in our modelling. There are no supply side challenges.

It also encompasses a range of different “mixed” futures combining elements of our “Challenging future” with elements of our “Optimistic” future. For example, we could achieve higher reductions in leakage in line with our “Optimistic future” (saving up to 20 MI/d) but see the supply-side challenges of our “Challenging future” (reducing supply by 18 MI/d).

Future 3: Our ‘Optimistic’ future. Under this future we do not experience any supply-side challenges, and we are able to outperform to the upper end of our ambition on long term demand management reducing PCC to 119 l/h/d by 2045 and leakage by 50% of its 2015 level by 2045. We also included a ‘stretch’ scenario where we applied 50% leakage reduction after 2020, resulting in an overall 57% reduction from the 2015 value.

Future 4: Our ‘Aspirational’ future. Under this future we do not experience any supply-side challenges, achieve the upper limit of ambition on leakage and we are able to go even further on demand management and reach our ultimate aim of 110l/h/d PCC. We have also considered the stretch 57% leakage under this future.

5.6.5 Under the ‘Challenging future’ the scope of the sustainability reductions was calculated based on the current analysis of licence capacity that may be reduced because it typically has not been used historically and therefore may be removed under the WFD principle of ‘no deterioration’. In this case that means licences may be cut to historic average values to prevent increased abstraction at those sources. This value is 11MI/d across our supply area as a whole, 7MI/d of which is calculated within the Central region.

5.6.6 We have updated our assumptions between the rdWRMP19 and fWRMP19 so that the reduction of abstraction at Friar’s Wash (2.9MI/d) was included in all futures.

Options selected under all our futures

5.6.7 The economic analysis showed that investment needs for all four futures are the same with the exception of:

- One of our longer-term demand management options, which is only selected under our “Aspirational” future; and
- The timing for delivery of the first and second strategic supply options, which is different for each of the futures.

5.6.8 All the futures required all the demand management options to be delivered except one. The key supply options that are required alongside our demand management options are:

- Increase in Anglian Water Grafham bulk supply up to its full 91MI/d capacity (pre climate change impact), which requires construction of a storage reservoir and conditioning plant at Sundon.
- Development of Lower Greensand borehole schemes at GSK/Slough and Iver.
- Brent Reservoir – this is an existing reservoir that is owned by the Canal & River Trust, the option involves modifying its use to provide public water supply.
- Development of inter-zonal transfers – this forms part of our “Supply 2040” programme described in Section 6.3. The timing of the first and second stage of the Egham to Iver transfer (32MI/d in total) is the same under each future, and ensures that all of the potential surplus in WRZ6 can be moved out to where the need is in the other WRZs. Details of the relevant supply/demand balances are provided in Technical Report 4.9. The Arkley North scheme linking WRZ4 to WRZ3 is then constructed as demand requires it, in 2034 for the ‘challenging’ and ‘expected’ futures, but in the 2040s under the higher demand management futures. The Boxted to Chaul End scheme that is required for transfer to WRZ3 beyond that enabled by Arkley North is not required until the second or third strategic supply development is constructed (late 2040s or beyond).
- The small licence trade on the River Thames to support the second stage transfer out of WRZ 6.
- Strategic supply options to deliver additional water in the mid-term. The EBSD modelling selected the SESR option as the preferred strategic option under all futures,

with 100MI/d of total resource being economically viable. It then selected the Grand Union Canal (“GUC”) transfer as the next preferred option.

Tipping points for our four futures

- 5.6.9 The date when we need to deliver strategic supply options varies between the four futures in response to whether supply from other options is less than expected or demand is higher than expected:
- **Challenging future** – the first strategic option is required by summer 2038 and the second strategic option by 2063.
 - **Expected future** – the first strategic option is required by summer 2042 and the second strategic option is required by 2066.
 - **Optimistic future** – the first strategic option is required by summer 2050 and the second strategic option is required by 2073.
 - **Aspirational future** – the first strategic option is required by summer 2059 and the second strategic option is not required within the planning horizon (2080).
- 5.6.10 Both of our strategic options, SESR and GUC, require a 15-year lead time. The GUC option has a 9-year development period, but currently there is no supporting water quality data or environmental investigation data. We have reviewed the timescales involved in these initial investigations as part of our Business Plan development and consider that we will be in a position to confirm the scope and environmental viability of the scheme by 2023 if we commence studies in 2020. The overall lead time for this scheme is therefore 12 years. Under our “Challenging” future we need to be able to confirm the selection of our preferred strategic option in 2023, as we will need to start planning and development of the SESR if this remains ‘best value’. This is our first tipping point, and given the up-front investigation time required for the GUC transfer we consider that we have enough time to investigate this as a potential alternative scheme. At this first tipping point we also need to be able to determine whether we are facing a “Challenging”, “Expected” or “Optimistic” Future (which could become an “Aspirational” Future) in order to confirm the need for strategic development.
- 5.6.11 Although we should have a reasonable understanding of the potential level of additional sustainability reductions, and greater clarity over whether we will be able to realise the full yield of our small supply-side schemes, by the 2023 tipping point, this will not be confirmed until 2025 – this is potentially our second tipping point. This second tipping point is relevant in our “Expected” future. It tells us whether we are continuing in our “Expected” future or are facing a “Challenging” future.
- 5.6.12 Achieving our “Aspirational” future in an affordable way will require policy or legislative support that would allow us to achieve the maximum benefits from our long-term demand management strategy, and ensure that most (or all) new homes incorporate highly efficient water saving devices and some water re-use. Without this policy support the costs of investment for this future are significantly higher (£770m additional total expenditure up to 2050 compared with our ‘optimistic future’) because the lower PCC targets would require that we source and install highly water efficient devices (including greywater re-use systems) into

almost all new developments, without a regulatory requirement on developers to deliver these savings as part of their development.

- 5.6.13 For leakage reduction, we have determined that with stretch efficiency assumptions we can economically achieve 40% reduction between 2015 and 2045, and will look to extend this further to 50% as part of our Plan. Our analysis showed that achieving this additional 10% would be expensive if we have to rely on mains renewals, with a cost in the order of £10m per annum for a 13Ml/d benefit. That is almost twice as expensive on a unit cost basis as our preferred strategic supply developments. As discussed in Chapter 6 we will therefore seek to achieve that 50% target through as yet unidentified efficiencies in active leakage control (ALC) and reduction in customer supply pipe leaks.
- 5.6.14 We will continue to aim to achieve the targets contained within our “Aspirational” future as part of our long-term planning, but recognise that there is a significant risk that this cannot be economically achieved. We expect to know whether our “Aspirational” future can be affordably achieved by the end of AMP8 (2030) – this is our third tipping point. This third tipping point is relevant to our “Optimistic” future and tells us whether we are able to move to an “Aspirational” future.
- 5.6.15 Under our four futures we have quoted leakage targets based on the 2015 to 2045 period, as we are already in the process of delivering our reduction programme 5 years ahead of the National Infrastructure Commission (NIC) ‘Planning for a Drier Future’ horizon of 2050. If we seek to deliver an extended leakage target of 57%, which is equivalent to reducing leakage by 50% post 2020, then we could defer decisions and investment in our “Optimistic” and “Aspirational” futures by between 3 and 4 years beyond the timescales discussed above. However, this would almost certainly require expensive mains renewals as part of the delivery programme, which does not represent good value for customers.
- 5.6.16 A conceptual summary of the adaptive pathways and decision points generated through the above analysis is provided in Figure 29 overleaf.




Figure 29: Conceptual summary of the adaptive pathways analysis

Enabling actions

- 5.6.17 We need to include in our fWRMP19 enabling actions to be started in AMP7 in order to ensure that we are able to meet our 'Challenging' future should it arise.
- 5.6.18 Our analysis shows that for all four futures, the EBSD modelling selects the SESR option as the clearly preferred option for the first strategic supply scheme and the GUC Transfer option as the preferred option for the second strategic supply scheme. These were confirmed as the first and second choice options by the MCA Check. We have focused our enabling activities within our adaptive plan on development of our two preferred options. Based on this stage of analysis we would continue discussions with Anglian Water to develop the South Lincolnshire scheme as part of our enabling activities.
- 5.6.19 We recognise, however, that there are uncertainties around the scope, operation and viability of the preferred schemes and other strategic options. All of these uncertainties will need to be resolved to a satisfactory extent before our 2023 decision point. We therefore reviewed our other potential strategic schemes to determine which schemes warrant investment into substantive investigations prior to 2023, as they could potentially form the preferred strategic option if the investigations demonstrate that they are better value than the SESR. Table 19 summarises this analysis.
- 5.6.20 It should be noted that the selection of the SESR and GUC transfer as first and second choice options in our current 'best value' plan was based on economic modelling and the subsequent MCA checks. The alternative options described below were included as potential options in the economic assessment, but were not selected on economic or MCA grounds. However, we recognise that this could change as a result of AMP7 investigations, so have identified what enabling actions are appropriate for the other options to support our adaptive strategy.

Table 19: Evaluation of preferences and enabling needs for other strategic schemes

Scheme	Preferences	General Enabling Requirements in AMP7
Grand Union Canal Transfer	<p>Second preference for strategic scheme after the SESR, it is chosen as second strategic option in most model runs.</p> <p>It will tend to have an upper economically effective limit in terms of size (between 50MI/d and 75MI/d capacity), so a further option may be required within the 60 year planning horizon if SESR is not available.</p> <p>Although scheme development is only 9 years, considerable water quality and environmental investigation, monitoring, modelling and analysis will be required to try and reduce the delivery risks, scope and costs of treatment prior to that 9 year period.</p>	<p>Include enabling activities to deliver in time for “Challenging” future. Prior to 2023 these will concentrate on the environment, water quality, plus hydraulics and hydrology of the canal to confirm the likely scope and operation of the scheme.</p>
South Lincolnshire Reservoir	<p>Although this scheme is currently relatively expensive, it does provide potential support in the longer term after the GUC scheme, and there may be opportunities for scope and engineering adjustments to reduce the costs.</p>	<p>Work with Anglian Water to determine if there are any options for reducing the overall costs of the scheme.</p>
River Thames to Affinity Transfer scheme	<p>As noted previously, it will be prudent to investigate the abstraction, transfer and treatment elements of the abstraction from the River Thames separately to the SESR, as it may be possible to use alternative sources to SESR (licence trading through the Severn Thames Transfer or based on Thames Water’s development of other schemes such as effluent re-use) as the raw water supply for the scheme.</p>	<p>Include enabling investigations to deliver in time for “Challenging” future, with or without the SESR.</p>
Minworth effluent re-use	<p>Not preferred. Although the larger scheme did appear as a potentially economic second scheme under some of the analysis runs, we consider that there is a greater potential for cost engineering on the GUC transfer, and customers significantly preferred the GUC transfer in comparison. We would only pursue this option if costs or delivery risks on the GUC transfer or South Lincolnshire reservoir escalated beyond our current expectations.</p>	<p>No enabling actions.</p>
Severn Thames Transfer	<p>One of the key reasons why this scheme is not selected as an economic option for us is because we do not have the raw water storage that is needed to manage variability in transfer availability, and would therefore need to utilise Thames Water’s existing London reservoirs storage to develop the scheme by ourselves. This would be a highly complex arrangement given the different nature of our systems and timing of drought risk, which results in high operational costs due to the amount of pumping associated with the operational arrangement.</p> <p>However, if the scheme was developed by other water companies (Thames Water, Severn Trent and United Utilities) then we will be able to evaluate the option of purchasing fixed volumes from Severn Trent or United Utilities to release to us – i.e. it may be a viable ‘water trading’ option that could replace the development of our own raw water sources.</p>	<p>This scheme will be investigated by the Thames Water, Severn Trent and United Utilities joint water company working group along a similar timeline to the SESR.</p> <p>Maintain close liaison with this joint working group to determine the cost of trading options once their initial AMP7 investigations are complete, to ensure we are able to use the scheme for water trading if it proves to be one of the ‘best value’ regional strategic options.</p>
Desalination	<p>Excessively costly to develop and transfer across to the Central region and not preferred by customers, therefore not considered as potential option.</p>	<p>No enabling actions.</p>

- 5.6.21 We have therefore included enabling actions in our fWRMP19 to develop our preferred ‘backup’ scheme to the SESR, the GUC transfer, and our third preferred scheme, the South Lincolnshire Reservoir. We will also separately develop the River Thames to Affinity transfer element of the SESR option, and continue to liaise with Thames Water, Severn Trent Water and United Utilities via working groups to determine if large scale water trading can offer a ‘best value’ alternative to the SESR development.
- 5.6.22 Importantly, the enabling activities for the GUC and South Lincolnshire Reservoir will ensure that our understanding of the scope, requirements and risks associated with this scheme will be at the same level as the SESR option when final decisions are made about the progression of development after the AMP7 2023 decision point. The Severn -Thames Transfer working group will carry out its investigations on the same timescale to allow trading to be developed in time for our ‘Challenging’ future if that proves to be a ‘best value’ solution.
- 5.6.23 Demand-side enabling activities relating to lobbying and industry wide collaboration are required in AMP7 to aim for the ‘Aspirational’ future, but these are contained within our ‘concerted action on water efficiency’ initiative, which is selected within all futures. The “Aspirational” future does not therefore require any future specific enabling activities until AMP8 (2025 to 2030), when the ‘water efficient new homes’ initiative would need to be commercially designed for implementation in AMP9 (2030 to 2035).

Review of long-term cost effectiveness

- 5.6.24 We wanted to make sure that our fWRMP19 is best value for customers. It is a requirement of the WRMP Guidelines that we carry out a cost benefit analysis to consider whether the benefits of implementing the solution are greater than the costs.
- 5.6.25 We therefore carried out a “least regrets” economic analysis to compare two costs:
- The ‘opportunity cost’ associated with the enabling actions that are required to allow us to pursue an “adaptive strategy”. The enabling requirements associated with the strategic schemes have been further developed as part of our evidence provided to Ofwat following their Initial Assessment of Plans in February 2019. This includes more detail on timetable and costs compared to our rdWRMP19. We have also considered the implications of these costs in comparison to the ‘wait and see’ approach and it is clear that it is only the pre summer 2023 activities that potentially represent an opportunity cost to maintain our adaptive approach. Based on the updated studies we have calculated that the total likely cost of these activities (equivalent to those required to reach ‘Gate 2’ in the Ofwat submission) is around £23m; and
 - the cost of having to rapidly develop more expensive, but shorter lead-time strategic schemes and/or more expensive demand management options because we do not carry out the shorter term enabling activities – the “wait and see approach”.
- 5.6.26 If our “Challenging” future arises then our adaptive approach means that we will have carried out the enabling activities that are required to deliver the required strategic option in time for the need. However, under our “Expected” or “Optimistic” Futures we will have modestly accelerated investment beyond the economic optimum. In our “Aspirational” Future, we

would not need to start work on the strategic option until the mid-2040s, and there is a chance it would not be required at all.

- 5.6.27 This means that if we were to adopt a “wait and see” approach we might delay or avoid incurring the cost of the enabling activities, but there is a risk that we incur significantly greater cost if our “Challenging” or “Expected” futures are realised and we have to deliver more expensive options in short timescales.
- 5.6.28 We compared these two costs under a range of planning horizons and probability weightings for each future. This analysis showed that even under a shorter term (2050) planning horizon where we assume that the “Optimistic” or “Aspirational” Futures are three times as likely to occur as the “Challenging” or “Expected” futures, there is still almost a 3:1 benefit to cost ratio of pursuing an adaptive approach over the “wait and see” approach.
- 5.6.29 We are therefore confident that the enabling actions we have included within our adaptive plan represent an appropriate balance between long term resilience and value for customers.

Monitoring

- 5.6.30 An important part of an adaptive plan is the development of the associated monitoring framework, which allows us to make the relevant decisions on future actions. That framework needs to be geared towards the key ‘tipping points’ and associated decisions identified through the adaptive pathways analysis. We describe our monitoring framework in further detail in Section 6.4.

Conclusion

- 5.6.31 Overall this means that our fWRMP19 includes both enabling actions for delivery of our preferred strategic option in 2038 and also monitoring that allows us to determine whether we are able to defer construction of these strategic options. Our proposed investments, including enabling activities and monitoring framework, are described in Chapter 6.

5.7 Results and key decisions – East and Southeast regions.

- 5.7.1 For the East region, there is no significant investment need under the current WINEP and associated sustainability reductions. The existing resources provide a surplus of circa 7MI/d to 2024/25, which increases to circa 9MI/d once the Ardleigh agreement reverts back to a 50/50 share with Anglian Water, and the 2.6MI/d sustainability reduction scheme comes into force.
- 5.7.2 There is a potential for a further 2MI/d sustainability reduction in AMP7, and Anglian Water has indicated to us that it may need a temporary agreement for a small transfer, but only for a short time during the start of the period. We still therefore have sufficient headroom within AMP7 to allow us to share resources with Anglian Water and meet the potential sustainability reduction prior to the return to a 50:50 sharing agreement in 2025/26. There is therefore no requirement for significant investment within the WRZ.
- 5.7.3 There is a risk that up to 15 to 20 MI/d of additional sustainability reductions could be applied to this WRZ (see Technical Report 1.4). The size of this risk means that we could only address this requirement through the construction of a desalination plant within the WRZ, as we could not deploy enough demand management to address this size of impact, nor do we have any

other supply side options of sufficient size. We have not included this as an investment proposal within our WRMP Table information, but we have therefore considered the desalination plant as part of the SEA. If a smaller level of reduction is required then it may be possible to seek regional transfer solutions, which we could explore once the size of the challenge is known.

5.8 Testing the Plan

5.8.1 We have tested our fWRMP19 in two ways:

- we have considered risks not included in the futures and the adaptive pathways, including the risk of experiencing combined supply and demand challenges; and
- we have carried out sensitivity testing of those risks to identify any changes that we may need to apply to our adaptive strategy.

Risks from combined ‘challenging’ futures

5.8.2 It is standard WRMP modelling practice to review the Target Headroom allowance in an iterative way once the final choice of demand-side and supply-side options has been identified. A Target Headroom allowance above and beyond the ‘baseline’ allowance described in section 3.5 is then added to reflect the uncertainties in the yields and benefits of the investment options themselves.

5.8.3 Our Adaptive Pathways already accounted for some of this risk in our ‘Challenging’ future, but it is acknowledged that this only allows for either supply-side or demand-side option benefit uncertainties. As described within Technical Report 4.9, we therefore halved the fWRMP19 Target Headroom allowance (resulting in a value of just under 5MI/d). We consider that the inclusion of this allowance is sufficient to address the combined risk that both futures might occur together, and is in line with standard practice used in WRMPs to manage risk and probability.

Other risks not included in the Central region Adaptive Pathways Analysis

5.8.4 There are potential emerging challenges that we have not accounted for in either the adaptive pathways analysis or the Target Headroom allowance. These are associated with the proposed CaMkOx development corridor, the potential for high growth rates in London as contained in the draft GLA development plans, and the possible need to move to an even higher level of resilience (e.g. 1 in 500 years) within future WRMPs. Following representations on our rdWRMP19 we have also considered the implications of reducing our abstractions from Chalk catchments beyond those levels identified for our ‘challenging’ future.

5.8.5 All of the above risks were analysed through sensitivity testing, as described below.

5.8.6 As noted in Section 3.4, there is also a risk from bromate contamination at our Essendon source. The magnitude of impact is relatively small (loss of 4MI/d), and currently we consider that we have sufficient indication that the EA and polluter will take action to prevent the risk from materialising.

Sensitivity testing

- 5.8.7 The adaptive pathways analysis that we used in our Decision-Making Process is, in itself, a highly structured form of sensitivity testing, and therefore incorporates many of the sensitivities around demand management and the more likely supply-side risks that we might face.
- 5.8.8 Our sensitivity testing of our fWRMP19 has therefore focused on the other risks identified above. These are:
- Environmental impacts – we considered what happens if we exclude options with the most environmental impact in the absence of mitigation as part of the scheme design and construction.
 - Drought resilience – we considered the implications of increasing drought resilience to a 1 in 500 year return period level.
 - High growth – we considered the implications of the potential growth figures published by the GLA in their draft development plan.
 - Further reductions in Chalk abstraction - we considered the implications of further reducing our Chalk abstractions beyond the ‘no deterioration’ values (see para 5.6.5) contained in the ‘challenging future’. We did this by testing a scenario that includes 40MI/d additional reductions in Chalk abstractions beyond our current AMP7 proposals (36.3MI/d). The rationale for this 40MI/d ‘stretch’ scenario is provided in Technical Report 1.4 (Sustainability Reductions). Throughout AMP7 we will maintain our commitment to understanding the needs of Chalk catchments, and will continue to liaise with the Environment Agency to understand and test the potential scope for future reductions as part of the WRMP24 submission.

Scenario 1: Environmental impacts

- 5.8.9 We assessed the sensitivity of our fWRMP19 to environmental impacts by removing any options scoring -2 or -3 in the MCA analysis in the absence of mitigation measures (see paragraph 4.4.2) and re-running our “Expected Future” (other futures were not analysed as the selection of supply side schemes are the same, it is the timing that changes).
- 5.8.10 We found that most of our options scored “-2” or “-3” in the absence of mitigation. Without mitigation, the choice of supply side options was therefore limited. Only the Minworth pipe transfer did not attract a score of ‘-2’ under any of the SEA categories. The 100MI/d version of that option was therefore selected alongside very high levels of leakage reduction and demand management. Under this run the total cost to 2050 was over £500m more than our best value investment under our ‘Expected’ future, and some £1,240m by 2080.

Scenario 2: Increased drought resilience

- 5.8.11 If a move to a 1 in 500 year level of drought resilience is incorporated from AMP8 onwards, then this would result in a fall in DO of 9.6MI/d ADO, 17MI/d PDO. The impact of this on the best value plan, is therefore limited, and would involve bringing forward our first strategic option by 2 years.

Scenario 3: High growth

- 5.8.12 The GLA draft development plan growth assumptions are far more significant, as they involve an increase of 127,000 new properties by 2045 in comparison to the baseline forecast. That equals a demand increase in the order of 38MI/d.
- 5.8.13 Within this analysis we ensured that there was no double counting of the population growth risk that was already incorporated into our Target Headroom allowance.
- 5.8.14 For the high growth scenario, we will need our first strategic scheme much earlier than in our adaptive futures. If we are only able to achieve the 'expected future' demand management, we would potentially need to adopt an alternative strategy, whereby we will continue to rely on some of the less environmentally damaging Drought Permits and then accelerate our supply side investment to deliver as soon as possible. That would mean delivery of our shorter lead time option, the GUC transfer, by 2032, and reliance on up to 12MI/d of Drought Orders and Permits beyond 2025, until the first strategic scheme is delivered. Under that plan, the second strategic option, the SESR would be required in 2042. The South Lincolnshire reservoir would then be required in 2060 as a third stage of development. Under this scenario the South Lincolnshire reservoir would also have to act as the primary backup if either of the two preferred options cannot be developed.
- 5.8.15 Even if we are able to deliver our 'optimistic future' levels of demand management, without supply side risks, the first strategic option is required in 2041 under the high growth scenario. In that case the timing is therefore included within the range of uncertainty covered by the main adaptive pathways analysis, so we could keep to that plan and avoid the need to continue reliance on Drought Permits.
- 5.8.16 The overall impact on investment up to 2050 from the high growth scenario is between £630m and £540m, depending on whether we achieve the 'expected' or 'optimistic' levels of demand management.

Scenario 4: Further Reductions in Abstraction from the Chalk

- 5.8.17 The investment required under the high future sustainability reductions scenario is almost similar to the high growth runs outlined above, although the supply/demand balance pressure is less, so under 'expected' future demand management the second stage strategic option (SESR) is not required until 2044. Costs up to 2050 are therefore circa £444m higher than the 'expected future' without additional sustainability reductions beyond AMP7. Effectively that means that we estimate that it would cost £444m by 2050 to deliver the additional 40MI/d of sustainability reductions contained in that scenario.
- 5.8.18 It should be noted that this cost excludes intra-zonal transfer needs that arise as a result of reducing abstraction, which typically adds around £1m to £2m per MI/d. Total costs would therefore be in the order of £500m to deliver this scenario. Reliance on Drought orders and Permits is required post 2025, but is more limited than the GLA run, with only 6MI/d being required between 2025 and 2028. The first stage of strategic resource development is still required as soon as it is available, so the GUC transfer is selected as this has the shortest lead time of the economically viable options.

Implications and adjustments to the Plan

- 5.8.19 The run carried out to exclude options that require mitigation according to the SEA demonstrated that such an approach would be prohibitively expensive for customers. Our preferred approach is therefore to continue with the adaptive plan, and mitigate the risks through constraining yield on the two Greensand borehole plus the Brent reservoir schemes, and providing mitigation on the development of the SESR as appropriate. This is reflected in our “Challenging” future.
- 5.8.20 Based on the sensitivity testing we determined that the only change that was warranted to the Plan is the inclusion of a further potential adaptation at the 2023 key decision point, whereby the risk of high growth or extended reductions in abstraction from Chalk catchments is evaluated. If at that point it is clear that we may need to accelerate supply side development beyond our ‘challenging future’ to avoid having to rely on Drought Permits for longer than is necessary, we will consult with customers over any significant costs associated with that acceleration as part of the WRMP24 process.
- 5.8.21 The high growth and extended sustainability reduction scenarios indicate that we may require both of our preferred options in the short to medium term, and that a third option, the South Lincolnshire reservoir, would be required within the planning period under this scenario. This third option would also be required as an alternative if either of the preferred options were not viable, or investigations altered the economics and MCA for the options. We have therefore enhanced the enabling actions for this option in our adaptive plan. The costs for this are included with the £23m described in Section 5.6.24, so still represent value for money to customers in the long-term.

5.9 Incorporating environmental considerations into our decision-making process

- 5.9.1 Our SEA, HRA and WFD Assessment were used to inform the decision-making process in three key ways:
- The SEA and WFD findings on feasible options were incorporated into Stage 2 of the decision-making process and resulted in the identified risks to yield for the Lower Greensand and Brent Reservoir options being included in our “Challenging” future. As described, in section 4.8, we will carry out further assessment of these options prior to implementation and will adopt an incremental approach to implementation. We will only implement these options to the extent that we can demonstrate that there is no risk of deterioration in status or risk that the option will prevent good status from being achieved. The “Challenging” future sets out what we will do if further assessment is unable to rule out WFD risks; our first strategic option will be implemented by 2038. – see section 5.5 above.
 - We carried out an SEA, HRA and WFD of our best value programme of options for each of the adaptive pathways included in our fWRMP19 for the Central region and of our best value plan for the East and Southeast regions – see section 6.8 below.

- We considered the economic cost implications of an alternative plan that did not require any mitigation activities (i.e. no scores of -2 or -3 on any of the SEA categories) was also tested, as presented within section 5.7 above.

5.10 Checking compliance with technical guidance

5.10.1 The Water Resources Planning Guidance (WRPG) issued by the EA (Water Resources Planning Guideline: Interim update, Environment Agency, July 2018) provides a general description on how water companies should develop a WRMP, but in terms of decision-making, makes specific reference to a report produced by UKWIR (WRMP 2019 Methods – Decision Making Process: Guidance, UKWIR, 2016). These two documents between them therefore describe the overall approach and specific tools which a water company should use.

5.10.2 Figure 30 summarises how we have complied with the relevant requirements of those two guidance documents, whilst at the same time creating a flexible plan that balances ambition with the need to maintain resilience for customers and principles of long term cost

WHAT THE GUIDANCE REQUIRES	HOW WE DID THIS
<i>It is recommended that the ‘conventional’ Economics of Balancing Supply and Demand (EBSD) is used as at least a baseline reference for the chosen decision-making process</i>	We included simple EBSD least cost modelling as our first step in our decision-making process
<i>If you face a future with a wide range of uncertainties, other methods may provide better overall solutions. The UKWIR Decision Making Process Guidance provides the relevant framework and tools for this</i>	We developed our process in line with the framework and used the methods outlined in that report
<i>Your decision-making process should be clear and transparent... whichever decision-making method you choose, the final options set should be justified economically, socially and environmentally</i>	Our final process relied fully on standard economic modelling (EBSD), within an adaptive pathways framework that was transparently informed by customer, stakeholder and non-monetary considerations
<i>You should consider the ability of the solution to cover a range of possible futures and provide resilience</i>	Our process was specifically developed to identify, solve and generate a plan that could cope with multiple uncertain futures
<i>You should consider whether future changes may make the solution redundant ... solutions that are not intended to resolve a deficit should still be cost beneficial</i>	We used adaptive pathway modelling methods and monitoring that are designed to ensure there are no stranded assets. Where we identified up-front enabling actions we subjected these costs to <i>formal</i> ‘least regrets’ economic analysis

Figure 30: Summary of our compliance with the Planning Guidance

6 Our best value Plan

6.1 Introduction

6.1.1 This section presents our best value Plan for each of our supply regions and the resulting final supply-demand balance as a result of implementing our Plan. The WRMP process is illustrated in Figure 31.



Figure 31: WRMP process

6.1.2 Our best value Plan for the Central region is an adaptive Plan delivering a “twin-track approach” that combines ambitious demand management activities with the appropriate and timely development of supply-side schemes in order to address the supply-demand deficit that we face. It comprises:

- Our demand management strategy (see Section 6.2).
- Our water supply strategy for the Central region based on our ‘Expected’ and ‘Challenging’ future (see Section 6.3).
- Our adaptive strategy setting out how we will implement our demand and supply strategies in our four different futures, identifying key decisions (or tipping points), setting out enabling actions and establishing a monitoring plan (see Section 6.4).

6.1.3 Our best value Plan for our Southeast region is more straightforward and comprises:

- Our demand management strategy (see Section 6.2).
- Supply options (see Section 6.5).

6.1.4 Our best value Plan for our East region is also more straightforward and comprises:

- Our demand management strategy (see Section 6.2).
- Supply options (see Section 6.6).

6.1.5 As noted previously in Section 5, all of the figures quoted for per capita consumptions (PCC) are in ‘normal year annual average’ (NYAA) figures. This has been done in order to be consistent with the Performance Commitment targets that we have set within our PR19 Business Plan. For leakage reduction targets, except where noted otherwise, we quote the percentage saving between 2015 and 2045, rather than 2020 through to 2050 as used by the NIC in their ‘Preparing for a Drier Future’ report, and by other water companies. The reason for this is that we started our leakage reduction programme 5 years earlier than most of the

rest of the industry, having already committed to a 14% reduction in leakage over the AMP5 period (2015 to 2020), so our period for meeting the NIC recommendations is 5 years earlier than the rest of the industry. However, we also support the ambition for a 50% reduction post 2020, so have incorporated that target into our aspirations, meaning that we will aim for a 57% reduction overall from 2015 to 2050.

6.1.6 We have carried out SEA, HRA and a WFD Assessment of our fWRMP19 and we summarise these in section 6.7. We provide a summary of the costs of our fWRMP19 in section 6.8. Finally, we present our final forecasts of supply and demand showing how our fWRMP19 affects our supply-demand balance in section 6.9 and show our levels of service for drought that we will achieve in section 6.10. We explain how our fWRMP19 aligns with the WRMPs of our neighbouring companies in section 6.11.

6.2 Our demand management strategy

6.2.1 Our demand management strategy is the same across all our regions and is therefore described for the Company as a whole within this section. The WRMP tables that are produced alongside this Plan are based on our “Optimistic” future. This section describes the activities contained within our demand management strategy and sets out how they will evolve over time. It sets out strategies for:

- reducing PCC of household customers;
- reducing non-household demand; and
- reducing leakage.

Reducing Household Consumption (PCC)

6.2.2 We will reduce PCC to 129 l/h/d by 2024/5 through continuation of our existing WSP and employing new demand management options. We have ‘front-end loaded’ our demand management strategy towards AMP7. This rate of reduction in demand is not sustainable in the longer term, as much of the saving is associated with the WSP, which will be largely complete by 2024/25. However, we have included options around household water efficiency audits and fast logging of customers in AMP7, which we intend to use to gain valuable insight into the behaviour of customers. By ‘front-end loading’ our initiatives we therefore hope to maximise the benefits from the longer-term strategies that are contained in our Plan. Our overall plan for achieving the 129l/h/d figure is summarised in Figure 32 below.




Figure 32: Makeup of Savings to Achieve the 129l/h/d NYAA PCC Target by 2025.

6.2.3 Beyond AMP7 we have identified and included further initiatives that are intended to achieve further savings in PCC. The components and timing of all the elements that make up our demand management strategy are described below.

Water Saving Programme (“WSP”)

We will continue to deliver our existing WSP (comprising meter installation and charging by reference to volume, customer supply pipe leakage reduction and water efficiency activities) in our Central region.

6.2.4 We anticipate 80% meter penetration by 2025 and 90% meter penetration by 2045. This represents a slightly lower target than at the draft WRMP (where the 90% was targeted for 2025), as a result of the higher than anticipated need to install internal meters, and difficulties metering some of those properties. Since our WSP commenced in 2015, we have installed over 150,000 meters and improved our understanding of some of the challenges of our universal metering programme in our Central region and the practicalities involved with installing meters in properties. We have also reviewed the learning from Southern Water’s metering programme (unable to achieve the metering coverage set out originally) and Thames Water’s challenges in London estimating circa 30% of properties in London are currently not possible to meter with current technology.

6.2.5 Currently, we encounter around a third of properties where an external meter installation is not possible. Two thirds of those properties that can only be metered through internal installations are found to be non-practicable due to plumbing or access issues. The resulting profile (80% by 2025 and 90% by 2045) still allows us to achieve the Normal Year Annual Average (NYAA) PR19 Business Plan performance commitment of 129l/h/d by the end of AMP. Although 90% penetration is not reached until 2045, the profile means that 88% is achieved before our earliest delivery date for strategic supply side options (2038). All but 3MI/d of the potential WSP savings are therefore in place by this point, so there is no significant impact on the timing of our main supply side developments.

- 6.2.6 The savings from the metering element of our core WSP are currently estimated to deliver an 18% reduction in demand for each customer that is metered, along with further savings on demand as a result of our associated communication during their customer journey. These savings are towards the upper end of ranges typically quoted by water companies, but are supported by our initial evaluation of the programme to date. This includes our Home Water Efficiency Checks (HWECS) which we are seeing an average saving between 20 to 30 litres (4% or 5%) per household through water saving advice to encourage behaviour change and fitting free water saving devices in customers' homes.
- 6.2.7 We will continue to closely monitor the saving of our water saving programme and enhanced water efficiency initiatives as we increase meter coverage and time span of data we will be able to learn more about customer behaviours around water usage and able to share progress with our stakeholders and customers more frequently.
- 6.2.8 We expect our PCC to reduce to around 136 l/h/d by 2025 through our WSP alone. These anticipated reductions are reflected in our baseline demand forecast – see section 3.2. Our WSP is an inherent part of our strategy, but was not modelled or separately costed.

New demand management options

- 6.2.9 We have a range of schemes that are designed to provide further demand reduction. During both the draft and revised draft WRMP19 consultation, the vast majority of customers (89%) indicated that they could make no or only 'small' changes to their consumption. Based on this, and from information gather during our rdWRMP19 pre-consultation focus groups, which highlighted the need for specific information and practical support on water saving, we intend to:
1. Provide better information on their own water use and how they compare with other similar households (i.e. not just through general information campaigns). Identification of leaks and plumbing losses is an important part of this.
 2. Provide them with water saving devices that will allow them to use less water.
- 6.2.10 Our water saving strategy is structured to support this approach over the next 25 years. This is broken down into a number of tranches of development, as described below. This explains the level of savings that are anticipated, and separates the savings into the separate initiatives, to demonstrate there is no 'double counting' of benefits.

AMP7 (2020-2025): Pilot Studies and Information Based Approaches

- 6.2.11 Within AMP7 we have included some smaller schemes that save relatively little water (less than 1Ml/d each), but provide us with good case studies and understanding of what might be possible through community-based schemes. These are:
- Our community water efficiency programme. Following review and stakeholder feedback during consultation we have revised the approach for this option and will look at a broad range of community-based initiatives. This will include funding to review the options and opportunities associated with water efficient new developments, which will provide information to our 'concerted action on water efficiency' campaign (see below), as well as the initiatives that are intended to save

water within AMP7 based on engagement at the community level (through local authorities and Non-Government Organisations (NGOs) to promote community understanding of consumption and the implications of high water use in selected higher use communities. Initiatives such as the 'Affinity Water champions' approach, where Affinity Water employees are empowered to act as champions for low water use in their communities, will also be trialled through this programme.

- Our housing associations targeted programme. This option involves company liaison with housing associations to promote water efficiency to residents. An initial assessment and advice visit, or communication is followed up with regular communications as new water saving techniques and devices enter the market.

6.2.12 The larger benefits within this part of the strategy (9.3Ml/d by the end of AMP7, if both behavioural change and customer side leakage are considered) are planned to derive from our 'street level PHC¹⁰' initiative, which incorporates the use of data from both our household metering and 'fast -logging' programmes (fast logging in this case relates to the rapid analysis and turnaround of logging data that we collect from our distribution network). This represents a pre-cursor to the rollout of smart metering (see below). The intention is that we will create the information database and customer feedback infrastructure required to collate, understand and feed-back relevant information gained about individual customer demand from the Automatic Meter Reading (AMR) meter reads. We will combine this with our distribution network information systems, primarily District Metered Area (DMA) loggers, to evaluate how demand fluctuates on a day to day basis within sub-communities to allow comparisons when we are sending out information. Savings will come from both this tailored feedback, and enhanced identification of likely customer side leakage and plumbing losses.

6.2.13 This option covers the associated rollout of repairs to address plumbing losses, including 'leaky loos' type initiatives that are being implemented by other water companies. The key separation between this and the 'concerted action on water efficiency' is that this scheme targets high usage, which is addressed through repair of plumbing losses (including 'leaky loos'), and behavioural change (e.g. reducing sprinkler or other external use). The 'concerted action' initiative focuses on reduction in water usage associated with regular use, through the adoption of water saving devices and 'every day' behavioural changes.

AMP7 to AMP10 (2020 through to 2040): Improving Water Efficiency in Household Devices

6.2.14 This programme starts with an initial learning exercise that we have titled 'comprehensive household visits and water audits'. This consists of follow up visits (after the HWEC contained in the WSP programme) to those customers that exhibit high usage (in the top 5%) to understand the drivers of high demand and provide tailored solutions comprising of additional, simple water saving devices (e.g. tap inserts, cistern devices and shower heads), plus identification and repair of plumbing. The number of households involved mean that savings from the programme are relatively small (up to 2Ml/d), but the key feature of this programme is the learning that we will gain on where and why high usage is occurring.

6.2.15 Our main programme, referred to as 'concerted action on water efficiency' is then started within AMP7 and continues through to the 2040 time horizon. This commences with a full rollout of follow up HWEC visits to generate wider scale water efficiency and enhance our

¹⁰ PHC – per household consumption

understanding of how efficiency can be achieved across a wider range of households. We recognise that this approach is relatively expensive and will operate on a law of diminishing returns, so in the longer term the programme seeks to replace that type of activity with influencing type initiatives that are largely outside of our direct control, but that could potentially significantly reduce demand in the longer term. We have recently launched our ‘manifesto’ of water efficiency and have already started public events (such as our #whynotwater campaign), which seeks to gain public and NGO support for initiatives such as Water Efficient Labelling Schemes (WELs) and hence influence local authorities and national bodies to support initiatives that will inherently improve the efficiency of water using devices.

6.2.16 Potential activities include:

- Supporting and influencing suppliers to generate further reductions to WC flush volumes for new WC cistern purchases and installations (possibly as low as 4 litres per flush).
- Encouraging further innovation, market transformation and point of sale control for other water using devices in the home; such as automatic dishwashers, washing machines, low water use showers, recycling showers and low flow taps. This would be most effective through a national government sponsored approach, but we will explore other avenues with manufacturers, local authorities and NGOs if this is not possible.
- Encouraging wide spread behaviour change of water-using habits and practice through the campaigns used to generate public support for the initiatives described above.
- Promoting the of voluntary building controls to deliver water efficient new homes, and supporting water-efficient or water-neutral developments through liaison with local planning authorities and developers.

6.2.17 The challenge in delivering these types of water savings is that a wide range of stakeholders need to be engaged who can craft, own and run an integrated programme of education, multidisciplinary research, outreach and delivery. This means that government departments (e.g. Defra, Centre for Local Government (CLG)), regulators (EA and Ofwat), Water Regulations Advisory Scheme (WRAS), local authorities, consumer groups, researchers and developers, entrepreneurs, educators, schools, the supply and delivery chains and customers all need to be engaged, in an integrated and coordinated manner. This will not happen on its own, and therefore the thrust of the option is for us to take a community lead, and to manage action plans, goals and deliverables for stakeholders, which we have already started on.

6.2.18 We have estimated the level of demand savings that could be delivered by concerted action on water efficiency on two bases:

- The level of savings achieved if we gain the co-ordinated support and policy backing (including water using product codes where relevant) and there is full and positive engagement from customers. We estimate this to be 64 MI/d by 2045, equivalent to 16 l/h/d, which is based on a conservative assessment of the level of savings that were achieved through the WELs strategy in Australia; and
- The level of savings without such policy support considering only the more reliable elements of the strategy (white goods labelling, behavioural change initiatives involving media campaigns and educational institution support). We estimate this to be 32 MI/d by 2045, equivalent to 8 l/h/d.

6.2.19 Table 20 presents the expected savings in the amount of water used for different purposes (“micro-components”) to the end of AMP7 as a result of our WSP and other new demand options and longer-term as a result of the Concerted Action Project. This does not take account of behavioural change as a result of smart metering. It is consistent with our estimate above in predicting a long-term expected reduction from concerted action of 8l/h/d.

Table 20: Comparative Estimate of Expectations from our ‘Concerted Action on Water Efficiency’ Programme.

Micro-component	Detailed reductions anticipated to End AMP7 – completion of WSP and new demand options other than concerted action		Long term <i>expected</i> reductions anticipated from concerted action	
	Percentage reduction from baseline	Resulting effect (l/h/d)	Percentage reduction	Resulting effect (l/h/d)
Bathing /showering	5%	-2.4	3%	-1.3
Flushing toilets	20%	-6.0	10%	-3.0
Cooking and drinking	7%	-1.2	0%	0.0
Washing hands	4%	-0.6	0%	0.0
Washing dishes	22%	-3.0	11%	-1.5
Washing clothes	20%	-2.4	10%	-1.2
Gardening	13%	-1.2	7%	-0.6
Other household use	13%	-0.6	0%	0.0
Totals (l/h/d)		-17.4		-7.6

AMP8 to AMP11 (2025 through to 2045): Rollout of Smart Metering

6.2.20 Our strategy is to roll out smart meters as part of our ‘business as usual’ meter replacement programme (i.e. we install the smart meter when the existing meter requires replacement anyway), which means we only incur the small additional cost of the meter technology compared with our ongoing business activities. At the same time, we progressively roll out the Information Technology (IT) and ‘fixed’ recording network, which is where the larger expense would come from, and is required to manage the data and realise the benefits from the smart meters. The associated data management infrastructure is essential as this would allow us to pro-actively inform customers of high use, and provide us with information about potential supply pipe leaks or leaks within customers’ properties to support our leakage reduction programme.

6.2.21 We have adopted this staged approach, rather than, for example, replacing our current WSP AMR based approach with smart metering in AMP7 for the following reasons.

- a. We will be able to use our ‘street level PHC’ initiative to understand customer behaviour and hence use that understanding to design the architecture of the smart metering fixed networks (or other information transfer solutions) before we start installing the smart meter devices in homes. Currently we do not have that information available, so could not use it to design an optimal solution.

- b. We can learn from the Thames Water experiences when developing our approach, giving us the cost and delivery advantages of being a ‘second adopter’.
- c. The proposed programme will deliver 75% of the expected savings before we need to deliver any supply side investment, even under our ‘challenging future’, so there is very little opportunity cost associated with this more cautious approach.

6.2.22 The smart metering programme would act to replace the ‘fast logging’ contained within our AMP7 programme, and over time we would anticipate that we will improve on the behavioural savings achieved in fast logging by providing customers with more timely, relevant information on their usage.

6.2.23 Savings from smart metering are based on the assumption that we can achieve between 2% and 3% behavioural change (as estimated for the smart metering initiative in the energy sector) and an average 75% reduction in supply pipe leakage from properties that we are able to identify as having significant leaks through the smart meter data. This level of saving represents the amount we consider is achievable above and beyond the WSP and the HWEC activities associated with the ‘concerted action on water efficiency’ programme. It is consistent with the levels used by Thames Water and is reflective of the ‘anticipation benefits’ details by Southampton University in their policy review¹¹ (6%), net of the other water efficiency initiatives described above.

AMP9 to 13 (2030 through to 2050): Improving Water Efficiency in New House Builds

6.2.24 We have identified a separate option for reducing demand through water efficient devices, which relates to the installation of highly efficient white goods and fittings and the opportunities for greywater recycling in new homes. Fitting within new homes is the most efficient way that we can implement such a scheme, and our analysis indicates that we could theoretically achieve very low levels of average PCC in new homes using this approach. These very low consumption levels in new homes should allow us to reach our aspirational target of 110l/h/d (or 106l/h/d if the influence of occupancy rate driven inflation is discounted) across the housing stock in our supply area. However, implementing this approach, which requires widespread uptake of measures amongst developers, without policy support would be expensive for customers, an additional £450m cost to 2050.

6.2.25 Our aspirational target is to leverage the influencing activities contained within the ‘concerted action’ investment to seek policy support around mandatory labelling and retailing of white goods and fittings, which may allow us to increase the benefits of the ‘concerted action’ programme towards its maximum potential (reducing PCC down to 115l/h/d). With this policy support we can then seek to work with developers to affordably deliver our water efficient new homes programme on a scale that is sufficient to reduce PCC down to our 110l/h/d aspirational target.

¹¹ See ‘The Effective of Metering on Water Consumption – Policy Note’ published 2015.

Our PCC forecast

6.2.26 A summary of our overall planned delivery and ambition for demand management, based on the above considerations, is provided in Figure 33 below. When estimating the savings from savings from longer term demand management it is important to note that PCCs in tend to increase as a result of falling occupancy rates - see Section 3.3. In the longer term that means all of our demand management initiatives have to act against this underlying inflation in PCC. We estimate that by 2045 the average PCC will be around 4l/h/d higher than it would be if occupancy rates remained stable from the 2025 position.




Figure 33: Summary of our demand management strategy impacts

Non-household demand management strategy

6.2.27 In the medium term, as well as the household initiatives described above we will be seeking to reduce demand in the non-household properties that are served by the water retailers in our wholesale supply area. Currently, our plans are to meter the remaining non-household properties within our region where it is practical to do so, and, working with retailers, we will look to extend our water audit offering to those customers that have high usage that is not associated with industrial processes. These plans are supported by potential schemes to

install rainwater and greywater schemes at larger premises, again working with retailers in our supply area.

- 6.2.28 During AMP7 we will also start to explore the potential for working with the non-household water retailers in our region to seek water savings with their customers. We are looking at mechanisms whereby water retailers can propose savings and seek incentive payments from us to offset any loss of profit resulting from the reduction in the amount of water they sell. Currently this is a concept only and savings are likely to be modest in the overall context of our total demand, but we consider that it is important to explore this potential as part of our AMP7 activities. We consider that this process has the potential to generate non-household savings more cost effectively than proposals that require us to deliver the scheme, as it will seek to harness market innovation in the water retail sector. If possible, we will therefore use this process to replace the proposals described above within future WRMPs.

Leakage reduction strategy

- 6.2.29 We support the initiative to achieve substantial leakage reduction across the water industry, and will reduce leakage by 18.5% during AMP7 (a total of 30% from our 2015 starting position). We will meet this target through a combination of pressure reduction schemes, supply pipe leakage savings achieved through metering and ‘fast logging’ of those customer meters, and a change in approach and policy to our Active Leakage Control (ALC) activities. ALC activities are those aimed at finding and repairing leaks as quickly as possible. We will then aim for an overall reduction of 50% between 2015 and 2045 through a combination of network pressure reduction, active leakage control on our distribution system network, and reduction in leakage from customer supply pipes. This 30-year programme to reduce leakage by 50% is planned five years earlier than most other water companies because we started the process in 2015, and will already have delivered 14% reduction by 2020. Beyond this we will seek to achieve a further 7% reduction from our 2015 position so that we can achieve 50% reduction post 2020, by 2050. Details of our leakage reduction strategy are provided in technical report 4.8, which is summarised below.
- 6.2.30 By the end of AMP7 we will have delivered all of the ‘Pressure Reduction Valve’ (PRV) schemes that we are able to install on our system. The impact of this is relatively small (3MI/d) as we have already completed most of the pressure management on our network. We did review options for reducing trunk main leakage (i.e. large mains not covered by our District Meter Area – DMA – network), but our current levels are very low, at between 6 and 8 MI/d depending on the number of bursts that occur each year. Of this, only a relatively small proportion could be found and fixed more quickly than we do under our current approach, and we have determined that this is not an economically viable investment.
- 6.2.31 As discussed in Chapter 5, our economic analysis showed that reducing leakage through mains replacement is not economic, with a much higher marginal cost than our strategic supply development options (effectively double the cost). Although these options were included in our ‘optimistic’ and ‘aspirational’ futures that was done for illustrative purposes, to demonstrate the large cost implications of achieving 50% leakage reduction if we are not able to do this through innovation in ALC and supply pipe leakage reduction.

- 6.2.32 The main focus of our leakage control therefore has to be on improving the efficiency and effectiveness of our ALC and customer side leakage management activities. The change in ALC activities represents our largest leakage innovation in AMP7. We have already purchased over 20,000 noise loggers, which we will use in a new, technology-led approach based on targeted District Meter Area sweeps on our mains distribution network. Through this we intend to achieve a 30% efficiency in our current ALC detection and repair costs.
- 6.2.33 Achieving leakage reduction beyond this 30% will need to be supported by our Smart Metering programme, which we will use to further reduce customer side leakage, and additional stretch efficiency in our ALC (we assumed a further 10% efficiency within our modelling). With these measures, we consider that it should be economic to reduce leakage by a further 10% (i.e. 40% overall) before leakage reduction becomes un-economic in comparison to our strategic supply-side options.
- 6.2.34 Although options for leakage reduction through mains replacement do not represent good value for customers in comparison to strategic supply side developments, we note that achieving our ambition of a 50% reduction in leakage will require that we bring overall leakage to a level that is very close to our current 'background' level (i.e. the level that we cannot move below, even with extremely high levels of expenditure on ALC). Achieving our ambition of 50% reduction in leakage will therefore require that we maximise the benefits of smart metering (i.e. using the data to improve the accuracy and effectiveness of supply pipe leakage detection) and find a way to allow us to identify smaller leaks through ALC using as yet undeveloped technologies (e.g. the 'internet of things').
- 6.2.35 Details of our planned leakage reduction strategy are contained in supporting technical report 4.8. We have updated and refined that technical report, along with our 'sustainable economic level of leakage' (SELL) report as part of our fWRMP19 submission.

6.3 Our water supply strategy for the Central region

Key features

- 6.3.1 Our water supply strategy is designed to meet our ‘Challenging’ and ‘Expected’ futures. We explain how our strategy will adapt in response to our different futures in our Adaptive Strategy in section 6.4.
- 6.3.2 In order to ensure we have a resilient supply system, our strategy includes investment in improving our ability to move water around our network to where it is needed as well as new sources. It therefore consists of four components, as shown in Figure 34 below.




Figure 34: Components of our supply strategy for the Central region

**note – whilst the intra WRZ transfers are reflected where necessary in our ‘Supply 2040’ bulk transfer strategy, the schemes themselves have been developed separately as they are below the scale where we would consider them within a WRMP.*

Providing additional water resources – new smaller sources and strategic supply schemes

- 6.3.3 Based on the economic modelling and ‘best value analysis carried out for this WRMP, using currently available information, we have developed a preferred supply side strategy. A summary of the timing and location of the new water sources (both within our supply regions and from outside of our supply regions) identified for this strategy is provided in Figure 35. It should be noted that the selection and timing of the strategic developments after the Grafham expansion will be the subject of further investigations in the first three years of AMP7, as discussed under our adaptive strategy below.




Figure 35: Summary of the timing and indicative location of the new water sources (within region and external transfers)

- 6.3.4 Our first major supply-side option relates to the expansion of the Grafham bulk supply, allowing us to use it up to the full statutory entitlement of 91MI/d¹² (an increase of 30MI/d over the baseline). This is fixed at the earliest possible delivery date (2024/25) to meet our near-term challenges, principally sustainability reductions and a move to an enhanced level of drought resilience.
- 6.3.5 We are currently prevented from using our full statutory entitlement because the chemical properties of water from Grafham differ to those of groundwater. Treated water from Grafham Reservoir reacts with galvanised iron pipes in our supply area leading to discolouration. In addition, the presence of chloramine, which customers are not used to, creates a risk of taste and odour that is unacceptable to customers. These issues mean that we are only currently able to use water from Grafham in the north of our Central region for a very limited period of time and to specific areas. We will install conditioning treatment at Sundon Reservoir to address these water quality issues, enabling us to supply water from Grafham Water Treatment Works (WTW) throughout our Central region at any time.
- 6.3.6 The ‘best value’ analysis presented in Chapter 5 concluded that we will require the next strategic development by 2038 in our ‘Challenging’ Future. Based on the modelling described in Chapter 5 we have identified the South East Strategic Reservoir (SESR) as our preferred option, which we propose to develop jointly with Thames Water. We propose to contribute sufficient investment to reserve 100MI/d out of the full 294MI/d yield of the scheme. We will develop the reservoir itself by 2038 in our ‘Challenging’ Future. If we see our ‘Expected’ Future we will review whether to continue with development of the reservoir by 2038 or to develop it over a slightly longer time-scale to be ready for 2042. However, it may not be practical or cost-effective to delay development. We would carry out this review in consultation with Thames Water.
- 6.3.7 We propose to develop the transfer and treatment elements of the SESR scheme in two 50MI/d stages. In the first stage we will develop an abstraction on the River Thames and transfer the new supply to a new treatment works located near our existing Iver works (WRZ4). In the second stage we will extend the transfer through to Harefield and a second 50MI/d works in that location (WRZ1).
- 6.3.8 The best value analysis identified that we are likely to require a second strategic scheme within the modelled timescale (i.e. before 2080). The economic modelling and ‘best value’ analysis carried out for this WRMP identified the GUC transfer as the preferred second stage of strategic development or ‘backup’ scheme to the SESR. Because this is our next preferred option we will continue to investigate the scheme as part of our adaptive plan. Part of that investigation process will include improving our understanding of the water quality and environmental constraints to determine if it is possible to reduce the scope and hence costs of the scheme. If we can reduce the scope and costs then we will review the timing of the scheme in comparison to the SESR as part of our adaptive strategy (see section 6.4).
-

- 6.3.9 Strategic schemes inevitably contain uncertainties over scope, cost and impacts, which need to be resolved before we commit to a preferred scheme to ensure cost effectiveness for customers, and ‘best value’ for our stakeholders. The ‘enabling actions’ developed in Chapter 5 therefore incorporate investigations and activities for schemes other than these two preferred options. These also feed into the adaptive plan within section 6.4.
- 6.3.10 The smaller options, consisting of three developments of the Lower Greensand and the development of the Brent reservoir, which is an existing asset owned by the Canal & River Trust, are proposed for development in the period prior to the SESR. They provide us with both flexibility in supply and represent an economically cost-effective part of our supply-demand management strategy.
- 6.3.11 In addition to these committed supply-side developments, we have identified a further potential option, which relates to a small licence trade on the River Thames. This is in the early stages of development and updated information on the option indicates that there are likely to be constraints on availability under drought conditions, so a yield benefit of 4Ml/d has been calculated for the scheme for this Plan.

Maintaining and improving operational flexibility – “Supply 2040”

- 6.3.12 For our fWRMP19 we have developed a long-term strategy that allows us to improve connectivity in our Central region and unlock the constraints within our current network. This will enable us to move water within our Central region by 2040; this strategy is known as “Supply 2040”. It includes a portfolio of new strategic internal transfers to move water more freely from further north and east in our Central region, and allows us to move the forecast surplus in WRZ6 to other WRZs. An outline summary of the schemes that are potentially included in the development is provided in Figure 36 below.




Figure 36: Details of the Key Elements of our “Supply 2040” Strategy

6.3.13 The development of our transfer system is a key component of our strategy, and we have ensured that transfers balance across all WRZs in all of our adaptive ‘futures’, including the ‘stretch’ high growth and sustainability reduction scenarios described in Section 5.8. The WRZ level balances for all four of our ‘core’ adaptive futures are presented within Technical Report 4.9.

6.3.14 In the short term (AMP7) “Supply 2040” is needed to enable the successful transfer of 17MI/d water from Wey in the far south of the Central region to Pinn (the only Community to border with Wey) and then north to Colne, Lee and Stort. It also ensures that we retain a constant level of operational risk once the increase in the Sundon transfer has been introduced into the

network. The inter-WRZ network changes required to enable this are highlighted in red, and the intra-zonal enabling works shown as orange on the diagram. All of these schemes are required to enable to the first stage of the Egham to Iver transfer (17MI/d) and the Grafham import upgrade (30MI/d) by the end of AMP7.

- 6.3.15 The next scheme required to deliver the WRMP strategy is the second stage Egham to Iver scheme (15MI/d). This is shown as an AMP8 scheme and labelled on the diagram. The other AMP8 Supply 2040 schemes represent intra zonal transfers that may be required to accommodate increasing growth and the AMP7 sustainability reductions, but are not part of the EBSD modelling. The need for those other schemes (shown in green on the diagram) will be reviewed during AMP7.
- 6.3.16 The next inter-zonal transfer that is required is the Arkley North scheme, which is a relatively small (50 to 100m) section of pipework plus associated valve changes (circa £0.6m cost). In the EBSD modelling this is not required until AMP9 (2034), but it also forms part of the intra-zonal network changes required to use the water introduced into WRZ 4 by the first stage Egham to Iver transfer. This scheme has therefore been included in AMP7 in our final 'best value' WRMP19 and the PR19 Business Plan.
- 6.3.17 The final inter-zonal transfer required from the decision-making modelling is the Boxted to Chaul End scheme, as shown on the diagram. In the Supply 2040 programme this is currently scheduled for AMP9 (2035 to 2040), but the EBSD modelling indicates that this would only be required after 100MI/d of strategic development has been carried out in WRZs 1 and 4, so it comes after 2050 (in time for the last 50MI/d of strategic resource). The timing of this scheme will therefore be reviewed as the plan progresses beyond AMP8.

Climate change risks to our proposals

- 6.3.18 We formally analysed the risk from climate change on the options that are contained within our best value plan, as shown in section 4.4. However, as the majority of our supply schemes are either internal transfers, abstractions from the Lower Greensand (which is resilient to drought and climate change) or sourced from effluent discharges (the GUC scheme), the risks are extremely small, accounting for less than 1MI/d of the overall uncertainty.
- 6.3.19 Two options are potentially vulnerable to climate change, the SESR and the Brent Reservoir. Modelling carried out by Thames Water and provided in its WRMP demonstrates that the SESR is not vulnerable to climate change. For the Brent Reservoir we have some concerns, but these are more generally incorporated within our overall yield uncertainty for the scheme (25% uncertainty on yield) and will work towards resolving this uncertainty as we develop the option.

Water quality and conjunctive use considerations

- 6.3.20 Our first strategic development is the conditioning of the bulk water supply from our Grafham import and associated new treated water storage, which will allow us to maximise the use of the transfer. This scheme introduces surface water into areas that have been historically

served by Chalk groundwater. The conditioning treatment therefore ensures that the difference in the nature of the water that it introduces into parts of our supply system will not create any deterioration in water quality.

- 6.3.21 The supply schemes associated with the Brent reservoir, Greensand boreholes and the abstraction and distribution of the SESR water all require conventional treatment that we are familiar with. We will review the extent of supply of these sources within our network as part of the detailed design of the schemes and, if required, incorporate conditioning plant within the treatment processes. For the SESR scheme this will be relying on water from the River Thames, so we will need to make sure that we have source protection measures and emergency storage or alternative supply arrangements in the case of pollution incidents in the river. Again, these will be reviewed as part of the detailed design for the scheme.
- 6.3.22 As part of the design for the transfer and treatment of water we will look for opportunities to improve our resilience against pollution events and the current rate of water quality shutdowns associated with our large surface water works, which may help us to reduce outage allowances. The nature of the SESR schemes means that we will be able to explore such options jointly with Thames Water, through connections and emergency supplies from their existing London storage reservoirs.
- 6.3.23 As noted previously, we do not currently have water quality data for the GUC, and we have not yet modelled the impact of introducing the treated effluent from Minworth on that water quality. Our current scheme costings for the GUC transfer therefore allow for a very high level of treatment, and we will work with our water quality regulator to ensure there is no risk to customers from any of the 'value engineering' of the scheme that we identify as investigations proceed during AMP7.
- 6.3.24 Within Section 4.6 we outlined the potential implications of our future investment strategy on the flows in the River Thames, and hence the availability of water for Thames Water, who abstract downstream of our main surface water intakes and many of the wastewater treatment works that discharge used water from customers. Based on the 'best value' plan described above, our investment strategy for the Central region will result in:
- A fall in demand of around 70MI/d between 2020 and 2035.
 - A reduction in abstraction from Chalk catchments of 33MI/d by 2035, which is offset by an additional supply from Grafham.
 - Increases in demand will be met by additional strategic resources beyond 2035.
- 6.3.25 Based on the above, our proposed investment strategy will affect Thames Water differently in the earlier (pre 2038) and later (post 2038) stages of implementation.

- 6.3.26 Prior to 2038 we reduce our overall demand (Distribution Input) by 70MI/d through our demand management and leakage reduction initiatives. We also import 30MI/d extra through Grafham under drought conditions. Without Grafham we would need to reduce demand by around 100MI/d to address our supply/demand deficit under the 1 in 200 year drought event and meet our commitment to reducing Chalk abstractions. In order for demand to be reliably lower during drought events it will be necessary for us to ensure it is lower at all times – i.e. during normal years as well as dry years.
- 6.3.27 Overall the net impact on Chalk stream flows during drought events will be equal to the difference between the amount that effluent returns will reduce as a result of the 70MI/d drop in demand, and the amount that they will increase as a result of our reduced abstractions and the fact that we are importing additional water in from Grafham. We do not currently have quantified information on the percentage impact that these two factors will have on dry weather flows. However, based on the fact that a relatively high percentage of our demand returns to the Thames via effluent discharges, compared with a low percentage increase in dry weather flows from reducing Chalk abstractions (see Chapter 4), at this time we consider that there is an appreciable risk that flows in the River Thames during drought events will reduce as a result of our investment programme prior to 2038.
- 6.3.28 In the longer term it is likely that flows in the River Thames will start to increase as a result of strategic resource developments, as this new water import will increase effluent returns in line with increasing demand.
- 6.3.29 The shorter versus longer term situation is shown conceptually in Figure 37 below. It should be noted that both of these changes could have an impact on water quality, which would need to be considered as part of future licence determinations.




Figure 37: Summary of Potential Regional Implications of Our Investment Strategy

6.3.30 Clearly there is a need for regionally based modelling of the supply systems and associated hydrology. We have therefore included this within our adaptive strategy for the Central region (see 'regional modelling and testing of options' within the proposed monitoring plan).

Managing Demand from HS2

6.3.31 There are two separate needs that arise from the HS2 scheme, which can be described as follows:

- We are allowing for up to 20MI/d peak only for our own sources to account for the risks associated with transient turbidity increases from the Tunnel Boring Machine (TBM) and/or pilling for the Cone valley viaduct as the HS2 route passes near the Blackford Group of sources. This is addressed through the licence variation applications to the Environment Agency for the Blackford and Watford group of sources to allow peak flexibility within the group licences and a 10MI/d peak only import from Thames Water Utilities Limited (TWUL) at Perivale, as an import of treated water. This import relies on transient capacity from TWUL and does not therefore impact on their ADO supply/demand balance. The water will be supplied from existing surface water sources from the River Thames.
- The construction demand of the scheme is currently up to 5MI/d, but is still being finalised. We are therefore in a process of discussing a potential import of up to 10MI/d at Cockfosters from TWUL to provide this water at both peak and average conditions. This is a temporary supply that TWUL are evaluating in detail (through the construction of a specific hydraulic model), in order to understand whether it has the capacity to supply the construction water. The water would again be supplied from existing surface water sources from the River Thames.

- 6.3.32 For the construction water, we have made it clear to HS2 that we are proposing to provide this water as a non-domestic supply, which is subject to us having sufficient water to meet our existing and anticipated future obligations to supply water for domestic purposes. Because we are unable to generate a reliable supply/demand surplus under design conditions within AMP7, this means the HS2 supply will be at a lower level of service than stated for our statutory customers. It will therefore be necessary to review this supply in the event of severe drought conditions developing. Such a review could be triggered by either TWUL indicating that they are unable to maintain the supply from Cockfosters, or in the event that we are at risk of reaching our design drought (1 in 200 year condition), with a review being triggered once we reach our Level 4 Drought management Plan threshold. In the event that we needed to rely on Drought Orders and Permits to support our own customer supplies, we would not supply HS2 construction water, unless the TWUL transfer from Cockfosters is available.
- 6.3.33 Because we are acting conjunctively between the two systems, we do have flexibility with drought management. If the drought is surface water-led, then we could support TWUL in maintaining London raw water storage by reducing the average take at our existing Fortis Green import below the allowance contained in this WRMP (12MI/d), as our groundwater source DO would be greater than the design condition. Similarly, if the drought is groundwater-led, then TWUL could maintain their supply, provided the surface water drought does not approach their design condition (currently just over 1 in 100 years). This means that, although the level of service provided to HS2 is not the same as for our statutory customers, the risk that we would have to cease supply is very low, in the order of 1 in 100 years.
- 6.3.34 Because the supply is not at the same level of service as for our statutory customers, we have not included HS2 demand or supply within the WRMP tables. We will liaise with the Environment Agency prior to the commencement of any supplies to HS2 and engage with the regulators (EA, Ofwat, Defra) to provide advance notice of risk of, and clear trigger for, the supply to terminate. This is likely to require more frequent communications than the 6-monthly report and we can make reference to this within our Drought Plan reporting, as appropriate.
- 6.3.35 The supply at Cockfosters will require some capital works so may not be available for the early part of the construction period. The maximum demand that we will need to provide to HS2 during this period is up to 2MI/d. It is likely that we can accommodate this from surplus outside of the design drought condition, as described in paragraph 6.3.31 above. The water would be sourced from within WRZ1, and the maximum duration of supply would be for 2 years, during the period 2021-23. This plan allows us to supply the water required by HS2 without affecting the WRMP or risking environmental detriment.

6.4 Our adaptive strategy for the Central region

- 6.4.1 The key objectives of our adaptive plan are to allow us to make decisions in a timely manner. This includes the potential deferring of investment on strategic supply options to reduce costs to customers, but *only* if we are able to satisfactorily demonstrate that this will not create a risk to our ability to supply water to customers. The adaptive plan is summarised graphically in Figure 38 below, which shows the different adaptive pathways in our strategy.

6.4.2 The enabling actions that we identified for AMP7 in Chapter 5 have been developed for the strategic schemes in alignment with the Business Plan process, and in particular our response to Ofwats' Initial Assessment of Plans (IAP), which requires such investigations as part of our AMP7 Business Plan. A core part of this process relates to the setting up of a 'gated' process, whereby the strategic scheme investigations are carried out jointly by the water companies involved, and the scope of works and decision whether or not to proceed to the next gate is scrutinised by the economic (Ofwat) and environmental (EA) regulators. This gated process will apply to all of the strategic investigations, and covers the enabling actions associated with the SESR, the River Thames to Affinity Transfer, the GUC transfer and the South Lincolnshire reservoir scheme, which were identified through our adaptive pathways analysis in Chapter 5.

6.4.3 Under the IAP proposal, the description and timing of the gates can be summarised as follows:

- Gate 1 relates to the completion of initial investigations that will ensure that all schemes are developed to the same standard of outline design, scoping and costing. They can then be cross compared on a regional basis as part of the governance process. All of our strategic investigations are planned to reach Gate 1 in mid 2022.
- Gate 2 then contains final outline design and a refined comparison of schemes that will form the basis of the South East regional plan and our WRMP24 submission. This is designed to fit in with our key adaptive decision in 2023. There is a marginal difference in timing between this and our adaptive plan decision point of March 2023 (of up to 3 months), as Gate 2 is currently planned for summer 2023, but this is not material to schemes with lead times of 9 years or more. If a scheme passes Gate 2, then substantive development and promotion activities (Development Consent Order or Environmental and Social Impact Assessment (ESIA) plus planning application preparation) will start.
- Gate 3 then falls towards the end of AMP7 and represents the point at which planning documentation will be ready for submission.

6.4.4 The description of activities associated with our adaptive plan therefore refers to this gated process as appropriate in the following sections. It should be noted that our adaptive plan is designed to determine the 'case of need' at Gates 1 and 2 (i.e. whether or not we need to proceed with a scheme given the monitoring of supply side and demand side forecasts that we have carried out as part of our Monitoring Plan). These activities are also described under the adaptive plan below.

6.4.5 The adaptive pathways analysis identified that our current preferred strategic option is the SESR, plus the associated River Thames to Affinity Transfer. Our second preferred option is the GUC transfer, with the South Lincolnshire Reservoir acting as a backup scheme. However, as shown in the adaptive plan in Figure 37, the investigations and gated process in AMP7 are intended to be run in parallel so that we can change our first and second preferences, if appropriate, as a result of the pre-2023 activities.

6.4.6 As well as the investigations that we will be undertaking on the strategic schemes that we will be directly involved in, we will also be liaising with Thames Water, United Utilities and Severn Trent to review the outputs from their investigations into the potential for water trading via the Severn Thames Transfer scheme, and discussing the options for other trades with Thames Water. As noted in Chapter 5, if, following these further investigations, trading options are found to be as good as, or better than, our WRMP19 preferred development options, then we will incorporate them as alternative sources for our Thames to Affinity Transfer scheme, replacing options such as the SESR.




Figure 38: Our Adaptive Plan

- 6.4.7 Further description of the enabling actions and timings within our adaptive plan are provided below, which relate back to the realisation of our four ‘futures’, as shown in Figure 38.
- 6.4.8 Whilst our WRMP is adaptive, it has been carefully constructed and timed to ensure that resilience to customers is not put at risk as a result of the investigation process and decision making activities. For our preferred first strategic option (SESR) this includes the potential for Public Inquiry into the scheme if we decide to proceed following the 2023 decision point. Table 21 below sets out the milestone dates for the possible delivery process of the South East Strategic Reservoir (SESR). This incorporates the latest information from regulators on the timings of the WRMP24 process, plus the regional plans. Where appropriate we have also referred to the Ofwat ‘gated process’, through which our regulators will be scrutinising progress on the investigation and development of potential strategic supply options.
- 6.4.9 We note that the timing of Gates 3 to 5 will depend on the findings of earlier gates, but the gated process is designed to support the investigation and (where appropriate) delivery of options, and will not act to delay the SESR delivery timeline.
- 6.4.10 Table 2 below is indicative only, but demonstrates that there is more than sufficient time to accommodate a public inquiry within the process, whilst still allowing for more than 10 years of development and construction once the subsequent DCO decision has been made.

Table 21: Programme of Development for the SESR Allowing for Public Inquiry.

Date	WRMP24/WRSE Milestones	SESR Milestones
Feb-20	WRSE Statement of need (SON)	
Feb-21	WRSE SON – update	
Jun-21		Complete Ofwat ‘Gate 1’ investigation activities (including regional optioneering)
Aug-21	Initial Regional Plan	
Jan-22	Draft Regional Plan	
Apr-22	WRSE Regional Plan to inform company WRMP24	
Aug-22	Draft WRMP24 & Revised Regional Plan	
Sep-22	Development of draft WRMP24	Complete Ofwat ‘Gate 2’ investigation activities (including further development of the regional best value resilience plan)
Nov-22	dWRMP24 consultation finishes	
Mar-23	Statement of Response dWRMP24	
Apr to Jul-23	Revised draft WRMP24 submission	Commence Development Consent Order (DCO) pre-application activities (July)
Sep-23	Final Draft Regional Plan	Complete Ofwat ‘Gate 3’ activities (final design, decide procurement etc)
Oct-23		
Nov-23		
Dec-23	Decision, scope and set-up for inquiry	Notify the Planning Inspectorate (PINs) of DCO scheme
Jan-24		
Feb-24		
Mar-24		
Apr-24		

May-24	Possible timing for public inquiry/examination into WRMP24	
Jun-24		
Jul-24		
Aug-24		
Sep-24		
Oct-24	Contingency on public inquiry	
Nov-24		
Dec-24		
Mar-25	Secretary of State confirmation of WRMP24	Case of need proven through the WRMP24 public inquiry; statutory DCO consultation starts
April-26		Submit DCO application
Oct-27		DCO decision
Sep-28		Complete pre-construction activities (land purchase etc)
Oct-28		Start construction activities
2037		Complete construction and filling
2038		Scheme on-line prior to summer 2038

6.4.11 Many of our options will need to be investigated and developed jointly with Thames Water, and the viability of schemes such as the SESR will depend on Thames Water’s needs and preferences. We have therefore aligned our adaptive plan and monitoring plan with the adaptive plan and monitoring plans described in Thames Water’s Section 11 of their rdWRMP19. A description of the alignment is provided as appropriate within each section below.

All four futures – 2020 to Summer 2023

6.4.12 During the period 2020-2023, we will implement our demand management strategy and our supply strategy. We will also carry out enabling actions and commence our monitoring plan during the period 2020-2023.

6.4.13 Our enabling actions are set out in Table 22.

Table 22: Summary of our AMP7 enabling actions 2020-2023

AMP7 enabling action	Activities and timing
SESR pre-development	Investigations to model conjunctive capability of water resource needs, confirm reservoir sizing and flood risk and develop operational management. Confirm scope and costing of scheme to a consistent level with other options.
GUC technical investigations	Two years of monitoring and investigation into water quality, hydraulics and hydrology carried out in partnership with CRT to determine the scope of the best value option. Confirm scope and costing of scheme to a consistent level with other options.
GUC environmental feasibility investigations	Ecological studies carried out in parallel with the above, plus associated detailed liaison with the EA and Natural England to review the options for abstraction on the River Tame, and/or pre-treatment requirements at Minworth. Explore both the Berkhamsted and extended Iver transfer options

River Thames transfer investigations	Investigations to confirm transfer and treatment needs for both a staged (50MI/d plus 50MI/d) and single (100MI/d) transfer option to take raw water from the River Thames (surplus generated either by SESR or an alternative raw water source via trading arrangements).
South Lincolnshire reservoir and Anglian Water transfer investigations	Ongoing liaison with Anglian Water plus further investigations into the yield, design and cost of the 100MI/d (Trent-Witham transfer version of the option). Confirm scope and costing of scheme to a consistent level with other options.
Additional water trading capability.	Review and development of water trading options that might act as a substitute for the three strategic options described above. Particularly relates to discussions and modelling associated with the Severn Thames Transfer, but also to determine if other trading options with Thames Water are viable (traded volumes would be offset by additional supply developments carried out by Thames Water, such as additional effluent re-use schemes).
Regional modelling and testing of options	Co-development of regional economic and resilience modelling as part of the Water Resources in the South East group, plus associated testing of regional options to confirmed preferred solution post 2023.
Monitoring framework activities	Monitoring to confirm the 'case of need' for new strategic options at the summer 2023 decision point. See below for the details Monitoring Plan framework, which includes activities needed to support the 2023 decision point.

6.4.14 For the strategic scheme investigations, we will carry them out as co-developments with other water companies or the Canal & River Trust. This will be delivered in two stages, or “gates”, with governance, including the decision or not to proceed beyond the first gate, provided by our regulators (as described under the monitoring plan below).

6.4.15 Our monitoring plan will allow us to assess objectively which of our four futures is being realised and should ensure that we invest in a strategic supply option at the right time. We will ensure that we use industry standard models and studies and that we provide evidence-based assessments.

6.4.16 Our monitoring plan will include three categories of monitoring activities as set out in Table 23.

Table 23: Our proposed AMP7 monitoring framework.

Assessment Area	Monitoring activity	Metrics being reviewed	Purpose and relationship with AMP7 decision points
Category 1: Technical assessments to provide an evidence base of benefits realised through demand management options and yields of supply options.	Borehole development investigations	Yield and likely licence capacity of the Greensand borehole schemes.	By 2023. Indicate whether if 'Challenging' supply future risks can be excluded.
	Brent reservoir investigations (hydrological and environmental)	Expected Deployable Output of the Brent reservoir scheme.	By 2023. Indicate if 'Challenging' supply future can be excluded. By end of AMP7. Confirm viability of scheme.
	WSP outturn benefits	Water saved by the current metering and water saving programme on household demand.	By 2023. Provide supporting information to determine whether the 'Optimistic' demand future is likely.

Assessment Area	Monitoring activity	Metrics being reviewed	Purpose and relationship with AMP7 decision points
	WSP data analysis	Confirm size of supply pipe leakage and overall scope for reduction	By end of AMP7. Identify whether leakage reduction could follow the 'Aspirational' future.
	Fast logging metering results	Impact of 'smart' information on customer behaviour, plumbing and supply pipe losses	By 2023. Identify whether the full smart metering rollout can achieve the 'Optimistic' demand future in the long term.
	Development plan data provided by Local Authorities or national government	Impacts of new development plans on housing and population forecasts	2021. Confirm if high growth sensitivity scenario will occur based on GLA and CaMKOx plans. 2022 use regional model growth projections to confirm strategic scheme timing.
	Leakage control costs and efficiencies	Analysis of leakage costs based on updates of cost data and outturn cost curves	By 2022: confirm if efficiency targets are in line with assumptions
Category 2: Evaluation of policy direction and developments in technology relating to demand management and supply	Liaison with industry and policy makers as part of the 'concerted action' programme	Scope of white good labelling and media activities to reduce demand.	By 2023: Identify whether the 'optimistic' demand future is likely.
		Scope for governmental policy support or construction industry wide potential for water efficiency targets on new developments*	End of AMP7: Initial identification of whether the 'aspirational' demand future could be achievable.
	New policy leakage data and cross industry review	Scope for efficiency in active leakage control beyond that currently available through leakage technology	End of AMP7: Initial identification of whether the 'aspirational' demand future could be achievable.
	Liaison with Environment Agency and river groups	Likelihood and magnitude of potential further abstraction sustainability reductions in the Central region	2022: Determine if high sustainability reduction scenario might occur. 2023: determine likely 'no deterioration' impacts and confirm if 'challenging' supply future can be excluded.
Category 3: Strategic Investigations	Enabling actions	Outcome of the pre-2023 investigations and studies and associated regional modelling checks	2022: Gate 1 regional modelling complete (scope and outline design for each option) indicating which options to progress further. 2023 Gate 2 and WRMP24 review complete with preferred option confirmed.

**In the short term, this will include the government publications relating to per capita consumption targets, and the Water UK study into pathways for water efficiency. In the longer term, we will seek to add to this through campaign findings and study reviews that we will develop with partner organisations (Government, local authorities and NGOs such as WaterWise) as part of our 'concerted action on water efficiency' initiative.*

Further Consultation and Engagement with Customers and Stakeholders

6.4.17 We propose to report on our progress against the delivery of these monitoring outputs through our annual submissions to the EA and Ofwat. We will accompany this with a 'stakeholder assembly', along similar lines to the event that we held as part of our consultation on the rdWRMP19. This will be supported by ongoing stakeholder engagement that will be arranged according to 'themes'. Our proposals for this are as follows:

- *Theme 1: Small scheme investigations.* Stakeholder consultation will involve the EA, Natural England (NE) and the Canal & River Trust. This would be achieved through regular meetings and technical working contacts. We will need to be able to confirm the viability of these schemes prior to our 2023 decision point. For the Brent reservoir our AMP7 monitoring will consist of up-front discussions and initial site visits to review the viability of the scheme in relation to its SSSI status and change of use from canal balancing to water supply. We will do this in 2020 and 2021 and we will work closely with the Canal & River Trust, EA and NE to determine the reliable yield that can be obtained given the environmental constraints, covering hydrological modelling of reservoir levels and the implications of that on flood risk and the Site of Special Scientific Interest (SSSI) ecology. More detailed investigations that will commence in AMP8 if the scheme appears viable at the 2023 decision point, which will include all relevant water quality and ecological modelling required for ESIA. For the Lower Greensand schemes, we will carry out initial investigations to confirm the viability of the Slough/GSK scheme, and propose to work with the EA to develop our understanding of the behaviour of this deeply confined part of the Lower Greensand basin. .
- *Theme 2: Reductions in Abstraction.* We will lead the way in protecting the environment, particularly relating to Chalk streams. This includes investigation and improvement of Chalk stream habitat within our supply region. Through this we will develop a sustainable plan to improve Chalk stream habitats where investigations demonstrate the need. We propose to re-start the Chalk Rivers Partnership that was trialled in AMP6 and incorporate Catchment Partnerships into our review process, with a view to determining the probable level of future sustainability reductions in time for the 2023 decision point. We will host an information exchange portal (the specification of this will be determined through initial rounds of consultation), followed by a formal review meeting in 2021. This will be followed by 6 monthly discussion events in 2022 and the first half of 2023. We will work closely with the EA with regular meetings between the events.
- *Theme 3: Managing Growth and Demand.* We propose to form a Partnership for Managing Growth and Demand, who we will consult with on updates to growth forecasts and the data and findings from our demand management and leakage programmes. This partnership will be drawn from the EA and stakeholders who expressed a preference for being involved at our recent Stakeholder Assembly. We will also consult on a regular basis with Thames Water, to share progress on demand management and considerations of delivery risk. We propose that information is exchanged with the Partnership through a similar arrangement to that used for the Chalk Rivers Partnership above.
- *Theme 4: Strategic Option Investigations.* This will primarily be managed through the gated development process, where the water company partners involved in our five

strategic initiatives will provide regular updates to the Regulatory Alliance for the Promotion of Infrastructure Development (RAPID), who are likely to act as the main governance control on the scheme findings. The individual schemes will require stakeholder engagement plans to be developed as part of the investigations.

6.4.18 In addition to these initiatives we will include WRMP customer consultation within our Citizen Assemblies, where we will test any non-monetary preferences and willingness to pay for proposals such as enhanced reductions in abstraction from the Chalk. The exact format and frequency of meeting of these assemblies is yet to be determined, but this will form the core part of our ongoing engagement with customers.

Alignment with Thames Water in the Period 2020 to 2023

6.4.19 Our plans align with Thames Water in two key ways up to this point:

- Joint investigations into the SESR and Thames to Affinity Transfer will be carried out according to the investigation activities developed for the IAP submission. A description of the detailed joint investigation activities up to Gate 1 (2022), and the timing of joint activities beyond is provided within our fWRMP19 Technical Report 5.3. This shows that the two schemes that we are investigating jointly with Thames Water are also being progressed in parallel with the investigations for the GUC transfer and South Lincolnshire reservoir schemes.
- Our monitoring plan and the monitoring plan described in Section 11 of Thames' WRMP contain similar metrics, which will be used to demonstrate the 'case of need' for the strategic schemes at Gates 1 and 2. We will include Thames Water in our 'Chalk Rivers' and 'managing growth and demand' partnerships to ensure that we share findings as appropriate to provide the consistency of approach that we will need to demonstrate our case of need. We will continue to liaise with Thames over demand and growth aspects through regular meetings and their technical stakeholder fora.
- As described in Appendix XX of Thames' WRMP, Thames will continue to investigate a number of London re-use options in AMP7. These could form part of a trade as an alternative to the GUC transfer if we have to accelerate development as a result of the 'high growth' or 'enhanced sustainability reduction' scenarios being realised with only 'expected' levels of demand management success. The trade options can therefore be pursued if investigations on the GUC transfer show that it is not viable, or is more expensive than we currently anticipate, and hence a trade represents better value for customers and stakeholders.

Decision point - 2023

6.4.20 By the end of summer 2023, our adaptive pathway splits into two: our "Expected" and "Challenging" futures are on one adaptive pathway and our "Optimistic" and "Aspirational" futures are on the others.

6.4.21 At this point, we will review the monitoring metrics to determine whether:

- The supply risks associated with the “Challenging” supply future are likely to occur.
- Demand management initiatives beyond AMP7 should at least be able to meet the “Optimistic” assumptions contained within this Plan and forecast housing and population growth is within the envelope of the forecasts contained within this Plan
- Innovation in leakage control is likely to be sufficient to meet, or come close to, the 50% target without having to replace water mains.

6.4.22 On the basis of this information gained from the first three years of our monitoring plan and following consultation with regulators, stakeholders and customers, we will decide whether we can defer progressing a strategic supply option. We will do this only if we are confident that this does not represent a risk to customers. Governance and decision making for this in the regional context will be managed through the gated assessment process referred to previously.

Alignment with Thames Water

6.4.23 Thames Water contain the same decision point within their adaptive plan, with Gate 2 and the key decision point for advancing options beyond the investigation stage scheduled for the period March 2023 to July 2023.

Expected and Challenging futures – 2023 onwards

6.4.24 From this point onwards we will start strategic scheme development, if it is required. We will continue to implement our demand management strategy, finalise our understanding of minor source capability and confirm the timing of the next stage of development of “Supply 2040” (Egham to Iver second stage development). Activities are therefore as summarised in Table 24.

Table 24: Summary of our AMP7 enabling actions 2023-2025

AMP7 Enabling Action	Activities and Timing
Ongoing review of the demand management strategy	Continue to collect and analyse data from our water efficiency programmes and ALC initiative.
Confirm preferred strategic option and commence development of planning application.	Work to ‘gate 3’ to confirm design (end of 2023) and, if required, select the final preferred option, Activities from there depend on the preferred scheme. For SESR or South Lincolnshire, this requires detailed design and preparation of the Development Consent Order application. For the GUC transfer the likely requirement would be to prepare ESIA and planning application documentation. Transfer elements will be promoted accordingly, and may be progressed on a ‘stand-alone’ basis if trading options are preferred.
Further water quality, environment, yield and design investigations for Brent Reservoir and confirmation of LGS borehole development scope.	Post 2023. If appropriate following the decision to proceed as part of the Monitoring Plan review, carry out some studies into environment, water quality, yield and treatment design to confirm viability. This includes initial on-site environmental and water quality investigations. Carry out further reviews of data and hydrogeology to determine the viability of the LGS borehole programme.

Further water trading capability and retail innovation	Additional review and development of water trading options beyond those identified for WRMP19, plus initial development of water efficiency innovations such as the retailers' incentives.
--	--

- 6.4.25 In 2025, we will be able to confirm whether we are seeing our “Expected” or “Challenging” Future, and at that point can decide whether a small delay (of up to 4 years) is useful for the strategic development if the “Challenging” future is no longer a concern. Otherwise we will carry on with submission of the planning application for the preferred scheme in 2025.

Optimistic and Aspirational futures – 2023 to 2030

- 6.4.26 We will continue to implement our demand management strategy and elements of our supply strategy other than those relating to delivery of a strategic supply option, which is deferred under our “Optimistic” and “Aspirational” futures. We will put in place an AMP8 Monitoring Plan that will be designed to determine, by end of AMP8 (2030), whether there is enough policy support and low enough risks on the supply side to allow us to achieve our “Aspirational” future.

Optimistic and Aspirational futures - decision point - 2029

- 6.4.27 In 2029, our adaptive pathway splits in two again: our ‘Optimistic’ Future is on one pathway and our Aspirational Future is on the other. We will make the decision on the basis of information gained as a result of implementing our AMP8 monitoring plan and following consultation with regulators, stakeholders and customers. We will decide whether there is enough policy support and low enough risks on the supply side to allow us to achieve our “Aspirational” future. We may be able to defer this further if we can achieve a ‘stretch’ leakage reduction target of 57% between 2015 and 2045 (i.e. 50% post 2020), although the benefits from this are relatively limited, as it would only defer the decision by around 3 or 4 years.

Optimistic future – 2029 onwards

- 6.4.28 If we see our “Optimistic” Future we will at this point commence development of the preferred option that we identified during our 2020 to 2023 investigation activities with delivery planned for 2051. For the SESR this timescale is similar to Thames Water’s WRMP19 Preferred Plan, and earlier than the stated delivery of the STT or South Lincolnshire reservoir, so we would consider that all these options will still be available to us.

Aspirational future – 2029 onwards

- 6.4.29 If we see our “Aspirational” future we will start with the ‘water efficient new homes’ initiative (or other initiatives that may become open to us as a result of the policy environment) and defer the decision on any supply side development until 2039.

Alignment with Thames Water

- 6.4.30 Thames describe four futures within Section 11 of their WRMP. These are described from Thames’ point of view, so the ‘expected’ future allows for our need for the first strategic option in 2038. They then show that they are able to adapt their plan if they experience higher than expected growth, with delivery of the first strategic option still in 2038, but with the

second option accelerated to the late 2040s. This is important, as it is likely that we would both experience high growth if this scenario developed due to our close proximity. Under our high growth scenario we would potentially need to accelerate our first strategic option to the early 2030s, and then require the second option (the SESR under our current modelling) by 2041. Thames Water’s plan shows that they have sufficient options to cope with high growth and still accommodate our need on the SESR within the late 2030s to early 2040s timescale. Our proposed adaptations in the event of high growth are therefore aligned with Thames Water’s Plan.

6.4.31 Thames also include ‘optimistic’ and ‘aspirational’ futures, where the timing of need for the first strategic resource is similar to the scenarios of the same name that we present.

6.4.32 Based on the above it is clear that Thames Water’s plan is able to accommodate the uncertainties and adaptations that we have presented within this Chapter of our fWRMP19.

6.5 Our water supply strategy for the Southeast region (WRZ7)

6.5.1 The majority of the deficit for the Southeast region can be managed through the demand management measures described previously, plus extension of our bulk supply arrangements with our neighbouring water companies. Some licence changes and infrastructure schemes are still required (removing constraints around our Dover source and strengthening the network around Broome), primarily to address needs during periods of peak demand. A summary of the supply side schemes and timings is provided in Table 25.

Table 25: Summary of supply side developments for the Southeast region (WRZ7).

Scheme Name	Date Required	Deployable Output (Peak, MI/d)
AFF-EGW-WRZ7-0629: Lye Oak Variation	2021	0.14
AFF-EGW-WRZ7-0908: Tappington South Licence Variation	2044	0.7
AFF-RNC-WRZ7-0626: Broome Network Improvement	2066	2.27
AFF-RNC-WRZ7-0900: Dover Constraint Removal	2022	1.32
AFF-RTR-WRZ7-0301: Barham Import Increase (of 2MI/d) to 4 MI/d	2057	2
AFF-RTR-WRZ7-0639: Deal Continuation After 2020	2020	0.0714
AFF-RTR-WRZ7-0909: Barham Continuation (After 2019/20)	2020	2

6.5.2 In terms of water quality, none of the schemes that we have identified represent new sources so there are no obvious risks from our proposals.

6.6 Our water supply strategy for the East region (WRZ8)

6.6.1 Under our preferred plan we are able to maintain a surplus within the East region throughout the planning horizon based on our demand management activities alone.

6.6.2 As noted previously, there is a risk that we will face substantial (up to 15-20MI/d) reductions in abstraction for our sources within the River Brett catchment in the relatively near term. If that does occur then we may need to construct a desalination plant on the East coast or if the

timing and the volumetric reduction changes a shared alternative option. As well as the costs of constructing this plant we are aware that this would involve a fundamental change in the nature and quality of the source water for many customers. We will therefore need to ensure that the plant design incorporates the necessary water conditioning that would be required to prevent deterioration of our pipe network and water quality if this scheme is required.

- 6.6.3 If a smaller level of reduction occurs then we will explore the opportunity for a more regionally based transfer solution, but the suitability of this will depend upon the timing required by the Environment Agency.

We will continue to liaise with the EA over the potential scale of any abstraction reductions in the River Brett catchment throughout the AMP7 period. We will end the temporary arrangement whereby Anglian receive 70% of the yield of Ardleigh Reservoir and we receive 30% to its usual position of each party receiving a 50% share from 2025/6, although we may bring this forward by a year to manage any sustainability reductions being implemented in December 2024. We believe by doing this we are planning prudently in advance of future uncertain sustainability reductions in the region.

6.7 Environmental assessment of our Plan

Strategic Environmental Assessment

- 6.7.1 We have carried out an updated SEA of our fWRMP19 and of reasonable alternatives against the objectives of our Plan as set out at paragraph 1.4.5 (see Technical Reports 4.10, 4.10.1, 4.11 and 4.11.1). We used this SEA scoring to inform the Multi-Criteria Assessment of our options, and have explained how that was used within our ‘best value’ decision making process in Chapter 5 and the associated technical report (Technical Report 4.9).
- 6.7.2 We assessed nine programmes in total including each of our four futures. We rejected five of these alternative programmes and incorporated four into our adaptive plan, being our four futures. As described at paragraphs 5.7.7 to 5.7.9, one of the alternative programmes was an “environmental adaptive run”, a programme that omitted options which the SEA has flagged as being without mitigation. This generated a plan dependent on meeting very high levels of leakage reduction and demand management and consequently a very high cost for customers and so was rejected. Our adaptive plan includes four reasonable alternatives, those relating to our four futures.
- 6.7.3 We concluded that while some options included within the fWRMP19 could have an adverse impact on the environment there is sufficient time before they are implemented to allow further investigation and assessment to be carried out and where necessary to allow mitigation measures to be developed to avoid potential impacts.

Habitats Regulations Assessment

- 6.7.4 A Habitats Regulations Assessment under the Habitats and Species Regulations 2017 was carried out on the options included in the fWRMP19 (Technical Report 4.12). The screening stage identified two options as likely to have a significant effect on the South West London Waterbodies SPA and Ramsar Site:

- SESR to Harefield transfer of 50 MI/d of water; and
- SESR to Iver 2 transfer of 50 MI/d of water.

The pipelines associated with these options that cause the potential impact would also be used if we adopt an alternative water trading option on the River Thames to replace the SESR as the raw water resource, if AMP7 investigations indicate that this represent a better regional solution. Both of these transfer options provide for a pipeline running adjacent to the South Water London Waterbodies SPA.

- 6.7.5 An appropriate assessment was carried out on these two options. This identified two impacts of potential concern. The first is the potential for construction disturbance on the bird interest features, which are sensitive to noise and visual disturbance during the period October to March inclusive. In line with the HRA recommendation, we will ensure that programming and construction process take into account the proximity of the South West London Waterbodies SPA. We will either avoid the winter period (October to March) entirely or will design our construction programme to ensure noise is maintained at an acceptable level.
- 6.7.6 The second impact of potential concern was the hydrological connectivity of the flooded gravel pits and the local water table, which depending on the depth and construction method used to install the pipeline, could result in the gravel pits being impacted. The HRA concluded that the likely depth of construction of the pipeline will avoid these impacts. We will, however, ensure that this is the case by carefully designing the pipeline, informed by site-specific geotechnical and hydrogeological investigations to ensure there is no requirement for de-watering impacting on groundwater levels.
- 6.7.7 We also considered the in-combination effects of these two options with three Thames Water schemes impacting on the South West London water body (Datchet Groundwater, Kempton WTW and South West London Pipelines) and concluded that there were no in-combination adverse effects taking into consideration the potential for mitigation measures.
- 6.7.8 We will carry out a further project-specific HRA at the detailed design stage and will liaise with Natural England regarding required mitigation measures. We have five other options available to us should, contrary to expectations, we be unable to identify appropriate mitigation measures for these two options. We therefore conclude that our fWRMP19 can be delivered without adverse effect on the integrity of South West London Waterbodies SPA or Ramsar site.
- 6.7.9 We also considered the in-combination atmospheric pollution effects of our fWRMP19 and Thames Water's WRMP on three European sites and the potential for hydrological changes to Oxford Meadows SAC and concluded there were no adverse effects on the integrity of these sites.

Water Framework Directive Assessment

- 6.7.10 We undertook a WFD Assessment of all our constrained supply side options to assess whether the option could result in deterioration of a water body status or prevent a water body from achieving its environmental objectives in the future.

We identified six options in the fWRMP19 with potential for a risk of deterioration in status or of preventing a water body from achieving good status. Two options were identified that may provide a potential improvement to status or allow good status to be achieved.

Table 26: Options in fWRMP with potential adverse impact

Option	Potential Adverse Impact	Potential benefit
Canal & River Trust Slough borehole	Yes	
Iver Greensand borehole	Yes	
Brent Reservoir	Yes	Yes
Birds Green Reservoir	Yes	
Grand Union Canal transfer	Yes	Yes

6.7.11 In most cases, the potential risks can be mitigated by appropriate design and management of the options. For example, measures can be taken to minimise the risk of invasive species for surface water schemes at the point of abstraction and transfer.

The potential risks in relation to options to be implemented post 2030 (Birds Green Reservoir and the GUC transfer) will be investigated further and mitigations identified. In the case of the GUC transfer we will carry out the initial investigations in the first three years of AMP7 in line with our adaptive strategy. We have explained our approach to those options to be delivered or started before 2030 (GSK/Slough borehole development and Brent Reservoir) in Sections 4.7 and 5.8. We will not implement any option unless and until it can be satisfactorily demonstrated that there is no risk of deterioration in WFD status and that there is no risk that an option will prevent achievement of good status. Our “Challenging” future responds to these risks. If we are unable to fully implement these options we will provide our first strategic option by 2038.

6.8 Cost of our Plan

Overview of costs

6.8.1 Table 27 shows our overall planned level of capital investment in our Best Value Plan over the medium-term planning horizon (2045) and longer term planning horizon (2080). The costs are presented in 2017/18 prices. The costs shown include capital investment, operational expenditure, capital maintenance, and environmental, social and carbon costs. Supply side investment has been taken from our ‘expected’ future, but with the first strategic option delivered by 2038 to meet our ‘challenging future’ as part of our adaptive strategy. Demand side costs are based on our ‘optimistic’ future, with the assumption that the 50% leakage reduction target can be met through ALC and supply pipe leakage efficiencies, without additional costs beyond the ‘expected’ future.

Table 27: Summary of revised draft best value Plan costs

Total Expenditure	25 year Total	60 year Total
	2020-45 (£m)	2020 - 80 (£m)
Baseline WSP – Metering programme only (CAPEX)	58.91	58.91
Baseline WSP – Metering programme only (OPEX)	2.47	2.47
Baseline WSP Activities (excluding metering)	7.20	7.20
Baseline WSP total	68.58	68.58
Leakage	356.20	1315.84
Non-household	12.04	24.75
Smart Metering	191.92	715.43
Water efficiency	108.94	115.59
Demand Management schemes	669.10	2171.60
Supply (ground & surface water)	124.55	1861.04
Bulk transfers	0.01	6.31
Network improvements	20.20	98.50
Supply side schemes	144.77	1965.85
Total for Supply and Demand	813.87	4137.45

Cost breakdown

6.8.2 In this section we break down the costs for capital expenditure (capex), operating expenditure (opex) and environmental and social carbon costs, see Table 28. The costs for treatment and deliverability of sustainability reductions are not included within this breakdown as they represent local intra WRZ network changes and are not therefore part of the WRMP analysis.

Table 28: Breakdown of investment within our Plan

	25 Year Total (2020 to 2045)			60 Year Total (2020-2080)		
	Capex (£m)	Opex (£m)	Env, Social & Carbon (£m)	Capex (£m)	Opex (£m)	Env, Social & Carbon (£m)
Leakage	187.16	162.21	6.83	595.47	706.94	13.42
Non-household	0.18	11.88	-0.02	5.00	19.74	0.00
Smart Metering	67.75	123.83	0.34	202.44	512.36	0.62
Water efficiency	0.12	108.63	0.19	0.28	115.17	0.14
Demand Management schemes	255.21	406.55	7.34	803.20	1354.22	14.19

Supply (ground & surface water)	82.94	17.00	24.62	1570.45	190.31	100.28
Bulk transfers	0.00	0.01	0.00	4.82	1.35	0.14
Network improvements	16.39	3.81	0.00	80.87	17.60	0.03
Supply side schemes	99.33	20.82	24.62	1656.14	209.27	100.45
Total for Supply and Demand	354.54	427.38	31.96	2459.33	1563.49	114.63

6.8.3 The resulting carbon emissions that result from the planned investment are provided in Figure 39. Details of the carbon emissions, by scheme, are provided in Technical Report 4.5.




Figure 39: Summary of carbon emissions from our 'Best Value' Plan

6.9 Final supply / demand water balances and WRMP Tables

6.9.1 The individual WRZ supply/demand balances for each of our four futures in the Central region, which demonstrate the timing of schemes and management of surplus, are provided in Technical Report 4.9. This section of the fWRMP19 therefore provides a summary of the overall balances in each of our Regions, according to the data contained in the WRMP final planning Tables.

Central region

6.9.2 The supply/demand balances for the Central region as a whole are provided below. As with the costs presented previously, these balances contain supply side investment from our 'expected' future, but with the first strategic option delivered by 2038 to meet our adaptive strategy, compared with demand management from our 'optimistic' future. This meets our Business Plan commitment of 129 l/p/d (NYAA PCC target) and 18.5% leakage reduction by

the end of AMP7. This also shows a commitment to a long-term leakage reduction of 50% between 2015 and 2045. We have combined the two different futures to demonstrate the risk management benefits of adopting an adaptive strategy; our combination of investigations and timely decision making will ensure customer resilience within the uncertain future that we face. The supply/demand balances and costs contained within the WRMP tables therefore consist of:

- On the supply side, the schemes and utilisation required under our ‘Expected’ future, but with the first strategic development (the SESR) brought forward to meet our ‘Challenging’ future requirement of 2038.
- On the demand side, the demand management and leakage benefits selected under our ‘optimistic’ future.

6.9.3 The individual balances generated by the economic modelling for each future individually are provided in Technical Report 4.9.




Figure 40: Central region final supply / demand water balance under average conditions (DYAA)




Figure 41: Central region final supply / demand water balance under peak conditions (DYCP)

Southeast region




Figure 42: Southeast region final supply / demand water balance under average conditions (DYAA)




Figure 43: Southeast region final supply / demand water balance under peak conditions (DYCP)

East region




Figure 44: East region final supply / demand water balance under average conditions (DYAA)




Figure 45: East region final supply / demand water balance under peak conditions (DYCP)

6.10 Drought levels of service

6.10.1 Table 29 shows our final levels of service in the event of a drought. It sets out the annual likelihood that we will need to place a restriction on water use or make use of drought permits or orders to temporarily increase the amount of water abstracted from our environment. Our fWRMP19 will enable us to meet a 1 in 200-year drought without the use of drought permits or orders post March 2024. These are consistent with our Drought Management Plan

(November 2018). Table 30 provides a comparison of our drought levels of service before and after implementation of our fWRMP19. Once we have introduced this new Level of Service then it remains constant for the duration of the Plan.

Table 29: Our levels of service

Drought Measure	Current frequency in our DMP	Annual probability of implementation	Probability of implementation over 60 years (2020 to 2080)
Temporary Use Ban to restrict non-essential use	1 in 10 years on average	10%	There is a greater than 99% chance of needing this action over 60 years (2020 to 2080).
Ordinary Drought Orders further restricting non-essential use	1 in 40 years on average	2.5%	There is a 78% chance of needing this action over 60 years (2020 to 2080).
Drought Permits / Drought Orders for temporary abstractions	1 in > 40 years on average Will change to 1 in >200 years post March 2024, in line with rdWRMP19, at next annual update of the DMP	<2.5% <0.5% post March 2024	There is less than 78% chance of needing this action over 60 years (2020 to 2080). Post March 2024 this will reduce to less than 26% chance of being needed over 60 years (2020 to 2080)
Emergency drought orders	Deemed an unacceptable drought response but could be used for short periods of time in localised areas as a result of a civil emergency		

Table 30: Summary of the current (fWRMP14) and proposed (fWRMP19) future levels of service to drought

Normal year	Extended periods of dry weather	Plan	Likelihood of implementation of restrictions							
			Increasing drought severity →							
			1 in 10 years (10% a.p) This is likely to be needed, possibly up to 6 times over 60 years (2020 to 2080)	Between 1 in 10 years to 1 in 40 years (2.5% to 10% a.p) There is between 78% and 100% chance of needing these actions over 60 years (2020 to 2080)	1 in 40 years (2.5% a.p) There is a 78% chance of needing these options over 60 years (2020 to 2080)	1 in 60 to 1 in 80 years (1.67% to 1.25% a.p) There is between a 53% to 64% chance of needing to use these actions over 60 years (2020 to 2080)	Between 1 in 60/80 years to 1 in 200 years (1.67% to 0.5% a.p) There is between a 26% to 64% chance of needing to use these actions over 60 years (2020 to 2080)	1 in 200 years (0.5% a.p) There is a 26% chance of needing to use these actions over 60 years (2020 to 2080)	Greater than 1 in 200 years (<0.5% a.p) There is less than 26% chance of needing to use these actions over 60 years (2020 to 2080)	
No likelihood of restrictions	Monitor groundwater levels. Raise awareness and appeal for voluntary usage reductions as situation worsens.	Final plan WRMP14	Introduce Temporary Use Bans (TUBs)	Introduce Ordinary Drought Orders (ODOs) for non-essential use	Maintain: <ul style="list-style-type: none"> TUBs ODOs 	Maintain: <ul style="list-style-type: none"> TUBs, ODOs Introduce: <ul style="list-style-type: none"> Drought permits/orders for additional abstraction Emergency Drought Orders for restrictions on essential use 	Maintain: <ul style="list-style-type: none"> TUBs ODOs Drought permits/ orders for additional abstraction Emergency Drought Orders for restrictions on essential use 	Potential for use of Emergency Drought Orders for standpipes and rota cuts in areas of significant water stress		
		rdWRMP19	Introduce Temporary Use Bans (TUBs)	Maintain: <ul style="list-style-type: none"> TUBs 	Introduce Ordinary Drought Orders (ODOs) for non-essential use		Maintain: <ul style="list-style-type: none"> TUBs ODOs 	Maintain: <ul style="list-style-type: none"> TUBs ODOs Introduce: <ul style="list-style-type: none"> Drought permits/orders for additional abstraction Emergency Drought Orders for restrictions on essential use 		

a.p = annual probability – this is the chance of a drought of this severity occurring in any given year.

N/B: As stated in our Drought Management Plan we consider the use of emergency drought orders for rota cuts and standpipes to be unacceptable. We consider that standpipes would only ever be deployed as a last resort in the event of a civil emergency and more than likely at a very local level for a short period of time to deal with a significant threat. In an event that the drought was to reach a level of severity requiring this action we would enact our Emergency Plan and restrictions would likely only need to be implemented in areas of significant water stress.

6.11 Alignment of our Plan with other companies' WRMPs

Introduction

6.11.1 Significant coordination has been undertaken between ourselves and other water companies when producing our respective WRMPs. This included coordination between the companies on approaches to adaptive planning, checking volumes of existing and proposed transfers and shared options to address deficits in supply-demand balance. As part of both the Business Plan and WRMP updates we have directly co-ordinated with Thames, Anglian, Southern, United Utilities and Severn Trent Water to ensure our proposals for AMP7 strategic scheme investigations are fully aligned. The dates presented for our adaptive strategy and monitoring plan reflect that process.

6.11.2 Technical Report 5.2 provides a detailed record of our work with all of our neighbouring companies and third parties.

Thames Water

6.11.3 We have already detailed how our adaptive plans align with Thames Water in Section 6.4, where we show that we have continued to liaise with them during the rdWRMP19 consultation period and worked with them to develop investigation proposals for the SESR option and the River Thames to Affinity transfer proposal. In addition to this, we note that our plans are aligned in the following ways:

- The timing of the need and development timescale (15 years) for the SESR option and the sharing of yield between our two companies.
- The costs and development period of the SESR (shared 1/3 Affinity Water and 2/3 Thames Water, with the same 15 year development programme).
- Confirmation of the timing of the Severn Thames Transfer, and in particular its availability if water trading from that option becomes a preferred replacement for SESR.
- The separate investigation and development of the River Thames to Affinity Transfer, which is timed to run in parallel to both the SESR and STT investigations and could be used for either option.

6.11.4 This alignment is supported by a commitment, via the WRSE group, to carry out economic and 'system simulation' analysis of strategic options for the south east to confirm the best value solution, including factors such as resilience and yield implications from our development proposals as part of that process. That work has been timed to support the decision points contained within our adaptive strategy.

Anglian Water

6.11.5 Our fWRMP19 is aligned with Anglian Water's WRMP in the following ways:

- The current modelling of the DO at Grafham is based on a 1:200 drought event, the two companies will work together to model the impacts of a 1:500 scale event going forward and will assess the potential impacts when that work becomes available.
- Both companies agree that should there be an impact on the deployable output of the Grafham source that would affect the operational ability of either company to supply customers (e.g. outage or extreme drought) that they will work together to provide a solution for both parties, as at present.
- Joint development of investigation proposals for the South Lincolnshire reservoir and associated Eastern Strategic Transfer (ETS) that run parallel to the Thames Water related schemes described above.

Southern Water

6.11.6 We will liaise with Southern Water as part of the all company working group on strategic regional options, and through the WRSE modelling described above, which will provide the regional understanding of the joint economic benefits of pursuing the different strategic options that are open to us.

7 Regional collaboration and links to other plans

7.1 Introduction

7.1.1 In this section, we:

- introduce the regional and national water resources work and further expand on how our fWRMP19 compares to the national and regional projects
- set out our approach to the development of water trading
- explain how this fWRMP19 links to other types of plan.

7.1.2 Regional collaboration provides an opportunity to develop strategic regional scale solutions across multiple company areas. These may be more effective or efficient than local solutions or may reduce overall environmental impacts.

7.1.3 Collaboration within the wider context of the East and South East of England is an important consideration for all our supply regions. They all share water in some way with other water companies, and our preferred plans or potential adaptive solutions for all regions involve collaboration with other water companies or other strategic partners from outside of our immediate company area.

7.2 Regional co-ordination

7.2.1 In this section, we outline the work of the WRSE and Water Resource East (WRE) groups on regional water resource planning. As discussed in Chapter 6, our adaptive strategy contains a commitment to carry out regional economic and system resilience testing to determine the 'best value' strategic solution for the region as a whole.

Water Resources in the South East (WRSE)

7.2.2 WRSE is an alliance of the six south east water companies, the Environment Agency, Ofwat, Consumer Council for Water, Natural England and Defra, to develop long term plans for securing water supplies in the south east. The water companies are:

- Affinity Water
- Portsmouth Water
- SES Water
- South East Water
- Southern Water
- Thames Water

7.2.3 The WRSE undertakes cross-boundary modelling across multiple companies to identify schemes which would be beneficial for the South East on a regional scale. Since fWRMP14, WRSE has extended its modelling approach to test resilience, by:

- modelling supply and demand to beyond worst historic drought severity; and
- testing the resilience of regional portfolios of options to increasing demand and sustainability reductions with and without the use of drought orders and drought permits.

7.2.4 The WRSE modelling process is iterative and multi-phased, allowing for output reviews, modifications and additional options to be added.

- 7.2.5 During our development of the fWRMP19 decision-making process we chose to align our economic modelling approach with that of the WRSE. That meant we:
- used the same ‘aggregated’ EBSD method for least-cost economic modelling, and applied scenarios to it using aggregated methods (i.e. single supply-demand balances for each of the discrete future scenarios that we considered)
 - where appropriate, we used the same stochastically generated data sets to calculate the impact on our resources of severe (1 in 200 year) drought events
 - aligned all of our underlying economic modelling assumptions with WRSE.
- 7.2.6 Since the rdWRMP19 we have updated our supply, demand and options inputs to the WRSE model. This includes updating our demand management options, the removal of Chalk groundwater options in our Central region and updating information and costs for the strategic regional options.
- 7.2.7 We have compared our fWRMP19 with the WRSE Phase 5 results which were released in April 2019. The Phase 5 results included:
- 11 least-cost scenarios
 - one sensitivity model run per company
 - a set of preferred fWRMP19 regional runs where the start dates for each option were included and
 - one set where the model was allowed to select the timing of the preferred fWRMP19 options.
- 7.2.8 Table 31 provides a comparison of our fWRMP19 preferred programme with the WRSE Phase 5 least cost Scenario 4 (S4) and the equivalent preferred plan regional scenario where the strategic option timing is fixed (Se4-1c).
- 7.2.9 The latest modelling contained within WRSE Phase 5 Scenario 4 selects:
- medium demand
 - severe drought DO (1:200)
 - 50% uncertainty of sustainability reductions
 - use of Temporary Use Bans (TUBs)
 - no use of drought orders
 - no use of drought permits
- 7.2.10 Set 4-1c uses the same parameters except that SESR option is a forced selected in the 2030s. Table 1 shows that the WRSE Phase 5 least-cost Scenario 4 results are closely aligned with our fWRMP19.

Table 31: Comparison of our fWRMP19 preferred programme with the WRSE Phase 5 least cost Scenario 4 and the equivalent preferred plan regional scenario

Option Type	fWRMP19 options (Expected Future)	WRSE Set 1-4 Scenario 4 (S4)	WRSE S4 Key comments	WRSE Preferred Plan S4 (Set4-1c)	WRSE Preferred Plan S4-1c Key comments
Demand Management	11	13		13	
Groundwater	7	5		4	
Network Constraint Removals	1	1		1	
Company Transfers	3	6		6	
Inter-company Transfers*	4	6	Initial strategic regional options selected	6	Initial strategic regional options selected
Surface Water Options	2	0		0	
Effluent re-use, desalination, treatment works	3	2	Strategic new treatment works linked to strategic regional imports	2	Strategic new treatment works linked to strategic regional imports
Demand Management	11	13		13	

7.2.11 We further note that:

- in all the regional model runs a strategic regional option is selected for Affinity Water. In most cases this is by the 2030s or 2040s
- the first strategic regional option selected in our fWRMP19 (the SESR option) continues to be selected in most of the regional least cost runs, as is our secondary option (the GUC transfer).

7.2.12 WRSE acknowledges that its current modelling approach is too simple to reliably determine the timing and order of strategic developments. For example, the current, simple EBSD modelling does not account for the fact that the opportunity cost associated with constructing large options (from generating spare capacity) varies depending on how much alignment there is between the timing of need between different companies. That timing depends on uncertainties in:

- supply (climate change and sustainability reductions)
- demand (growth and PCC) and
- benefits from supply and demand side options.

7.2.13 WRSE intends to address these issues and have details on the preferred regional timing of options prior to our key 2023 first adaptive decision point and draft WRMP24 publication.

7.2.14 WRSE are now in a process of reviewing their economic model to incorporate adaptive approaches and more sophisticated management of uncertainty within the economic appraisal. This will be used during 2021 and 2022 to inform the adaptive strategies of Thames Water and Affinity Water. WRSE are also scoping out the requirements of the ‘system simulation’ model that they will use to evaluate how the separate water company supply systems respond jointly to drought events, and how the investment proposals generated by the economic model affect the river flows and water resource systems across the companies of the South East of England. These models will be used iteratively to develop a regional plan for the south east of England, which will form the basis of the next round of WRMPs and provide a critical support to the final decisions that need to be made in relation to the strategic schemes in 2022 and 2023.

Water Resources East (WRE)

7.2.15 WRE brings together regulators, companies, retailers and individuals in the water, agriculture, power and environmental sector to develop an affordable, sustainable and resilient regional approach to water resource management. The water companies are:

- Anglian Water
- Cambridge Water (South Staffs)
- Essex and Suffolk Water (Northumbrian)
- Affinity Water (East).

7.2.16 WRE has developed a model that simulates the key supplies of water and demands for water based on the system configured to start at the end of AMP7 (i.e. 2025). The purpose of the regional simulator is to help inform the decision-making process and is central to the implementation of WRE.

7.2.17 The regional simulator is the means of assessing the vulnerability of the system (at the end of AMP7), initially testing whether the AMP7 system will perform adequately for a range of future scenarios. It is used to identify and short-list portfolios of interventions and for the stress testing of these candidate portfolios.

7.2.18 Initial WRE modelling suggests that future demand could lead to increased discharges in certain catchments, which may in time form the basis for future options to re-circulate this water for supply and thus create more sustainable catchments. The way the model represents ‘boundary conditions’ is important, especially the boundary between WRE and WRSE (which is shared with our Central region).

7.2.19 The WRE regional modelling will need to support the assessment of the costs and viability of the South Lincolnshire Reservoir and associated ETS. We will therefore be working closely with Anglian Water and WRE during the 2019 to 2023 period to interpret those results on a timescale that runs parallel to the WRSE modelling described above.

National Level Initiatives

7.2.20 Since the submission of the draft WRMPs, government, regulators and senior water industry representatives have been working together and discussing the future of resilient water

supplies and the potential for greater regional coordination. In the lead up to the publication of our fWRMP19 those discussions have led to the development of a national framework for water resources. The national framework aims to:

- provide strategic direction to water resources planning,
- include water users outside the water industry and
- promote collaboration.

7.2.21 This national level view will be crucial to the development of the regional plans, effectively providing them with guidance on the scenarios and ‘boundary conditions’ that they will need to include within their analyses.

7.2.22 As well as the national modelling initiative, the economic and environmental regulators have joined to form the Regulatory Alliance for the Promotion of Infrastructure Development (RAPID). Amongst other duties this body is likely to form the primary external governance control on the investigations and initial promotion of the strategic schemes that are proposed within our adaptive strategy.

7.3 The National Water UK study

7.3.1 The National Water UK Study (Water UK, 2016) project was established to provide analysis to support a national, strategic and long-term view of water needs across the whole country.

7.3.2 The primary aim of the study was to develop a strategy and framework for the long-term planning of water resources at a national level, up to 50 years into the future, and in doing so to assess the long-term water needs and the available options to meet them.

7.3.3 The following conclusions were drawn by the study:

- there is a significant and growing risk of severe drought impacts arising from climate change, population growth and environmental drivers
- that there is a strong case for government to promote a consistent national minimum level of resilience for water resources
- the investment needed to increase resilience is ‘modest’ compared to the potential costs from drought and flood and therefore there is an economic benefit of increased resilience
- a twin-track approach is required by companies, which includes supply enhancement and transfer (between companies) and demand management, as being the best strategic mix for the future resilience to drought
- there is a strong case for ‘adaptive planning’ to support company WRMPs, including ‘trigger points’ prior to the 2040 and 2065 horizons analysed in the report.

7.3.4 The major conclusions of the study relating to Affinity Water were that:

- our area is among five areas in the country where the impacts of reductions in abstraction, from licence reduction to protect the aquatic environment, would be most significant to a water company's supply-demand balance
- the modelled demand management savings were reliant on significant behavioural change and the study note that they were ambitious and potentially risky
- 'extended' demand management requiring behavioural change, metering related initiatives and greater efficiency in leakage control are required to meet future challenges
- 'enhanced' water efficiency involving the use of household level water re-use and wide spread mains replacement for leakage were not cost beneficial, or required to maintain long term supply/demand balances.

7.3.5 Our fWRMP19 features the future provision of strategic infrastructure of regional scale and is therefore consistent with the national long-term strategy for national scale water resource resilience. Our fWRMP19 proposals for water efficiency are also broadly aligned, although under our 'Aspirational' future we will be looking for ways to introduce some household level water re-use within new developments, if policy support is available.

7.4 Future development of water trading

7.4.1 In this section, we outline our approach to facilitating the development of water trading.

Water trading options

7.4.2 Our preferred strategy includes liaison with Thames Water, United Utilities and Severn Trent to review the cost effectiveness of large-scale bilateral trades during AMP7. We will also continue with our work on identifying and, where possible, implementing other trades. We are currently analysing, and have included in our Plan, a cross-sector option to use water currently being utilised in the energy industry (referred to as the River Thames small Licence Trading option). This would extend the concept of conjunctive use across sectors and would potentially involve a licence-sharing scheme to benefit customers of both the energy and water industries through efficient transfer of capacity during non-coincident periods of utilisation.

7.4.3 Whilst the option is at an early stage of development, we are continuing to explore the potential to utilise the option and we are following the same process of option screening and feasibility as our other fWRMP19 options. The option does nevertheless represent an interesting opportunity.

7.4.4 We are interested in opportunities to trade with any party that either wishes to take from us, or offer to us, a reasonable volume of reliable, sustainable and cost-effective water resources. During pre-consultation for our dWRMP19 we invited offers for trading new supplies under our current procurement process.

- 7.4.5 We have developed a Bid Assessment Framework (“BAF”) to support the market for water resources, demand management and leakage services. It provides the framework for potential bidders to understand the context, scope, principles and process by which third party providers can bid to supply us with these services and gives confidence that third party bids will be assessed fairly alongside in-house solutions.
- 7.4.6 Our BAF includes development of a new “Water Trading Portal” to act as a repository of information, publicise new opportunities and serve as a single point of reference for potential bidders. It explains clearly the stages of our procurement process and how this will interact with development of our future water resources management plans. It also explains that third party and in-house options for new supplies of water are assessed using the EBSD model based on multi-criteria analysis.
- 7.4.7 Our BAF sets out two routes for procuring demand management services from third parties. We may seek these in a traditional manner where we have determined the nature of the demand management service we wish to procure. However, we also want to seek “demand management options” where bidders are invited to propose solutions for delivering a defined volume of demand reduction. These will be assessed using the EDBD model based on multi-criteria analysis and again we will publish standardised criteria to enable bidders to understand how their options will be assessed.

Consistent transfer pricing

- 7.4.8 We have also developed a specific operational accounting tool for our operational zones from District Meter Area level upwards to facilitate a transparent access price. The Activity Based Costing model collates all maintenance and replacement costs associated with our infrastructure and non-infrastructure assets to build accurate and reliable site and transfer prices per zone.

7.5 Links to other types of plans

- 7.5.1 In this section, we consider how our fWRMP19 links to other plans.

PR19 Business Plan

- 7.5.2 As part of the Initial Assessment of Plans (IAP) by Ofwat in January 2019, Ofwat identified from the draft WRMPs and business plans that at least one of the schemes that might be needed for balancing supply and demand across the south east of England would need to be ready for development by the end of AMP7. The regional development should be complemented by smaller short-term supply options (delivery <5 years), localised long-term options, water efficiency programmes and leakage management. This fWRMP19 is consistent with the Business Plan and associated evidence that was submitted to Ofwat in response to their IAP. This includes the timing of investigation and development of strategic options that was submitted in response to Ofwats’ proposals.

The Water Industry Strategic Environmental Requirements

- 7.5.3 The Water Industry Strategic Environmental Requirements (WISER) document, provides steer from Natural England and the Environment Agency on strategic priorities for the next Price Review. It describes the environmental, resilience and flood risk expectations for Water Company Business Plans. Technical report number 1.4.2. that accompanies this Plan shows the expectations in the WISER document relating to our WRMP and how we already meet or plan to meet these objectives in our planning.

Drought Management Plan

- 7.5.4 Our current Drought Management Plan (DMP) was published in November 2018, covering five years until 2023. The purpose of the DMP is to demonstrate how we plan to monitor and manage future drought related events, reduce the demand for water and mobilise extra resources, whilst minimising the need to implement drought orders and permits and ensuring security of supply. It is an operational plan, setting out the policy and steps we would take during a drought. The WRPG states that WRMPs should be appropriately linked to a company's DMP, and we have ensured this through the calculations of supply side availability and the savings on demand through customer side restrictions within this fWRMP19.

EA drought planning process

- 7.5.5 Where our WRMP links to our DMP, this in turn links to the EA drought planning process. We worked closely with the EA to develop our DMP, and this ensured consistency between actions identified within the respective plans. The document, 'Drought response: our framework for England (Environment Agency, 2017a)', sets out how the EA works with government, water companies and others to manage the effects of drought on people, business and the environment. It sets out who is involved in managing drought and how the EA and stakeholders work together to act to manage drought.

River Basin Management Plans

- 7.5.6 We have regard to the River Basin Management Plans when exercising our functions, including producing our fWRMP19. The purpose of a River Basin Management Plan (RBMP) is to provide a framework for protecting and enhancing the benefits provided by the water environment. RBMPs are published by the EA.
- 7.5.7 The last publications were in 2015 and were therefore reflected in our previous WRMP14 Plan, covering the current 2015 to 2020 period. We continue to support the development of the current RBMPs. Our supply area covers three river basin districts (RBD); the Thames, South East and Anglian RBD. The environmental objectives of WFD are to:
- prevent deterioration of the status of surface waters and groundwater
 - achieve objectives and standards for protected areas
 - aim to achieve good status for all water bodies or, for heavily modified water bodies and artificial water bodies, good ecological potential and good surface water chemical status.

7.5.8 We have taken account of these objectives when making decisions that could affect the ecological status of the water environment. Our rdWRMP19 recognises that:

- the objective of no deterioration requires that new or modified abstractions should not adversely affect the status of a water body
- the aim of achieving good status should not be inhibited by existing abstractions.

7.5.9 The objectives of these three RBMPs have been reviewed in conjunction with our fWRMP19 options and proposed sustainability reduction strategy for AMP7. In combination with the abstraction reductions, we are also delivering in partnership with the EA and other catchment partners, an extensive programme of morphological mitigation (river restoration and habitat enhancement works), one of the largest in the water industry. Further details on this work are included in Technical Report 1.4.1.

Local Plans

7.5.10 Our supply area is expected to witness significant population growth in the future. We have estimated that our population is forecast to increase in the order of 12% by 2025, 27% by 2045 and 51% by 2080 (equivalent to approximately 1.8 million more people in our supply area). As a result, we have undertaken work to forecast the total water demand in our supply area over our chosen planning period, to assess whether an imbalance exists between supply and demand (see section 3 for further detail). This work has taken account of the housing and population estimates contained within local plans, using water industry standard best practice methods.

8 Board assurance and governance

8.1 Introduction

8.1.1 In this Statement, as a Board, we set out how we have effectively overseen the preparation of this fWRMP19, and how we have assured ourselves that our fWRMP19 represents the most cost effective and sustainable long-term solution for managing and developing water resources so as to be able, and continue to be able, to meet the Company's water supply obligations under Part III of the Water Industry Act 1991.

8.2 Governance

8.2.1 We have established a Water Resources Management Plan Committee to help us discharge our responsibilities as a Board with respect to development of our fWRMP19. The Committee comprises:

- Tony Cocker (Committee Chairman)
- Chris Bolt (Non-executive Director)
- Tony Roper (Non-executive Director)
- Pauline Walsh (Chief Executive Officer)
- Tim Monod (Director of Legal and Assurance)

8.2.2 The Committee invited individuals from the project team to attend Committee meetings as non-members including Marie Whaley (Interim Director of Asset Strategy), Doug Hunt (Project Director) and Julie Smith (Head of Legal Services).

8.2.3 The Committee provided oversight and scrutiny of development of this fWRMP19 to ensure it represents the most cost effective and sustainable long-term solution and meets legal requirements and relevant guidelines.

8.3 Assurance

8.3.1 The Committee reviewed and approved the assurance plan for this fWRMP19 developed by the project team and supported by external specialist providers.

8.3.2 We have obtained technical assurance from Atkins Limited with respect to preparation of our fWRMP19 and its adherence to the Water Resources Planning Guidelines and the Water Resources Management Plan (England) Direction 2017. A report from Atkins Limited detailing its findings will be published alongside our final WRMP19.

8.3.3 We have also obtained technical assurance from Ricardo Energy & Environment of the SEA, HRA and the WFD assessment. A report from Ricardo Energy & Environment setting out its findings will be published alongside our fWRMP19.

8.3.4 Our fWRMP19 has also been subject to legal assurance, with specific reference to the requirements of SEA and HRA.

8.4 Summary

- 8.4.1 We have reviewed this fWRMP19 and the assurance reports provided by Atkins Limited and Ricardo Energy & Environment and comments and views provided by Counsel following legal review.
- 8.4.2 We are satisfied that the fWRMP19 represents the most cost effective and sustainable long-term solution for managing and developing water resources so as to be able, and continue to be able, to meet the Company's water supply obligations under Part III of the Water Industry Act.
- 8.4.3 We are further satisfied that our fWRMP19 takes account of all statutory drinking water quality obligations, and that it includes plans to meet our statutory obligations in this respect in full. We approve the fWRMP19 on behalf of the Board.

A handwritten signature in black ink that reads "Tony Cocker".

Tony Cocker

Chairman

Appendix: List of Technical Reports

	Category	ID	Title
	MAIN REPORT	1	Final Water Resources Management Plan 2020-2080
1	SUPPLY	1.1	Deployable Output and Climate Change Impact Assessment
		1.1.1	Deployable Output and Drought Plan links
		1.2	Climate Change Assessment report - Basic and intermediate (HRW)
		1.3	Climate Change Vulnerability Assessment
		1.4	Sustainability Reductions
		1.4.1	AMP6 NEP Progress and Summary of WINEP PR19 Schemes
		1.4.2	WISER Addendum
		1.5	Water Resource Zone Integrity
		1.6	Drought Management Plan 2018
		1.7	Problem Characterisation Report
2	DEMAND	2.1	Household Demand Forecast - MLR Modelling Report
		2.2	Household Demand Forecast - Micro-Component Report
		2.3	Domestic Housing and Population Forecast
		2.3.1	Population, Household and Dwellings Forecasts (Experian)
		2.4	Non-Household Demand Forecasting Summary Report
		2.5	Dry Year Annual Average (DYAA) and Critical Period Factors Analysis
		2.6	Metering Cost Benefit Analysis
		2.7	Overarching Demand Forecast Report
3	RISK AND UNCERTAINTY	3.1	Outage
		3.2	Headroom
4	OPTIONS AND EBSD	4.1	Unconstrained Options Report - Supply Options
		4.2	Unconstrained Options Report and Screening Results - Demand Management Options
		4.3	AECOM Screening Methodology (Supply Options)
		4.4	LRMC Cost Model Update
		4.5	Supply Side and Constrained Options Report Vol 1
		4.6	Supply Side and Constrained Options Report Vol 2
		4.7	Water Demand Management Framework - Assessment of Demand Options
		4.8	Leakage Strategy Report
		4.8.1	ELL and SELL Determination 2016
		4.9	Economics of Balancing Supply and Demand Modelling and Decision Making Process
		4.10	SEA Scoping Report v1
		4.10.1	SEA Scoping Report v2
		4.11	SEA Environmental Report
		4.11.1	SEA Environmental Report Appendices
4.12	Habitat Regulations Assessment		
4.13	Water Framework Directive Report		
4.14	Supply 2040		
5	REGIONAL MODELLING	5.1	National and Regional Water Resources Modelling Report
		5.1.1	Addendum to National and Regional Water Resources Modelling Report
		5.2	Water Company and Third Party Bulk Transfers
		5.3	Strategic Regional Options Programme
6	REPORT PRODUCTION	6.1	WRP Tables and Commentary & Exception Report
7	CONSULTATION AND ENGAGEMENT	7.1	Engaging with Customers, Communities and Stakeholders

Abbreviation list and Glossary

ADO	Average Deployable Output – the average output of a source.
AMP	Asset Management Plan / Period – five-yearly cycle covered by a water company’s business plan.
AONB	Area of Outstanding Natural Beauty – an area of land protected by the Countryside and Rights of Way Act 2000 to conserve and enhance its natural beauty.
Annual Return	Annual performance report provided by a water company to Ofwat.
BAF	Bid Assessment Framework – our framework for potential providers of water resources, demand management and leakage services, explaining how we will ensure we fairly assess third party bids for these services against in-house solutions.
CAMS	Catchment Abstraction Management Strategies – assess the amount of water available in each river catchment.
CaMKOx	Cambridge -Milton Keynes-Oxford development corridor.
Capex	Capital Expenditure – the money that is used to fund the installation of new water infrastructure.
CCG	Customer Challenge Group – independent local groups of customer representatives and other stakeholders established for the price review process to provide challenge to water companies’ business plans.
CRT	Canal & River Trust – a charity looking after 2000 miles of waterways.
CSA	Customer & Stakeholder Analysis – a technique for stakeholder identification and analysing their needs.
DCO	Development Consent Order – the means of obtaining planning permission for developments categorised as Nationally Significant Infrastructure Projects.
DEFRA	Department for Environment, Food and Rural Affairs.
DI	Distribution Input – the amount of water entering the distribution system.
DO	Deployable Output – the output of a commissioned source or group of sources assessed under drought conditions.
Drought Order	An authorisation granted by the Secretary of State under the Water Resources Act 1991, which imposes restrictions upon the use of water and/or allows for abstraction/impoundment outside the schedule of existing licences on a temporary basis in the event of a drought.
Drought Permit	An authorisation granted by the Environment Agency under the Water Resources Act 1991, which allows for abstraction/impoundment outside the schedule of existing licences on a temporary basis in the event of a drought.

DMA	District Metered Area – a collection of water mains in an area that are isolated such that there is only one (or sometimes more) feed, this feed is metered and the volume of water supplied to the area or zone can be regularly monitored to check for leakage.
DMP	Drought Management Plan – a statutory plan which sets out how the company will supply water in the event of a drought situation.
DWI	Drinking Water Inspectorate – the DWI is responsible for assessing the quality of drinking water in England and Wales, taking enforcement action if standards are not being met, and appropriate action when water is unfit for human consumption.
DYAA	Dry Year Annual Average – the annual average value of demand or deployable output or other parameter over the course of a dry year.
DYCP	Dry Year Critical Period – the time in a dry year when demand is greatest, often taken to be the peak week.
EA	Environment Agency – a non-departmental public body with statutory functions relating to protection of the environment.
EBSA	Economics of Balancing Supply and Demand – a model used in water resources future planning
GARD	Group Against Reservoir Development.
GES	Good Ecological Status – the principal objective for most water bodies under the Water Framework Directive, defined as a slight variation from undisturbed conditions.
GLA	Greater London Authority – the developed regional governance body of London with jurisdiction over both counties of Greater London and the City of London.
GUC	Grand Union Canal – a canal linking London to Birmingham.
HDZ	Hydraulic Demand Zone – zone characterised by having discrete supply and storage arrangements with strategic inter zone transfers.
HRA	Habitats Regulations Assessment – an assessment of the effect of a plan or project on a protected European site carried out under the Conservation of Habitats and Species Regulations 2017.
HS2	High Speed 2 – a high speed railway connecting London to Birmingham, the East Midlands, Leeds and Manchester that is currently under construction within parts of the Affinity Water supply area
INNS	Invasive Non-Native Species – a species that does not occur naturally in an area and that becomes so abundant that it damages biodiversity and often causes substantial economic or health problems.
l/h/d	Litres per head per day – a unit of measurement detailing in litres how much water each customer uses each day
LoS	Levels of Service – a measure of the likelihood of applying restrictions on customers during drought conditions or taking additional measures such as increasing abstraction from a particular source or reducing augmentation. They set out how

often on average we expect that we will need to take a specified step in response to a drought

MCA	Multi-criteria analysis – using multiple criteria to assess key risks.
MI/d	Mega litres per day – one million litres per day. Just under half the volume of an Olympic swimming pool.
MLR	Multi-linear Regression – most common form of linear regression analysis. Used to explain the relationship between one continuous dependent variable and two or more independent variables.
NERC Act	Natural Environment and Rural Communities Act 2006.
NIC	National Infrastructure Commission – non-ministerial government department responsible for providing expert advice to HM Government on the pressing infrastructure challenges facing the UK
NGO	Non-Governmental Organisation – a non-profit organisation that operates independently of government, typically one whose purpose is to address a social or political issue.
NYAA	Normal Year Annual Average - the annual average value of demand, deployable output or other parameter over the course of a normal year.
OBHs	Observation boreholes – a borehole drilled to monitor groundwater levels
Ofwat	The Water Services Regulation Authority, or Ofwat, is the body responsible for economic regulation of the privatised water and sewerage industry in England and Wales.
Opex	Operational Expenditure – money that is used to fund the day to day operation of the water company.
PCC	Per Capita Consumption – the volume of water consumed per household customer per day.
PDO	Peak Deployable Output – the maximum output of a commissioned source under periods of peak (summer) demand.
PHC	Per Household Consumption – the water consumption that is consumed by a household in one day.
RBD	River Basin District – means the area of land and sea, made up of one or more neighbouring river basins together with their associated groundwaters and coastal waters, which is the main unit for management of river basins under the Water Framework Directive.
RBMP	River Basin Management Plans – a plan produced for a river basin district under the Water Framework Directive setting out information about water bodies within that river basin district, their environmental objectives and measures to be taken to achieve those environmental objectives.

SACs	Special Area of Conservation – area of land designated under the Habitats Directive (Directive 92/43/EEC) to protect habitats and species considered to be European interest.
SEA	Strategic Environmental Assessment – an assessment of the environmental impacts of certain plans and programmes likely to have significant effects on the environment carried out under the Environmental Assessment of Plans and Programmes Regulations 2004.
SIC	Standard Industrial Classification – a system for classifying the nature of a company’s business by a four-digit code used by government agencies.
SoR	Statement of Response – a document explaining how we have considered representations on our draft WRMP prepared under the Water Resources Management Plan Regulations 2007.
SPA	Special Protection Area – a designation under the European Union Directive on the Conservation of Wild Birds (Directive 2009/147/EC).
SPL	Supply Pipe Leakage – leakage from pipes that customers are responsible for.
SSSI	Site of Special Scientific Interest – an area of land designated under the Wildlife and Countryside Act 1981 as being of special interest by reason of its flora, fauna or geological or physiographical features.
THR	Target Headroom – the minimum buffer to cater for supply-side and demand-side uncertainties in the overall supply demand balance
TRACE	Track down Reliability Availability Cause and Effect – an outage recording system used at Affinity Water
TUB	Temporary Use Ban – demand management action which temporarily restricts non-essential use of water by customers during a drought (formerly a ‘hosepipe ban’)
UKWIR	UK Water Industry Research – UKWIR was set up by the UK water industry in 1993 to provide a framework for the procurement of a common research programme for UK water operators.
WAFU	Water Available for Use – the total volume of all the water that we are able to produce and make available to supply customers the water that is available for supply within each WRZ. It is equal to the DO, minus outage, minus treatment losses plus or minus the net imports and exports from the WRZ.
WATCOM	Water Consumption Monitor – our stratified sample of unmeasured households established in 1997 and since used to assess unmeasured household consumption.
WFD	Water Framework Directive – European Union Directive 2000/60/EC, which establishes a framework for the protection of inland surface waters, transitional waters, coastal waters and groundwater.
WINEP	Water Industry National Environment Programme – a programme of investigations and actions for environmental improvement schemes.

WISER	Water Industry Strategic Environmental Requirements – a document published by the Environment Agency and Natural England which provides a strategic steer to water companies on the environment, resilience and flood risk for business planning purposes.
WRMP	Water Resources Management Plan – a plan prepared by a water company under Section 37A to Section 37D of the Water Industry Act 1991 setting out how the water undertaker will manage and develop water resources so as to be able, and continue to be able, to meet its obligations under Part III of the Water Industry Act 1991.
WRPG	Water Resources Planning Guideline - Interim Update (July 2018) published by the Environment Agency. It is designed to help water companies prepare their WRMP in accordance with relevant statutory requirements and, where appropriate, government policy.
WRE	Water Resources East – a multi sector regional planning group. WRE brings together regulators, companies, retailers and individuals in the water, agriculture power and environmental sector to develop an affordable, sustainable and resilient regional approach to water resource management.
WRP Tables	The water resources planning tables forming part of this rdWRMP19 containing the information required by the WRPG.
WRSE	Water Resources South East – an alliance of the six south east water companies, the EA, Ofwat, Consumer Council for Water, Natural England and Defra, to develop long term plans for securing water supplies in the south east.
WRAS	Water Regulations Advisory Scheme – The scheme is operated by UK water suppliers to contribute to the protection of public health by preventing contamination of public water supplies and encouraging the efficient use of water by promoting and facilitating compliance with the Water Supply (Water Fittings) Regulations 1999.
WRZ	Water Resource Zone – the largest possible zone in which all water resources, including external transfers, can be shared and hence an area in which all customers will experience the same risk of supply failure from a water resource shortfall.
WSP	Water Saving Programme – our programme of work to reduce household consumption. It includes switching customers from unmeasured charges to metered charges (compulsory metering), home water efficiency checks and the provision of water savings devices and educational materials.
WTW	Water Treatment Works – facilities belonging to a water company that treat water to prescribed standards for drinking water.